



Kenya Power

*Central Office – P.O. Box 30099 – 00100,
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road,
Nairobi, Kenya*

Our Ref: KP1/9A.3/OT/09/17-18
Your Ref:

Date: 21st November, 2017

TO: ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

RE: ADDENDUM NO. 4. TO THE TENDER NO. KP1/9A.3/OT/15/17-18 FOR SUPPLY OF POWER TRANSFORMERS

Please refer to the above Tender.

The following amendments are made to the specified provisions of the Tender document for the Supply of Power Transformers.

1) RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2) ON LOAD TAP CHANGER

As per clause 4.12.8 the tap changer shall be of design and make approved by KPLC. The make and design approved by KPLC is **MR Germany**.

3) CLOSING DATE

The tender closing date remains the same on **30th November, 2017**

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED


BERNARD NGUGI
GENERAL MANAGER SUPPLY CHAIN.