



---

*The Kenya Power & Lighting Co. Ltd.*  
*Central Office – P.O. Box 30099, Nairobi, Kenya*  
*Telephone – 254-02-3201000-Telegrams 'ELECTRIC'- [www.kenyapower.co.ke](http://www.kenyapower.co.ke)*  
*Fax No. 254-02-3514485*  
*StimaPlaza, Kolobot Road*

**Our Ref. KP1/6E.1/.PT/1/17/A01/JKG/eo**

**7<sup>th</sup> April, 2017**

Dear Sir/ Madam

**ADDENDUM NO.1 - TENDER NO. KP1/6E.1/.PT/1/17/A01 FOR PROCUREMENT OF PREPAID ENERGY METERS AND METERING ACCESSORIES - LAST MILE CONNECTIVITY PROJECT (LMCP)-II**

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT.**

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

**2. CLARIFICATIONS TO TENDER**

The following responses are made to clarifications sort on various issues in the Tender document for Procurement of Prepaid Energy Meters and Metering Accessories - Last Mile Connectivity Project -II (LMCP) and shall be deemed to form the addendum.

<b>Item</b>	<b>Query by Bidders</b>	<b>KPLC Responses</b>
1	We found your tender online regarding meter box and very interested in. (Last Mile Connectivity Project II - Supply of Prepaid Energy Meters and Metering Accessories).	The tender can be accessed in the e Kenya Powers website <a href="http://www.kplc.co.ke">www.kplc.co.ke</a>  The tender number is KP1/6E.1/.PT/1/17/A01 For

Item	<i>Query by Bidders</i>	<b>KPLC Responses</b>
	We are 10 years meter box customize manufacturer in China looking for cooperation. Would you please send us the detail tender info?	Procurement of Prepaid Energy Meters and Metering Accessories - Last Mile Connectivity Project -II
2.	<p>It was mentioned in the advertisement that the tender documents would be made available on the website. I cannot seem to locate the documents and the technical specifications.</p> <p>If possible, could you kindly mail these to me. Please also confirm whether payment needs to be made, and if so, how much, together with banking details</p>	<p>Refer to response No. 1 above. To access the Tender document.</p> <p>Yes, bidders shall be expected to pay for the tender document as detailed in the Specific Tender Notice on KPLCs website.</p> <p>Banking details are also available on the website</p>
3.	<p>We are interested to know more about this project so that it helps us to give you a competitive Bid.</p> <ol style="list-style-type: none"> <li>a. Total scope of the project</li> <li>b. Bidder's qualifying requirements</li> <li>c. Process for registration of new Bidders</li> </ol>	<p>a) The tender is an International Competitive Bid which is open to Eligible bidders as described in the Bidding Document Section 1 on Eligibility of bidders, goods and Services and Section V on Eligible countries.</p> <p>b) Bidders qualifying requirements are Section III - Evaluation Criteria and as may be required in the Tender document.</p> <p>c) All eligible bidders are free to participate.</p>
4.	<p><b>KP1/6E.1/PT/1/17/A01- LOT G1-G5</b></p> <p>We hereby seek your clarification on the Fuse Link Cartridge 30A. HRC LV that you require. As Doc, No KP1/6C1713' TSP' 11/022, issue No 2; Rev No 1 Page 10 states "It shall match with 32A Amp. Rating and size is "29mm length x 12.7 mm diameter".</p> <p>However, we are of the opinion that Fuse Link Cartridge 30A. HRC LV shall be installed into the DMC cut-out and thus the size should be 57± 1 x22mm</p>	<p>The Fuse shall be used in standard DMC cut out. This shall comply with requirements of table 4.4.1 of KP1/6C.1/13/TSP/11/023 and table 2 of KP1/6C.1/13/tsp/11/022</p>

Item	<i>Query by Bidders</i>	KPLC Responses
	Please confirm the size of “Fuse Link Cartridge 30A. HRC LV” and if it shall be used on the DMC Cut outs that have been advertised in the same tender document.	
5.	We would like to request some clarifications about the minimum experience requirements for the participants in the bidding process as a consortium or as an individual bidder. If it is possible, we also would like to know where we can find the bidding documents to analyse all the information of the project.	Refer to response No. 1 above. To access the Tender document.  Information on minimum experience requirements is detailed under Section III Evaluation Criteria and as may be required in the Tender document.
6.	My enterprise is an authorised agent of a famous chinese smart meter manufacturer as well as it is focus on African market, is it available for us to participate the bidding?	Information on Eligibility of bidders is found in Eligible bidders as described in the Bidding Document Section 1 on Eligibility of bidders, goods and Services and Section V on Eligible countries.
7.	We downloaded a set of bidding documents from <a href="http://www.kplc.co.ke/">http://www.kplc.co.ke/</a> , are these as same as the set of documents purchased on spot completely? (purchase at Stima Sacco Investment Plaza, 3rd Floor, Kolobot Road, Parklands, Nairobi, Kenya)	If the documents refer to the same bidding number, they are the same.
8.	We notice that submission of a sample of meter is a must, should the sample be submitted with the tender documents before deadline?	The sample shall be submitted together with the bidding document before or the time and date specified in the bidding document
9.	What is the payment currency exactly?	Bidders making payments in Kenya can make their payments in Kenya Shillings. Bidders making payments from overseas can make payments in USD using the Banking details provided Kenya Powers website detailed in Response 1.
10.	<b>KP1/6E.1/PT/1/17/A01- LOT G1-G5</b>  Please refer to the above tender on the Bill of Quantities on the Cut Out and Fuse links the qty is 314, 200pcs while on the delivery schedule	The correct quantities for both the cut out and Fuse Links is <b>314,200</b> as indicated in the Bill of quantities and Price Schedule.

Item	<i>Query by Bidders</i>	KPLC Responses
	the quantity is different it shows 628,400 pcs kindly clarify which quantity we should use	
11.	<p><b>KP1/6E.1/PT/1/17/A01- LOT F</b></p> <p>Our understanding is that the SPN is a call for supply of pre-paid meter and it does not have the vending station / communication / installation scope – kindly confirm the same.</p>	The SPN for Prepaid Meters covers supply of the meters only.
12.	<p><b>Bidding Documents- Clause 1.7(2) (b)ii</b></p> <p>It is stated that the detail of supply contract shall include copies of contract award letters, and purchase Orders indicating quantity supplied under the contract and contract amount</p> <p><b>Question:</b> Some of our contracts are only for one type of meter, it is too easy to release our commercial unit price if we show the contract amount, and our clients also not prefer to let us release the price to third party. We request to block the price in our contract. Will this be accepted?</p>	Yes, you can show the value of the contract only
13.	<p><b>KP1/6E.1/PT/1/17/A01- LOT F</b></p> <p><b>Please clarify if samples shall be required</b></p>	<b>Yes,</b> Bidders shall be required to submit samples as per the Technical Specification of the bidding document
14.	<p><b>KP1/6E.1/PT/1/17/A01- LOT F</b></p> <p><b>Technical Specifications Clause 4.2.17</b></p> <p>The MCU body shall be ultrasonically sealed for life and there should be no screws on the MCU body except for the termination of cables.</p> <p><b>Question 1:</b> Please clarify if the terminal cover shall be sealable with screw</p> <p><b>Clause 4.2.2.2.20</b></p> <p>The UIU shall be able to communicate with MCU when power off via 2xAA battery.</p> <p><b>Question 2:</b> The number of AA batteries for off power communication does not influence the communication function of the UIU. Can the</p>	<p>Terminal cover screw shall be sealable with utility seals clause 4.2.1.13</p> <p>Type AAA or AA are acceptable so long as they are capable of powering the communication when power is off.</p>

Item	<i>Query by Bidders</i>	KPLC Responses
	quantity and type of batteries differs be accepted, for example, 4xAAA batteries be accepted	
15.	<p><b>KP1/6E.1/PT/1/17/A01- LOT G1-G5</b></p> <p>The bidding document does not require sample, but in the technical specifications, sample is required</p> <p><b>Question:</b> Are samples needed for lot G1-G5, If yes, how many samples are needed</p>	Samples are not required
16.	<p><b>KP1/6E.1/PT/1/17/A01- LOT G1-G5</b></p> <p>In the Technical specification of the meter box, it is required that the thickness of the one meter position meter box is not less than 3mm, but that of the four meter positions meter box is only 1.5 mm.</p> <p><b>Question 1:</b> What is the thickness requirement for the 4-meter position meter box?</p> <p><b>Technical Specification of 4 meter positions box</b></p> <p>We found that the specification for the 4-meter position meter box is released in 2010, and in the specification, it mentions that the voltage is 240V, which is apparently not Kenya voltage. And in our clarification in question 1 above the thickness is only 1.5 mm, which is not suitable for a 4 meter positions box.</p> <p><b>Question 2:</b> Will KPLC revise the Technical Specification of the 4 Meter Positions box</p>	<p>The requirement is that the thickness should NOT be LESS than 1.5mm. Any thickness above 1.5mm is acceptable</p> <p>The specifications will not be revised</p>
17.	<p><b>KP1/6E.1/PT/1/17/A01- LOT G1-G5</b></p> <p>We are aware that KPLC has latest specification on MCB that is released on march 2015 but in this tender the MCB specification is the old version</p> <p><b>Question:</b> Will KPLC revised the MCB specification to the latest one</p>	Refer to the revised Technical Specification attached as <b>Appendix I</b>

Item	<i>Query by Bidders</i>	<b>KPLC Responses</b>
18	<p>In this tender, there are many lots</p> <p><b>Question:</b> If the bidder intends to bid in more than one lot, for example LOT F and LOT G 1-G5, can the bidder open only one bid security that has the total amounts of all the lots?</p>	<p>Yes, Bidders can have one Bid security covering the Lots they are bidding for. They will be required to indicate the Lots the Bid Security covers.</p>
19.	<p><b>Request for Extension for Bid Submission Date</b></p> <p>We found that some of the technical specifications are very old and not the latest version of KPLC, and there are many items for clarifications. The time for sample and tender preparation is not enough.</p> <p>We request for one month extension of the bid submission</p>	<p>The tender closing date shall remain the same as indicated in the Bidding document.</p>
19.	<p><b>KP1/6E.1/PT/1/17/A01- LOT G1-G5</b></p> <p>As per tender, Ref: Specification of miniature circuit breakers (for use in domestic /residential buildings and similar premises) Doc no. KP1/3CB/TSP/11/010, Clause 2, reference standard, the standards mentioned is IEC898 (which is applicable for the material under scope of supply clause 1. Scope) to be used for Domestic/Residential meters protection.</p> <p><b>Question1:</b> Please mention the latest standard IEC 60898-1:2002. This MCB can be handled by unskilled worker safely</p> <p>There is also the reference to IEC 60947-2 which is for: Low Voltage Switchgear and Control gear – Part 2: Circuit breakers which are primarily meant for higher ratings beyond 63A essentially for Industrial application and not applicable to the scope of material.</p>	<p>Refer to the revised Technical Specification attached as <b>Appendix I</b></p>

Item	<i>Query by Bidders</i>	KPLC Responses
	<p><b>Kindly delete the same as it is superfluous and in contradiction. Moreover, this type circuit breaker can only be handled by skilled worker and poses a safety risk</b></p> <p><b>Question 2:</b> Should we refer to the clause 4.2 design and construction specifications this refers to IEC 898 standard mostly especially tripping curves</p> <p><b>Question 3:</b> Further referring to clause 4.2.22 the rated short circuit reference has been mentioned as per IEC 60947-2 which is in contradiction and lesser stringent test than scheme of testing for IEC 60898-1:2002 (Latest standard) for additional consumer safety.</p> <p><b>Question 4:</b> Test Reports Requirement However as per Clause 5.2 of same specification, the copy of type test reports to be submitted with tender shall include the tests in accordance with IEC 898 only and no mention of test reports complying to IEC 60947-2</p> <p>Specifications in Immediate past tenders awarded/quoted We would like to highlight in immediate past tenders reference to standard was IEC 60898-1</p> <ul style="list-style-type: none"> <li>• KP1/6E-2/PT/5/16/A51 Dated 21<sup>st</sup> October 2016 (Under same Kenya Electrification Funded Project)</li> <li>• KP1/9AA-3/PT/66/2105-17 Dated March 20415 (3 years supply contract)</li> </ul> <p><b><u>Note: there was no reference to IEC 60947-2 in specs of above tenders.</u></b></p> <p>Accordingly, the clauses as per IEC 60898-1 to be corrected</p> <p>4.2.23 The power frequency withstand voltage of the MCB to be 2Kv rms.</p> <p>4.2.24 The Impulse withstand voltage of the MCB to be 4kVp</p>	

Item	Query by Bidders	KPLC Responses
	<p>We would like to add that globally, the reference standard followed for miniature Circuit Breakers for domestic/ residential applications (meter protection) is IEC 60898-1:2002 (Latest standard of IEC 898). We would like KPLC to confirm on the above aspects on IEC standards and specifications.</p>	
20.	<p><b>The LV Cartridge 30A HRC specifications does not clarify what type of holder is required,</b></p> <p><b>Question 1:</b> Please clarify whether these fuses will be fitted in the cut-outs?</p> <p><b>Question 2:</b> Please clarify the fuse rating specifically, the 30A rating seems very low for a house service cut-out.</p>	<p>The Fuse shall be used in standard cut out. This shall comply with requirements of table 4.4.1 of KP1/6C.1/13/TSP/11/023 and table 2 of KP1/6C.1/13/tsp/11/022</p>
21.	<p><b>KP1/6E.1/PT/1/17/A01- LOT G1</b></p> <p>The degree of protection of the enclosure shall be at least IP65 when the top cover is secretly closed and sealed.</p> <p><b>Question 1:</b> May we provide a meter box with IP54 degree of protection as per meter pole top boxes we currently supply.</p> <p><b>Hinges:</b> The top cover shall be made of polycarbonate and easily opened by means of a hinge between it and the main meter board base</p> <p><b>Question 2:</b> May we provide a top slide cover?</p> <p><b>Size:</b> The meter board shall measure 300mm (Height) x 240mm (width) x 180mm (Height) tope cover inclusive.</p> <p><b>Question 3:</b> May we provide a smaller box measuring 150 x 240 x 100mm which will be able to accommodate the single phase prepayment split meter, the</p>	<p><b>Response to Q 1:</b> Comply to clause 3.1 of specifications</p> <p><b>Response to Q 2:</b> Provide as per specification clause 11.1.3</p> <p><b>Response to Q 3:</b> Provide as per specification clause 12.2 and fig 2</p>



Item	Query by Bidders	KPLC Responses
	<p>circuit breaker, 4 glands, 4way copper neutral block &amp; the Metal Oxide Varistor</p> <p><b>Sample:</b> A sample of the meter board being offered shall be submitted together with the tender documents. This sample shall not be returned to the tenderer.</p> <p><b>Question 4:</b> Please confirm if we should submit a sample. The BDS does not state if a sample of any of the LOTS should be submitted</p> <p><b>Mounting Bracket:</b> A galvanized/electro plated steel mounting bracket shall be provided behind the meter board to assist in</p> <p><b>Question 5:</b> May we provide a mounting bracket which is part of the box and also the same material as the box?</p>	<p><b>Response to Q 4:</b> Sample is not required</p> <p><b>Response to Q 5:</b> Provide as per specification clause 5.3.4</p>
22.	<p><b>KP1/6E.1/PT/1/17/A01- LOT G1- Specification for Mounted Meter Boards (4 Meters)</b></p> <p><b>Sample:</b> A sample of the meter board being offered shall be submitted together with the tender documents. This sample shall not be returned to the tenderer.</p> <p><b>Question 1:</b> Please confirm if we should submit a sample. The BDS does not state if a sample of any of the LOTS should be submitted.</p> <p>Mounting Bracket: galvanized/electro plated steel mounting bracket shall be provided behind the meter board to assist in securing the meter board on the pole.</p> <p><b>Question 2:</b> May we provide a mounting bracket which is part of the box and also the same material as the box?</p>	<p>Sample not required</p> <p>Provide as per specification clause 5.3.4</p>

Item	<i>Query by Bidders</i>	<b>KPLC Responses</b>
23.	<p><b>KP1/6E.1/PT/1/17/A01- LOT G2- Miniature Circuit Breaker</b></p> <p><b>IEC Standard:</b> Short circuit (KA) rating of 6KA mentioned on clause 4.22 is not relevant to the item on list of goods and related services. The item procured is 63A and the standard IEC60497-2 is for MCBs higher than 63A.</p> <p><b>Question 1:</b> Kindly confirm which IEC standard to follow with respect to items procured</p> <p><b>Test Reports:</b> as per clause 5.2 of same specification, the copy of type test reports to be submitted with tender shall include the tests in accordance with IEC 898 only and no mention of test reports complying to IEC 60947-2.</p> <p><b>Question 2:</b> Kindly confirm the test reports should be done as per which standard.</p> <p><b>Note:</b> We would like to add here that globally, the reference standard followed for Miniature Circuit Breakers for domestic/ residential applications (meter protection) is IEC60898-1:2002 (Latest standard of IEC 898) and thus standard IEC60947-2 NOT APPLICABLE to goods being procured (63A MCB).</p> <p><b>Sample:</b> Sample MCB being offered shall be submitted with the Bid at no cost to KPLC as per specification.</p> <p><b>Question 3:</b> Please confirm if we should submit a sample. The BDS does not state if a sample of any of the LOTS should be submitted.</p>	<p>Refer to the revised Technical Specification attached as <b>Appendix I</b></p>
24.	<p><b>KP1/6E.1/PT/1/17/A01 - LOT G4: Cut-out service 1P+N 60/80A (double) and Fuse-Link Cartridge 30A HRC LV</b> Specification: KP1/6C.1/13/TSP/11/023</p>	<p>Yes, Bidders are required to submit the samples as required in the Technical Specifications.</p>

Item	<i>Query by Bidders</i>	KPLC Responses
	<p><b>Sample:</b> Please confirm if we should submit a sample. The BDS does not state if a sample of any of the LOTS should be submitted.</p>	
25.	<p>As per Tender Clause ITB 11.1(h) , If Bidder is not a manufacturer, they shall demonstrate that they have successfully completed at least four (4) contracts of similar goods in the past five (5) years</p> <p><b>Question:</b> Please clarify whether our organisation which is an International Trading Company of the Government of India wishing to participate as JVCA where the JV members / partners shall meet the eligibility criteria but not our organisation can take part in this arrangement.</p>	<p>Refer to the Eligibility criteria outlined in the bidding documents Bidding Document Section 1 on Eligibility of bidders, goods and Services and Section V on Eligible countries.</p>
26.	<p><b>KP1/6E.1/PT/1/17/A01- LOT G2- Miniature Circuit Breaker</b></p> <p>As per Tender Specification of Miniature Circuit Breakers (for use in domestic/residential buildings and similar premises) Doc no. KP1/3CB/TSP/11/010, clause 2, reference standard, the standards mentioned is IEC 898 (which is applicable for the material under scope of supply clause 1. Scope) to be used for Domestic/Residential meters protection.</p> <p><b>Question 1:</b> Please mention the latest standard IEC 60898-1:2002. The MCB can be handled by unskilled worker safely.</p>	<p>Refer to the revised Technical Specification attached as <b>Appendix I</b></p>
27.	<p><b>Question 2:</b> There is also reference to IEC 60947-2 which is for Low Voltage Switchgear and Control gear- part 2: Circuit breakers which are primarily meant for higher ratings beyond 63A essentially for industrial application and not applicable to the scope of material.</p>	<p>Refer to the revised Technical Specification attached as <b>Appendix I</b></p>

Item	Query by Bidders	KPLC Responses
	<p><b>Note:</b> Kindly delete the same as it is superfluous and in contradiction. Moreover, this type of circuit breaker can be handled by skilled worker and poses a safety risk</p> <p><b>Question 3:</b> Should we refer to the clause 4.2 design and construction specifications this refers to IEC 898 standard mostly especially tripping curves.</p> <p><b>Question 4:</b> Further referring to clause 4.2.22 the rated short circuit reference has been mentioned as per IEC 60947-2 which is in contradiction and lesser stringent test than scheme of testing for IEC 60898-1:2002 (Latest standard) for additional consumer safety.</p> <p><b><u>Test Reports Requirements</u></b></p> <p><b>Question 5:</b> As per clause 5.2 of same specifications, the copy of type test reports to be submitted with tender shall include the tests in accordance with IEC 898 only and no mention of test reports complying to IEC 60947-2.</p>	
28	<p><b>KP1/6E.1/PT/1/17/A01- LOT G1- Specification for Mounted Meter Boards (4 Meters)</b></p> <p><b>Question 1:</b> If samples are required, we will need to make mound for same and it will cost at least Rs. 20 Lacs (for two projects)</p> <p><b>Question 2:</b> We are also confused about exact material requirement of Pole Mounted Meter boards as in Clauses for material 11.2.1 and 11.2.2</p> <p><b>Question 3:</b> Thickness given for top and bottom of Pole Mounted Teeterboards is very less, i.e. 1.5 mm, it's not possible to manufacture such size box in 1.5 mm. Please clarify.</p>	<p><b>Response to Question 1:</b> Samples are not required</p> <p><b>Response to Question 2:</b> Refer to clause 7.1</p> <p><b>Response to Question 3:</b> The requirement is that the thickness should NOT be LESS than 1.5mm. Thickness above 1.5mm is acceptable</p>
29.	<p>As mentioned in 4.2.2.1.7, the MCU shall be equipped with 100A relay both in Live and Neutral circuits, while in 6, it said the</p>	<p><b>Question 4:</b> The latching contactor should be <b>Double pole</b>.</p>


Item	<i>Query by Bidders</i>	KPLC Responses
	<p>disconnection device type shall be single pole latching contactor. So, the question is: the single pole latching contactor shall be used both in Live and Neutral circuits or just in Live circuit? If both the Live and Neutral circuits need relay, can we use one double-pole relay to replace two single pole relays?</p>	
30.	<p><b>UNIVERSAL CLAMP /DUTY</b></p> <p>We have some doubt in the Tenders technical specifications for Universal Clamp, Kindly confirm which drawing to follow as there are three design mentioned in the specification (page no. 12,13 and 14 of the specification for multipurpose overhead line clamps.</p> <p><b>Question 1:</b> Please clarify the dimensions A and B are the measurement from the inner diameter or the outer diameter. If from the outer diameter as indicated from the specification, the clamp cannot fit at specified position on the pole.</p> <p><b>Question 2:</b> Please specify the correct dimension of the clamp.</p> <p><b>M20 x 89 Bolt</b> with one nut, one lock nut, flat washer and spring washer (Both Side) cannot fit in the holes provided for the meter boxes and D -Iron for LV Installation.</p> <p><b>Question 3:</b> Please clarify the correct one lock nut, flat washer and spring washer (Both Side)? Or can they be changed to M16 x 80 with one lock nut, flat washer and spring washer (Both Side)?</p>	<p><b>Response to Question 1:</b> Refer to Technical Specification -Fig 1: TSP/02/004/01- Horizontal Section Clamp.</p> <p><b>Response to Question 2:</b> Inner diameter</p> <p><b>Response to Question 3:</b> Provide as per specification clauses 4.4.4 and 4.4.5</p> <p>All bolts shall be M16. If M20 they should be interchangeable with M16.</p>
31.	<p>As per tender clause 2.4.1 Experience, it has been given that “For Experience as supplier for KP1/6E.1/PT/1/17/01- Lot G2 at least USD. 2,400,000 in at least (3) contracts within the last (5) years, each with a value of US \$ 2,400,000</p>	<p><b>Response:</b> Experience shall be as indicated in the tender clause 2.4.1.</p> <p>A bidder shall be expected to meet the minimum criteria. Each of the</p>

Item	<i>Query by Bidders</i>	<b>KPLC Responses</b>
	<p>have been successfully and substantially completed and that are similar to the proposed Goods and Related Services. The similarity shall be based on the physical size, complexity, methods/technology or other characteristics as described in section IV, Bidding Forms.</p> <p><b>Question:</b> We need to ascertain whether any supplier who doesn't have past supply of any single order worth US \$ 2,400,000 for the same product. However, the aggregated value of the orders amounting to US \$ 2,400,000 towards supply of various switchgears (RCCBs MCB and Cut outs etc)</p>	<p>contract will be of the value indicated.</p>
32.	<p>Kindly extend the closing date of the tender by another 15 days.</p>	<p>The Tender closing date shall remain the same as indicated in the bidding document</p>

All other terms and conditions remains as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



**ENG. JOSEPH K. GATHURU,**  
**ELECTRIFICATION PROJECT MANAGER.**