

*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3201889
Stima Plaza, Kolobot Road*

Our Ref:
M/s

25th February, 2020

Dear Sir,

ADDENDUM NO. 1 TO THE TENDER NO.KP1/9A.2/OT/037/ID/19-20 PROVISION OF CIVIL WORKS AND STEEL STRUCTURES AT NEW BAMBURI 132/33KV SUBSTATION

The following amendments are made to the specified provisions of the Tender document.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. CLARIFICATION MADE TO THE INTERESTED BIDDERS.

The following responses are made to clarifications sought on various issues on the tender document and shall be deemed to form the addendum:-

a) BILL NO 2: SWITCH YARD EXCAVATIONS AND LEVELLING

Item No. 13.0—Supply and spread uniformly 150mm thick size 50-60mm [Railway ballast size] ballast in switchyard singly graded.

SECTION 1. INVITATION TO TENDER

The tender closing date has been extended from **4th March, 2020** to **6th March, 2020** at **10:00am** and opening on the same day at **10.30am**.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



JANE MUIGAI
AG. SUPPLY CHAIN MANAGER (PROCUREMENT)