

DOCUMENT NO: KP1/6C/4/1/TSP/11/007-2



Kenya Power

AUTOMATIC LOAD TRANSFER SWITCH

Part 2: 11KV INDOOR AUTOMATIC LOAD TRANSFER SWITCH —
SPECIFICATION

A Document of the Kenya Power & Lighting Co. Ltd
October 2019



TITLE:
**AUTOMATIC LOAD TRANSFER
 SWITCH**
Part 2: 11KV INDOOR AUTOMATIC
**LOAD TRANSFER SWITCH —
 SPECIFICATION**

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 2 of 18 | |

TABLE OF CONTENTS

| | |
|---|----|
| 0.1 Circulation List | 3 |
| 0.2 Amendment Record | 4 |
| FOREWORD..... | 5 |
| 1. SCOPE..... | 6 |
| 2. REFERENCES (NORMATIVE) | 6 |
| 3. DEFINITIONS AND ABBREVIATION..... | 6 |
| 4. REQUIREMENTS..... | 7 |
| 4.1. Service conditions..... | 7 |
| 4.2. Materials and Construction | 7 |
| 4.2.1. Switch | 7 |
| 4.2.2. Voltage Transformers | 8 |
| 4.2.3. Control Unit | 9 |
| 4.2.4. Electrical Characteristics | 10 |
| 5. TEST REQUIREMENTS..... | 11 |
| 6. MARKING AND PACKING..... | 11 |
| 6.1. Packing | 11 |
| 6.2. Marking: | 11 |
| APPENDICES..... | 12 |
| APPENDIX A: TESTS AND INSPECTION (NORMATIVE) | 12 |
| APPENDIX B: QUALITY MANAGEMENT SYSTEM (NORMATIVE)..... | 12 |
| APPENDIX C: TECHNICAL DOCUMENTATION (NORMATIVE) | 13 |
| APPENDIX D: GUARANTEED TECHNICAL PARTICULARS (GTPs) — NORMATIVE | 15 |

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



TITLE:
**AUTOMATIC LOAD TRANSFER
SWITCH**
*Part 2: 11KV INDOOR AUTOMATIC
LOAD TRANSFER SWITCH ---
SPECIFICATION*

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 3 of 18 | |

0.1 Circulation List

| COPY NO. | COPY HOLDER |
|--|--------------------|
| 1 | Manager, Standards |
| Electronic copy (pdf) on Kenya Power server (http://172.16.1.40/dms/browse.php?fFolderId=23) | |

REVISION OF KPLC STANDARDS

To keep abreast of progress in the industry, KPLC standards shall be regularly reviewed. Suggestions for improvements to approved standards, addressed to the Manager, Standards department, are welcome.

© Kenya Power & Lighting Co. Ltd.

Users are reminded that by Section 25 of the Copyright Act, 2001 (Revised 2009) Cap 130 of the Laws of Kenya copyright subsists in all KPLC standards and except as provided under Section 26 of this Act, no KPLC standard produced by KPLC may be reproduced, stored in retrieval system by any means without prior permission from the Managing Director & CEO, KPLC.

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



TITLE:
**AUTOMATIC LOAD TRANSFER
 SWITCH**
*Part 2: 11KV INDOOR AUTOMATIC
 LOAD TRANSFER SWITCH ---
 SPECIFICATION*

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 4 of 18 | |

0.2 Amendment Record

| Rev No. | Date (YYYY-MM-DD) | Description of Change | Prepared by (Name & Signature) | Approved by (Name & Signature) |
|------------------|----------------------|---|-----------------------------------|-----------------------------------|
| Issue 1 Rev 2 | 2010-04-12 | Clause 4.3.1: Changed no. of mechanical operations & making/breaking currents | S.K. Nguli | G.K. Gathige |
| Issue 2 Rev 0 | 2017-07-19 | i. Editing ii. Changed the title to <i>Automatic Load Transfer Switch - Part 2: 11kv Indoor Automatic Load Transfer Switch --- Specification</i> iii. Restated Clause 4.2.1.2 4.3.1 | Rotich Benard | Dr. Eng. P. Kimemia |
| Issue 2 Rev 1 | 2019-10-17 | i. Added clause 4.2.11,4.2.1.2,4.2.1.3 4.2.1.4, 4.2.3.2 (c &d) and 4.2.3.10 ii. Revised Table 1, clause 4.2.1.9, 4.2.1.10,4.2.3.3, 4.2.3.5, 4.2.3.6 and 4.2.3.12 | Nancy Wairimu | Dr. Eng. P. Kimemia |

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



TITLE:
**AUTOMATIC LOAD TRANSFER
SWITCH**
*Part 2: 11KV INDOOR AUTOMATIC
LOAD TRANSFER SWITCH —
SPECIFICATION*

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 5 of 18 | |

FOREWORD

This Specification has been prepared by the Standards Department in collaboration with technical Services Department, both of Kenya Power and Lighting Company Limited (Kenya Power) and it lays down requirements for 11kV indoor pad-mounted automatic load transfer switch herein called 'switch'.

The automatic load transfer switches shall be air-insulated and interruption shall be in vacuum.

The equipment shall be complete with all components to realize the intended application. The indoor- pad mounted automatic load transfer switch, while assembled, shall comprise of 2 switches, control unit(s) plus associated control cables and accessories.

This specification is in this series:

KP1/6C/4/1/TSP//11/007-1: Automatic Load Transfer Switch - Part 1: 11kV and 33kV Pole-Mounted Automatic Load Transfer Switch — Specification

KP1/6C/4/1/TSP//11/007-2: Automatic Load Transfer Switch - Part 2: 11kV Indoor Automatic Load Transfer switch — Specification

KP1/6C/4/1/TSP//11/007-3: Automatic Load Transfer Switch - Part 3: 11kV and 33kV Pole-Mounted Vacuum Switch in SF₆ — Specification

KP1/6C/4/1/TSP//11/007-4: Automatic Load Transfer Switch - Part 4: 11kV Indoor Pad-mounted Automatic Load Transfer switch in SF₆ — Specification

It shall be the responsibility of the manufacturer to ensure adequacy of the design and good engineering practice in the manufacture of the indoor pad mounted automatic load transfer switch for KPLC. The manufacturer shall also submit information which confirms satisfactory service experience with products which fall within the scope of this specification.

The following are members of the team that developed this specification:

| Name | Department |
|-----------------------|--------------------|
| Adrian Sagwe | Technical Services |
| Rotich Benard | Standards |
| Zacheus Omondi Oluoch | Technical Services |
| Nancy Wairimu Mungai | Standards |

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



| | | |
|---|----------------------|--------------------------------|
| TITLE: AUTOMATIC LOAD TRANSFER SWITCH Part 2: 11KV INDOOR AUTOMATIC LOAD TRANSFER SWITCH — SPECIFICATION | Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| | Issue No. | 2 |
| | Revision No. | 1 |
| | Date of Issue | 2019-10-17 |
| | Page 6 of 18 | |

1. SCOPE

This specification is for 11kV Indoor Automatic Load Transfer Switch together with controls and auxiliary equipment for use on underground distribution network to provide seamless load transfer from one source to an alternative standby source without voltage or frequency transients whenever there is an interruption on the current source of power supply. The specification also covers inspection and test of the equipment.



2. REFERENCES (NORMATIVE)

The following standards contain provisions which through reference in this text constitute provisions of this specification. For dated editions, the cited edition shall apply; for undated editions, the latest edition of the referenced document shall apply.

- IEC 62271-100: High-voltage switchgear and controlgear - Part 100: High-voltage alternating-current circuit-breakers.
- IEC 62271-200: High-voltage switchgear and controlgear - Part 200: A.C. metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV.
- IEC 60051 Direct acting indicating analogue electrical measuring instruments and their accessories.
- IEC 60044-1: Instrument transformers - Part 1: Current transformers.
- IEC 60044-2: Instrument transformers - Part 2: Inductive voltage transformers.
- IEC 60255: Electrical Relays.
- IEC 60529: Degrees of protection provided by enclosures (IP Code).

3. DEFINITIONS AND ABBREVIATION

For this specification, the definitions and abbreviations given in the reference standards shall apply.

| | |
|---|---|
| Issued by: Head of Section, Standards Development | Authorized by: Head of Department, Standards |
| Signed:  | Signed:  |
| Date: 2019-10-17 | Date: 2019-10-17 |



TITLE:
**AUTOMATIC LOAD TRANSFER
SWITCH**
**Part 2: 11KV INDOOR AUTOMATIC
LOAD TRANSFER SWITCH ---
SPECIFICATION**

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 7 of 18 | |

4. REQUIREMENTS

4.1. Service conditions

The 11kV Indoor Automatic Load Transfer Switch shall be suitable for use indoors in tropical areas and harsh climatic conditions including areas exposed to:

- a) Altitudes of up to 2200m above sea level
- b) Humidity of up to 95%
- c) Average ambient temperature of +30°C with a minimum of -1°C and a maximum of +40°C, in direct sunlight,
- d) Pollution: Design pollution level to be taken as “Heavy” (Pollution level III) for inland and “Very Heavy” (Pollution level IV) for coastal applications in accordance with IEC 60815.
- e) *Isokeraunic* levels of up to 180 thunderstorm days per year.

4.2. Materials and Construction

4.2.1. Switch

- 4.2.1.1. The switch shall consist of three panels, two for incoming cables and one for outgoing cable.
- 4.2.1.2. The two incoming panels shall have three compartments each, the cable, circuit breaker and auxiliary compartments. The outgoing panel shall have two compartments, the bottom cable compartment and the upper compartment shall be reserved for the DC battery charger and the battery bank.
- 4.2.1.3. There shall be provision for capacitive voltage indicators in the incoming panels cable compartments to indicate voltage presence when the cables are powered.
- 4.2.1.4. The auxiliary compartment of the incoming panels shall have a 230v ac door switch operated lighting point and universal socket type.
- 4.2.1.5. The switch shall be suitable for indoor ground-mounting, designed for three phase operation by means of a local and remote control for load transfer from two sources.
- 4.2.1.6. The switching shall take place in vacuum while the insulation medium shall be air. The switch shall be equipped with an operation counter visible from the outside.
- 4.2.1.7. The switch shall have a mechanical status indicator for both the Open and the Closed position.

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



TITLE:
**AUTOMATIC LOAD TRANSFER
SWITCH**
**Part 2: 11KV INDOOR AUTOMATIC
LOAD TRANSFER SWITCH —
SPECIFICATION**

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 8 of 18 | |

- 4.2.1.8. The Switch shall be equipped with inbuilt two core current transformers, the rated burden shall not be less than 15VA. Core 1 shall be class 5P10 with a ratio of 400/1A for overcurrent and earth fault protection, which will be connected to the control unit so that faults on the load side can be detected and load transfer blocked.
- 4.2.1.9. Core 2 of the current transformer shall class 0.5 with a ratio of 400/1A for metering on the load side.
- 4.2.1.10. All current carrying parts shall be made of electrolytic high conductivity material with the contacts silver -plated.
- 4.2.1.11. Manually operated levers to enable manual trip and close of source-side interrupter switches during power outages to be provided.
- 4.2.1.12. The switch to be provided with suitable terminals for connecting cables of up to 300mm² (both aluminium and copper).
- 4.2.1.13. The switch shall be provided with suitable durable surge diverters at point of cable termination. Healthy status of surge diverter shall be monitored via suitable indicator meter. The diverters shall be fitted in such a way that can guarantee easy removal and replacement.
- 4.2.1.14. The cable compartment shall have an anti-vermin guard plate giving protection against rats, rodents, snakes etc.
- 4.2.1.15. The cable compartments shall have a 230V ac heater switched through the humidity meter.

4.2.2. Voltage Transformers

- 4.2.2.1. A set of three single-phase voltage transformers shall be supplied for monitoring the status of the two sources. The marshalling boxes for the voltage transformers and connection cables to the marshalling box and to the control box shall be provided.
- 4.2.2.2. The secondary voltage of the voltage transformers shall be between 230V ac. This voltage shall be used for powering the control box and also for electrical operations of the switches.
- 4.2.2.3. The voltage transformers in the incoming panels shall be adequately protected from short circuits by high voltage fuses on the primary side and MCBs on the secondary side.

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



TITLE:
**AUTOMATIC LOAD TRANSFER
SWITCH**
**Part 2: 11KV INDOOR AUTOMATIC
LOAD TRANSFER SWITCH —
SPECIFICATION**

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 9 of 18 | |

4.2.3. Control Unit

- 4.2.3.1. The control unit shall be complete with auxiliary equipment suitable for automatic load transfer from one source to alternate standby source whenever there is loss of power on the preferred source.
- 4.2.3.2. The control unit shall be a fully programmable microprocessor/numerical-based unit with the following features on its front face:
- a) LCD Screen to facilitate manual programming of the control unit and viewing of data such as events, faulty records and measurands.
 - b) **Key Pad:** This shall be used for programming and viewing the control settings, measurands and control logic for the unit.
 - c) LED indications for CB open, CB closed CB in service, CB in test, Earth switch open and earth switch close positions.
 - d) The control unit shall have a suitable means of showing the status of the two sources, i.e. whether they are live or not.
 - e) If the control has locked out i.e., failed to transfer load because it has detected a fault on the load side, then this should be indicated on the control by a suitable means.
 - f) The time delay for load transfer from preferred source to alternate source and vice versa and from one to another where none of the sources is preferred shall be programmable from 0 seconds to at least 60 seconds.
- 4.2.3.3. The auto changeover shall be able to “remember” to switch to its previous preferred source of supply in an event where both sources of power supplies are restored after failure. Under voltage trip block in case of loss of both sources of supply is also acceptable. There shall also be a facility to enable /disable this function.
- 4.2.3.4. Phase sequence indication by means of press button shall be provided and an audible alarm provided in case of wrong rotation. The correct phase sequence shall be R, Y, B.
- 4.2.3.5. The charger output shall be 30V DC and the battery shall be rated such that it shall supply the rated load for 8 hours without recharge.

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2019-10-17

Date: 2019-10-17



| | | |
|---|----------------------|--------------------------------|
| TITLE: AUTOMATIC LOAD TRANSFER SWITCH Part 2: 11KV INDOOR AUTOMATIC LOAD TRANSFER SWITCH --- SPECIFICATION | Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| | Issue No. | 2 |
| | Revision No. | 1 |
| | Date of Issue | 2019-10-17 |
| | Page 10 of 18 | |

- 4.2.3.6. The unit shall be supplied complete with 7 copies of programming software in a CD ROM and 10 no relay communication cables shall also be provided to facilitate easy programming of auto changeover numerical relays.
- 4.2.3.7. It shall be possible to load the software into at least 10 different laptop computers without requirement for additional licenses. Seven (7) sets of hardcover manuals for the software supplied providing detailed instructions for programming and settings shall be provided.
- 4.2.3.8. The control units shall be supplied complete with integral termination kits, control and interconnecting cables.
- 4.2.3.9. The control Unit shall be equipped for supervisory control via SCADA
- 4.2.3.10. The closing of the two incoming circuit breakers shall be interlocked such that either of the breakers shall only be closed with the other open. Closing operation shall be inhibited if the other incoming CB is closed.
- 4.2.3.11. Automatic change-over from one source to the other shall occur when: -
 - a) One or all the phases for the source in service is detected to be dead or de-energized and all the phases of the standby source are healthy.
 - b) Under voltage or overvoltage is detected on one or more phases of the source in service and all the phases of the standby source are healthy.
- 4.2.3.12. The settings of the overvoltage and under voltage sensing relay shall be programmable 20% above nominal voltage for overvoltage and 30% below nominal voltage for under voltage.

4.2.4. Electrical Characteristics

4.2.4.1. The electrical characteristics of the load transfer switch shall be as shown in Table 1 below:

Table 1: Electrical Characteristics of the Load Transfer Switch

| CHARACTERISTICS | 11KV SWITCH |
|---|--------------------|
| Rated system highest voltage and frequency | 17.5kV, 50Hz |
| Rated Current | 630A |
| Rated power frequency withstand voltage, rms | 38kV |
| Rated lightning impulse withstand voltage, peak | 95kV |
| Minimum breaking /making capacity peak | 16/31.5 kA |

| | |
|--|---|
| Issued by: Head of Section, Standards Development | Authorized by: Head of Department, Standards |
| Signed: | Signed: |
| Date: 2019-10-17 | Date: 2019-10-17 |



TITLE:
AUTOMATIC LOAD TRANSFER SWITCH
Part 2: 11KV INDOOR AUTOMATIC LOAD TRANSFER SWITCH ---
SPECIFICATION

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 11 of 18 | |

| CHARACTERISTICS | 11KV SWITCH |
|--|--|
| Minimum number of Mechanical & Full load operations | 10,000 |
| Minimum number of operations under fault conditions | 100 |
| Rated short-time withstand current | 16kA, 3sec |
| Internal Arc Classification (IAC) in accordance to IEC 62271-200 | 25kA, 1s |
| Standard degree of protection | IP4X |
| Surge diverter rating | I _n : 10kA, U _r : 9kV U _c : 7kv |
| Voltage transformer rating | VA: 50VA |

- 4.2.4.2. The insulation level for the voltage transformers shall be 38kV and 95kV for Power frequency and Lightning Impulse withstand voltage respectively.
- 4.2.4.3. Spares required to run equipment for 15 years after installation shall be listed and offered as an option.

5. TEST REQUIREMENTS

The switches shall be tested in accordance with the requirements of IEC 60255, IEC 60529, IEC 60265, IEC 60270, IEC 694, IEC 61000, IEC 60068, ANSI C37. 60, IEC 60298, ISO 1461 and the requirements of this specification.

6. MARKING AND PACKING

6.1. Packing

The switches and associated components shall be packed in a manner as to protect it from any damage in transportation and repeated handling.

6.2. Marking:

- 6.2.1. Each assembly and package of items associated with the switches shall be suitably marked. A packing and parts list shall be provided
- 6.2.2. The following information shall be marked indelibly and eligibly and in a permanent manner on each item/ name plate:
- Manufacturer's name or Trademark;
 - Manufacturer's Type Designation;
 - Specified electrical characteristics;
 - The wording "**Property of KPLC**"

6.2.3. All marking shall be permanent either by embossing or engraving.

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



| | | |
|---|----------------------|--------------------------------|
| TITLE: AUTOMATIC LOAD TRANSFER SWITCH Part 2: 11KV INDOOR AUTOMATIC LOAD TRANSFER SWITCH — SPECIFICATION | Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| | Issue No. | 2 |
| | Revision No. | 1 |
| | Date of Issue | 2019-10-17 |
| | Page 12 of 18 | |

APPENDICES

APPENDIX A: TESTS AND INSPECTION (NORMATIVE)

- A.1. Type tests, sampling tests and routine tests shall be done in accordance with the requirements of IEC 60255, IEC 60529, IEC 60265, IEC 60270, IEC 694, IEC 61000, IEC 60068, ANSI C37. 60, IEC 60298, ISO 1461 and the requirements of this specification. It shall be the responsibility of the manufacturer to perform or have performed all the tests specified.
- A.2. Copies of previous type test reports by the relevant independent /international or National Testing /Standards Authority of the country of manufacture (or ISO/IEC 17025/ILAC accredited laboratory) shall be submitted with the tender for evaluation (all in English Language). A copy of accreditation certificate for the laboratory shall also be submitted.
- A.3. The indoor automatic Load Transfer Switches shall be subject to acceptance tests at the Manufacturer's works before dispatch. Acceptance tests shall be witnessed by two Engineers appointed by The Kenya Power and Lighting Company Limited(KPLC). Routine and Sample Test Reports for the Load Transfer Switches to be supplied shall be Submitted to KPLC for approval before delivery of goods.
- A.4. On receipt of the equipment, KPLC will inspect them for acceptance at stores and may perform or have tests performed to verify compliance of the equipment with this specification. The supplier shall replace without charge to KPLC, any equipment which upon examination, test or use fail to meet any or all of the requirements in this specification

APPENDIX B: QUALITY MANAGEMENT SYSTEM (NORMATIVE)

- B.1. The supplier shall submit a quality assurance plan (QAP) that will be used to ensure that the switches' material, workmanship, tests, service capability, etc. will fulfil the requirements stated in the contract documents, standards, specifications and regulations. The QAP shall be based on and include relevant parts to fulfil the requirements of ISO 9001:2008/2015

| | |
|--|---|
| Issued by: Head of Section, Standards Development | Authorized by: Head of Department, Standards |
| Signed: | Signed: |
| Date: 2019-10-17 | Date: 2019-10-17 |



TITLE:
AUTOMATIC LOAD TRANSFER SWITCH
Part 2: 11KV INDOOR AUTOMATIC LOAD TRANSFER SWITCH — SPECIFICATION

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 13 of 18 | |

- B.2. The Manufacturer’s Declaration of Conformity to reference standards and copies of quality management certifications including copy of valid and relevant ISO 9001: 2008 or 2015 certificate shall be submitted with the tender for evaluation.
- B.3. The bidder shall indicate the delivery time of the switches, manufacturer’s monthly and annual production capacity and experience in the production of the items. A detailed list and contact addresses (including e-mail) of the manufacturer’s previous customers outside the country of manufacture for switches sold in the last five years together with reference letters from four of the customers shall be submitted with the tender for evaluation.

APPENDIX C: TECHNICAL DOCUMENTATION (NORMATIVE)

C.1. The bidder shall submit its tender complete with technical documents for tender evaluation. The technical documents to be submitted (all in English language) for tender evaluation shall include the following:

- a) Fully-filled clause by clause Guaranteed Technical Particulars (GTPs)- Appendix D - stamped and signed by the manufacturer.
- b) Detailed drawings and technical data of the automatic load transfer switch (all in English Language)
- c) Detailed manuals and drawings of the installation and control unit circuits and components shall accompany the tender (all in English Language)
- d) Wiring diagram for complete set of auto-changeover switch
- e) Details of manufacturing capacity and the manufacturer’s experience;
- f) Copies of required test certificates and test reports by a third-party testing laboratory accredited to ISO/IEC 17025;
- g) Sales records for previous five years and reference letters from at least four of the customers;

C.2. The successful bidder (supplier) shall submit two sets of the following documents/details to The Kenya Power & Lighting Company for approval before manufacture:

- a) Fully filled clause by clause Guaranteed Technical Particulars (GTPs) stamped and signed by the manufacturer (**these are not the ones submitted with the tender**);


| | |
|---|--|
| Issued by: Head of Section, Standards Development | Authorized by: Head of Department, Standards |
| Signed: | Signed: |
| Date: 2019-10-17 | Date: 2019-10-17 |




| | | |
|---|----------------------|--------------------------------|
| TITLE: AUTOMATIC LOAD TRANSFER SWITCH Part 2: 11KV INDOOR AUTOMATIC LOAD TRANSFER SWITCH — SPECIFICATION | Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| | Issue No. | 2 |
| | Revision No. | 1 |
| | Date of Issue | 2019-10-17 |
| | Page 14 of 18 | |

- b) Detailed drawings and technical data of the automatic load transfer switch (all in English Language)
 - c) Detailed manuals and drawings of the installation and control unit circuits and components shall accompany the tender (all in English Language)
 - d) Wiring diagram for complete set of auto-changeover switch
 - e) Marking and packaging details.
- C.3. Three copies of as built drawing on A3 or A4 paper to be supplied prior to shipment of the switches.
- C.4. A set of Three (3) Installation, Testing Configuration Programming, commissioning, operation and maintenance manuals shall be provided with the switches shall be submitted during delivery.

Issued by: Head of Section, Standards Development

Signed: 
Date: 2019-10-17

Authorized by: Head of Department, Standards

Signed: 
Date: 2019-10-17



TITLE:
**AUTOMATIC LOAD TRANSFER
 SWITCH**
**Part 2: 11KV INDOOR AUTOMATIC
 LOAD TRANSFER SWITCH —
 SPECIFICATION**

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 15 of 18 | |

APPENDIX D: GUARANTEED TECHNICAL PARTICULARS (GTPs) — NORMATIVE

(to be filled, stamped and signed by the Supplier and submitted together with relevant copies of the Manufacturer's catalogues, brochures, drawings, technical data, sales records for previous five years, four customer reference letters, details of suppliers' capacity and experience; and copies of complete test certificates and test reports for tender evaluation or approval, all in English Language, as per clauses C.1 and C.2)

Tender No.

Bidder's name and Address.....

| Description | | Bidder's offer |
|---|--|----------------|
| 1. Manufacturer's Name & Country of manufacture | | State |
| 2. Type/Model Number of Components | | State |
| 3. List of components to be supplied (for one installation) | | Specify |
| Clause | Description | Bidders offer* |
| 1.1 | Scope | State |
| 2 | Applicable Standards | List |
| 4. | Requirements | |
| 4.1 | Service conditions | Specify |
| 4.2 | Material and Construction | |
| 4.2.1 | Switch | |
| 4.2.1.1 | Number of panels | Specify |
| 4.2.1.2 | Number and function of the incoming panels compartments | Specify |
| | Number and function of the outgoing panels compartments | Specify |
| 4.2.1.3 | Capacitive voltage indicators in the incoming panels cable compartments provided | State |
| 4.2.1.4 | 240v ac door switch operated lighting point and universal socket type in the auxiliary compartment provided. | State |
| 4.2.1.5 | Switch designed for three phase operation by means of a local and remote control | State |
| 4.2.1.6 | Switching takes place in vacuum while the insulation medium shall be air | State |
| 4.2.1.7 | switch has mechanical status indicator for both the Open and Closed position. | Specify |
| 4.2.1.8 | Core 1 class and ratio of the current transformers for protection | State |
| 4.2.1.9 | Core 2 class and ratio of the current transformers for metering | State |

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



TITLE:
AUTOMATIC LOAD TRANSFER SWITCH
Part 2: 11KV INDOOR AUTOMATIC LOAD TRANSFER SWITCH --- SPECIFICATION

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 16 of 18 | |

| | | | |
|---------------|--|---|---------|
| 4.2.1.10 | All current carrying made of electrolytic high conductivity material with contacts silver -plated. | State | |
| 4.2.1.12 | Manually operated levers to enable manual trip and close are provided | State | |
| 4.2.1.13 | suitable terminals for connecting cables of up to 300mm ² (both aluminium and copper) are provided | Specify | |
| 4.2.1.14 | durable surge diverters at point of cable termination are provided | Specify | |
| 4.2.1.15 | cable compartment has an anti-vermin guard plate | Specify | |
| 4.2.2. | Voltage transformers | | |
| 4.2.2.1 | The switches are supplied with a set of three-phase voltage transformers for monitoring the status of the two sources | state | |
| 4.2.2.2 | secondary voltage range of the voltage transformers | State | |
| 4.2.2.3 | Protection of voltage transformers on the primary side | State | |
| | Protection of voltage transformers on the secondary side | State | |
| 4.2.3. | Control Unit | | |
| 4.2.3.1 | Control unit complete with auxiliary equipment suitable for automatic load transfer | Specify | |
| 4.2.3.2 | Control unit has a fully programmable microprocessor/numerical-based unit | Specify | |
| | Control unit front face features | State | |
| 4.2.3.3 | Auto changeover able to "remember" to switch to the preferred source of supply when both sources of power supplies are restored after failure. | Specify | |
| 4.2.3.4 | Phase sequence (R, Y, B) indication by means of press button provided | State | |
| 4.2.3.5 | Duration of the DC supply to sustain auto changeover operation after loss of AC without recharge | State | |
| 4.2.3.6 | No. of copies of control unit's programming software in a CD ROM and relay communication cables | State | |
| 4.2.3.7 | No. of computers which the software can be loaded the into without requirement for additional licenses | State | |
| 4.2.3.8 | Accessories to be supplied the control units | State | |
| 4.2.3.9 | Control unit equipped for supervisory control via SCADA | Specify | |
| 4.2.3.10 | Interlocking of the two incoming circuit breakers | Specify | |
| 4.2.3.11 | Scenarios when automatic changeover occur | State | |
| 4.2.3.12 | Settings of the overvoltage and under voltage sensing relay | State | |
| 4.2.4 | Electrical characteristics | | |
| 4.2.4.1 | Electrical characteristics of the load transfer switch | Rated system highest voltage and frequency | Specify |
| | | Rated Current | Specify |
| | | Rated power frequency withstand voltage, RMS | Specify |
| | | Rated lightning impulse withstand voltage, peak | Specify |
| | | Minimum breaking /making capacity peak | Specify |

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



TITLE:
AUTOMATIC LOAD TRANSFER SWITCH
Part 2: 11KV INDOOR AUTOMATIC LOAD TRANSFER SWITCH —
SPECIFICATION

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 17 of 18 | |

| | | | |
|----------|--|--|---------|
| | | Minimum number of Mechanical & Full load operations | Specify |
| | | Minimum number of operations under fault conditions | Specify |
| | | Rated short-time withstand current | Specify |
| | | Internal Arc Classification (IAC) in accordance to IEC 62271-200 | Specify |
| | | Standard degree of protection | Specify |
| | | Surge diverter rating | Specify |
| 4.2.4.2 | Insulation for the voltage transformers | | Specify |
| 4.2.4.3 | Spares required to run equipment for 15 years after installation | | List |
| 5 | Test standards | | State |
| 6.1 | Switches and associated components packed in a manner to protect from any damage in transportation and repeated handling. | | State |
| 6.2.1 | Each assembly and package of items associated with the switches suitably marked | | State |
| 6.2.2 | Information marked indelibly and legibly on each item | | List |
| A | Tests and Inspection (Normative) | | |
| A1 | Tests to be performed and the standards of tests | | State |
| A2 | copies of previous type test reports by the relevant independent /international testing laboratory submitted | | State |
| A3 | Factory Acceptance Tests to be witnessed by KPLC Engineers at the factory | | List |
| A4 | Supplier shall replace without charge to KPLC items that don't meet specification | | Specify |
| B | Quality Management System (Normative) | | |
| B1 | QAP and ISO 9001:2008 | | State |
| B2 | Copies of quality management certifications attached | | State |
| B3 | Delivery time, Production capacity & experience of the manufacturer | | State |
| C | Technical Documentation(Normative) | | |
| C1 | Technical documents to be submitted with tender documents | | |
| | a. Fully-filled clause by clause Guaranteed Technical Particulars (GTPs)- Appendix D - stamped and signed by the manufacturer. | | |
| | b. Detailed drawings and technical data of the automatic load transfer switch (all in English Language) | | state |
| | c. Detailed manuals and drawings of the installation and control unit circuits and components shall accompany the tender (all in English Language) | | Specify |
| | d. Wiring diagram for complete set of auto-changeover switch | | State |

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2019-10-17

Date: 2019-10-17



TITLE:
AUTOMATIC LOAD TRANSFER SWITCH
Part 2: 11KV INDOOR AUTOMATIC
LOAD TRANSFER SWITCH — SPECIFICATION

| | |
|---------------|-------------------------|
| Doc. No. | KP1/6C/4/1/TSP/11/007-2 |
| Issue No. | 2 |
| Revision No. | 1 |
| Date of Issue | 2019-10-17 |
| Page 18 of 18 | |

| | | |
|----|---|-------|
| | e. Details of manufacturing capacity | |
| | f. Copies of required type test certificates and type test reports by a third-party testing laboratory accredited to ISO/IEC 17025 | |
| | g. Sales records for previous five years and reference letters from at least four of the customers | State |
| C2 | Documents to be submitted for approval before manufacture | |
| | a) Fully filled clause by clause Guaranteed Technical Particulars (GTPs) stamped and signed by the manufacturer (these are not the ones submitted with the tender); | State |
| | b) Detailed drawings and technical data of the automatic load transfer switch (all in English Language) | State |
| | c) Detailed manuals and drawings of the installation and control unit circuits and components shall accompany the tender (all in English Language) | State |
| | d) Wiring diagram for complete set of auto-changeover switch | State |
| | e) Marking and packaging details | State |
| C3 | Number as built drawings provided before shipment | State |
| C4 | Manuals to be provided during delivery | State |

** Words like 'agreed', 'confirmed', 'As per KPLC specifications', etc. shall not be accepted and shall be considered non-responsive.*

.....
Manufacturer's Name, Signature, Stamp and Date

| | |
|---|--|
| Issued by: Head of Section, Standards Development | Authorized by: Head of Department, Standards |
| Signed: | Signed: |
| Date: 2019-10-17 | Date: 2019-10-17 |