



- NOTES**
- A) SMESH REINFORCEMENT TO BE SIZE A1/2
  - B) CONCRETE MIX TO BE CLASS 30/45 PER M.O.W. SPECIFICATIONS IE 12/4 MIX
  - C) BUILDING CONCRETE TO BE 14/8 MIX POLYMER SHERING GAUGE 3009
  - D) REINFORCEMENT STEEL TO BE AS PER 4661/4469 FOR HIGH YIELD AND MILD YIELD STEEL RESPECTIVELY.
  - E) MINIMUM COVER TO MAIN REINFORCEMENT TO BE FOR BEAMS 25mm SLAB 15mm ROUNDOFFS IN CABLE TRENCHES 50mm
  - F) NOTATIONS Y HIGH YIELD BARS SQ TWISTED T TOP STEEL ROUND B BOTTOM
  - G) FOUNDATION DEPTH TO BE DETERMINED ON SITE MINIMUM 1200mm.
  - H) ALL DIMENSIONS ARE TO BE IN MM UNLESS OTHERWISE STATED.

APPROVED	DATE	NAME	ROLE
DESIGN		Eng. S. K. Singh	DESIGNER
CHECKED		B. Ghosh	CHECKER
PREPARED		S. K. Singh	DRAWN
DATE			
SCALE			

REVISION	DATE	DESCRIPTION
1		
2		
3		
4		
5		
6		

**GENERAL ARRANGEMENT, PLAN, SECTION, SLAB & ROOF DETAIL FOR 10M X 5M CONTROL ROOM**

