

Our Ref: KP1/9A.1A/OT/012/20-21/JN/ama

05th February, 2021

TO ALL TENDERERS

RE: ADDENDUM NO. I TO TENDER NO.KP1/9A.1A/OT/012/20-21 FOR PROCUREMENT OF AERIAL WARNING BALLS.

Please refer to the above Tender. We make the following amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Supply of Smart Large Power Metering units

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT (PTD)

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. KP1/6C/4/1/TSP/03/019-SPECIFICATION FOR POWER LINE AERIAL MARKERS – CLAUSE 4.2 DESIGN AND CONSTRUCTION.

A clarification is made on sub-clause **4.2.9**; power line aerial markers particular requirement (table 1) as indicated below.

MECHANICAL STRUCTURE	
PARAMETER	REQUIREMENTS
Colour	Red: Top half of the sphere with groove Yellow- lower half of the sphere with comb
Diameter	24" or 600 mm
Preformed Armor Rods	Preformed grip for 10sq mm conductor

3. TENDER CLOSING DATE

The tender closing date remains **18th February, 2021 at 10:00am.**

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



Dr. JOHN NGENO
GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS