



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/23/20-21/JN/jk

12th January, 2021

TO ALL TENDERERS

RE: ADDENDUM NO. 2 TO TENDER NO.KP1/9A.3/OT/23/20-21 FOR SUPPLY OF SMART LARGE POWER METERING UNITS.

Please refer to the above Tender. We make the following amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Supply of Smart Large Power Metering units

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT (PTD)

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLAUSE 3.1.11.3-TENDER PRICES

Clause 3.11.3- Local Tenderers shall quote on Delivery Duty Paid (DDP) basis and foreign tenderers shall quote on Delivery at Place(DAP) basis.

To help in understanding Definitions

DAP” wherever appearing means the supplier or its appointed agent shall have the responsibility of shipping the goods, paying all freight costs and the discharging port charges, payment of customs duties and taxes on behalf of KPLC (should be made in the name of KPLC where Value added Tax (VAT) paid at the port will be reimbursed), undertaking customs clearance of goods, transporting and delivering the goods from the port of discharge to KPLC stores or other destination as may be indicated.

DDP” wherever appearing means Delivered Duty Paid. The supplier’s responsibilities shall include payment of all taxes, duties and levies, and delivery to KPLC stores. For avoidance of doubt, this includes Value Added Tax(Vat), Railway Development Levy (RDL) and Import Duties.

3. SECTION IV SCHEDULE OF REQUIREMENT

A clarification is made for Metering requirement for Lot A-33kv/66kv/132kv that the solution for the various voltage(s) is the same.

4. SECTION V - PRICE SCHEDULE FOR GOODS

The price schedule has been amended as below and bidders shall use this format.

1	2	3	4	5	6	7	8	9	10
No.	KPLC Code	Description	Qty (PC)	For Local bidders			For Foreign Bidders		
				Unit price Ksh DDP VAT Exclusive	Total price Ksh DDP VAT Exclusive	Total price Ksh DDP VAT Inclusive	Unit price Ksh DAP VAT Exclusive	Total price Ksh DAP VAT Exclusive	Total price Ksh DAP VAT Inclusive

5. KP1-6C-4-1-TSP-14-018-SPECIFICATION FOR 12KV OUTDOOR PROTECTION METERING BREAKER UNITS-CLAUSE 4.5.5 CURRENT TRANSFORMERS

A clarification is made on sub-clause 4.5.5.5 that the CT accuracy is 0.2 and not 0.5 as indicated.

6. TENDER CLOSING DATE

The tender closing date remains **27th January 2021 at 10:00am.**

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

Dr. JOHN NGENO
GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS