



The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3201889
Stima Plaza, Kolobot Road

Our Ref: **KP1/9A.2/OT/109/NM/23-24/JM/at**

29th May, 2024

M/s

Dear Sir/Madam,

ADDENDUM NO. I TO THE TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF RISER BOARD AND LOW VOLTAGE DISTRIBUTION BOARD AT NAIROBI, NAKURU AND KISUMU ELECTRICITY HOUSES UNDER TENDER NO. KP1/9A.2/OT/110/ADMIN/23-24

The following clarifications are made to the specified provisions of the Tender document.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. CLARIFICATION

Bidders are informed the amendment of the following:-

a) Section III – Tender Data Sheet

ITT Reference	PARTICULARS OF APPENDIX TO INSTRUCTIONS TO TENDERS
F	Award Criteria
ITT 45.1	Award Criteria shall be made as follows:- a) These are three lots. Bidders are free to quote for the sites they visited. b) Award shall be made to the lowest evaluated bidder per lot. No bidder shall qualify for more than one lot.

	<p>c) If a bidder emerges the lowest in more than one lot they will be awarded the lot with the highest value.</p> <p>d) Consequently, the subsequent lots shall be awarded sequentially following (c) above until all the lots are allocated provided that the price of the subsequent qualified bidder is within the prevailing market price.</p> <p>e) In case there is no other qualified subsequent bidder for the unallocated lot(s) , the award will revert to the tenderer with the lowest evaluated price per lot, notwithstanding (b) above.</p>
--	--

- a) A revised form of tender is attached as **appendix I**.
- b) Drawings for lot II and Lot III are attached as **appendix II** and **appendix III** respectively
- c) Summary page signed by QS is not applicable for this tender however bidders are required to fill the price schedules provided per lot.
- d) Refer to Lot III – Kisumu Electricity House item D/5.1 on pump capacity requirement is of 2.2kW minimum

3. TENDER CLOSING DATE

The tender closing date remains the same as **Thursday, 6th June, 2024 at 10.00am**. Bidders are encouraged to witness the tender opening that will be at Stima Plaza - Auditorium.

Yours faithfully,

For: **THE KENYA POWER & LIGHTING CO. PLC**



DR. JOHN NGENO, OGW
GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS