



Kenya Power

*The Kenya Power & Lighting Co. Ltd
Central Office – P.O. Box 30099 Nairobi, Kenya
STIMA PLAZA, KOLOBOT ROAD, PARKLANDS, NAIROBI.
Telephone – 24-20-3201000 – Fax No. 254 – 20 – 3514485*

*Our Ref: KP1/9A.3/OT/28/19-20
Your Ref:*

Date: 1.4.2020

TO:

ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

The following amendments are made to the specified provisions of the Tender document for the Supply of Single Phase Prepayment Meters (S/P)

RE: ADDENDUM (NO. 1) TO THE TENDER NO. KP1/9A.3/OT/28/19-20 FOR (SUPPLY OF SINGLE PHASE PREPAYMENT METER.)

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT.

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. TENDER SPECIFICATIONS

This is to advise that the technical specifications should be revised as follows for the following clauses: -

- a) Clause 4.2.2.2.8 – the UIU shall communicate via PLC to and from the MCU through both the supply and load side of the MCU independently.
- b) Clause 4.3.6 – the Auto scroll sequence to scroll the following
 - Remaining Credit
 - Date and Time
 - Flagged alarms e.g Bypass, Meter Terminal Cover Open

3. TENDER CLOSING

The tender closing date has been extended from 7th April 2020 **to 28th April 2020 at 10.00am.**

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED



DR. JOHN NGENO
GENERAL MANAGER, SUPPLY CHAIN.