



Kenya Power

The Kenya Power & Lighting Co. Ltd.  
Central Office – P.O. Box 30099, Nairobi, Kenya  
Telephone – 254-02-3201000-Telegrams 'ELECTRIC'  
Fax No. 254-02-310336  
Stima Plaza, Kolobot Road

KP1/9A.2/OT/006/ADMIN-ICT/19-20/JN/ba

22<sup>th</sup> August 2019

M/s.....

Dear Sir,

**ADDENDUM NO. 1 TO TENDER NO: KP1/9A.2/OT/006/ADMIN-ICT/19-20  
PROPOSED REPLACEMENT OF LOW VOLTAGE (LV) BOARD AND  
ASSOCIATED CIVIL WORKS FOR ELECTRICITY HOUSE NAIROBI**

The following amendments are made to specified provisions of the Tender document

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the principal tender document shall continue to be in full force and effect.

The provision of this Addendum shall be deemed to have been incorporated in and shall be read as part of the principal tender document

**2. CLARIFICATIONS MADE TO QUERIES ON THE TENDER DOCUMENT**

The following are responses made to clarifications sought on various issues on the tender document and shall be deemed to form the Addendum.

**a. SECTION VI: Evaluation criteria 6.16**

Because of the sensitivity of works involved NCA 4 and above (under Electrical / Mechanical Engineering Services) may be accepted to carry out the works.

**b. Guarantee Specifications; SECTION IV, Lot 1**

Amended to read as attached below; this to include Bypass Switch, AVR

1.	Switchboard Panel	Form 3/4bi LV board also accepted
----	-------------------	-----------------------------------

2.	Bypass switch	Set of Stabilizer Bypass Switch comprising of the following:  1600A 4P non-withdrawable ACB of type NW16H1 (to AVR stabilizer)  1600A 4P key interlocked non-withdrawable switch disconnecter of type NW16HA (from stabilizer and bypass)
----	---------------	---

**c. LOT 1: DESIGN, SUPPLY & INSTALLATION OF NEW LV BOARD; SECTION V**

Amended to include the following:

B/9	Supply of spares parts		
	1600 A TPN draw out type ACB EDO	NO	1
	1200 A TPN ACB EDO	No	1
	250A MCCB	No	2
B/2.9	Automatic Voltage Regulator	NO	1

**d. Kindly ignore the previous scope of works, price schedule and drawings and adopt the amended ones to reflect changes.**

**3. SECTION 1.INVITATION TO TENDER**

- a. **Site Visit:** was held on 20 August 2019 from 10:00am at Electricity House Nairobi and it was mandatory. All the bidders present were registered. Kindly note the scope of works & service is different from previous tender.
- b. **Opening of Submitted Tenders:** The tender closing date has been extended from **28<sup>th</sup> August, 2019** to **06<sup>th</sup> September, 2019** at **10:00am** and opening on the same day at **10.30am**.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

**For: KENYA POWER & LIGHTING COMPANY LIMITED.**

  
**BERNARD NGUGI**  
**GENERAL MANAGER, SUPPLY CHAIN**