



# Kenya Power

Central Office – P.O. Box 30099, Nairobi, Kenya  
Telephone – 254-02-3201000  
Fax No. 254-02-3514485  
StimaPlaza, Kolobot Road  
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/10<sup>14</sup>/18-19/JN/hm

30<sup>th</sup> June 2019

TO:

ALL PROSPECTIVE BIDDERS

**RE: ADDENDUM NO.2 TO THE TENDER NO. KP1/9A.3/OT/14/18-19 FOR FOR THE SUPPLY OF 11KV & 33KV AUTORECLOSERS.**

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (hereinafter abbreviated as the PTD) for the Supply and delivery of 11KV & 33LKV Autoreclosers

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

**2. TECHNICAL CLARIFICATION ON TENDER NO. KP1/9A.3/OT/14/18-19 FOR SUPPLY OF 11KV & 33KV AUTORECLOSERS**

Reference is made to the tender no. KP1/9A.3/OT/10<sup>14</sup>/18-19 for supply of 11KV and 33KV Autorelosers

The clarifications are made as below: -

No	Clause	Clause description	Bidder Question	KPLC Clarification
1	Tender point & 1.4 & clause 3.19	Tender validity	Clarify the validity period of Tender.	i) Tenders shall remain valid for <b>One Hundred and Eighty (180) Days</b> after the date of tender opening.

				ii) The tender security shall remain valid 30 days after the expiry of tender validity.
2	4.11(d) (KPLC specifications)	Pollution	What pollution level category the autoreclosers are required.	Advice manufacturers to treat all the equipment for very heavy pollution
3	4.2.3 (KPLC Specifications)	Insulation medium and Arc Interruption	If vacuum interruption under SF6 gas for insulation would be acceptable	As per clause 4.2.3 , either air(SF6)or solid insulation is acceptable.
4	Appendix F4.1-f3	Manufacturers recommended spares	We note that repairs and maintenance facilities should be available, however we do not see any request for any recommendation spares. Please advise if we should quote for the recommended spares to be carried for the maintenance of the autoreclosers.	As per appendix F, clause F.1, the manufacture is required to provide a list of recommended spare parts to ensure that the reclosers provide at least 10 years of continuous service. The price(s) is to be provided separately from the bid as an option.
5			As per technical specifications for 11kv and 33kv autoreclosers, spares items section and computers section, please clarify if  a) The stated spares to be supplied per lot or per unit in a lot.  b) The computers are per lot	(a) As per appendix F, clause F.1, the manufacture is required to provide a list of recommended spare parts to ensure that the reclosers provide at least 10 years of continuous service. The price(s) is to be provided separately from the bid as an option.  (b) The four computers are per Lot.

6. Please note following.

- a) In the portal the currency is fixed as Kenya shillings and cannot be changed. Please ignore and submit your quotation in your preferred currency on a separate price schedule as an attachment.
- b) Tender security-  
Please note you may submit your tender security with a total sum amount for both items or for each item separately whichever is easier for you.
- c) We have attached updated specifications for 11KV Autoreclosers dated 30.05.2019. Ignore the previous attached and use the current specifications.
- d) The closing date has been extended from 4<sup>th</sup> June 2019 to 18<sup>th</sup> June 2019.

Please note the clarifications and adhere to them.

All other terms and conditions remain the same.

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED**



**JANE NDINYA**

**Ag. SUPPLY CHAIN MANAGER, PROCUREMENT**

