



Kenya Power

Central Office – P.O. Box 30099 – 00100,  
Telephone – 254-02-3201000  
Fax No. 254-02-3514485  
Stima Plaza, Kolobot Road,  
Nairobi, Kenya

**Our Ref:** KP1/9A.3/OT/09/17-18  
**Your Ref:**

Date: 27th October, 2017

TO: ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

**RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9A.3/OT/15/17-18 FOR SUPPLY OF POWER TRANSFORMERS**

Please refer to the above Tender.

The following amendments are made to the specified provisions of the Tender document for the Supply of Power Transformers.

**1) RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

**2) APPENDIX TO INSTRUCTION TO TENDERERS.**

Bidders are reminded on clause 3.13.3 (a) on Manufacturers authorization is not applicable for this tender, as the tender is open to **MANUFACTURERS ONLY**

**3) BIDDERS QUERIES AND RESPONSES**

KPLC has received various requests for clarifications and respond as follows:

**Responses for 7.5MVA -33/11kV & 23MVA 33 & 66/11kV Power Transformers**

| No | Clause/ Item  | Query  | KPLC Response   |
|----|---|--|---|
| 1  | 4.12.8<br>On load Tap changer<br><br>4.19<br>Fittings and accessories | <p>The tap changer shall be of design and make approved by KPLC</p> <p>All fittings and accessories including Gas &amp; Oil Actuated Relays shall be of design &amp; make approved by KPLC</p> <p>In this context, please provide us the list of approved makes of OLTC, Fittings and Accessories to be considered for this tender</p>   | <p>The items shall be provided as per the clauses 4.12.8 and 4.19 read in full.</p> <p>The requirements are given in the clauses 4.12.8 and 4.19 and shall be approved at evaluation as per clause 7.1 of the specification and before manufacture as per clause 7.2 of the specification. Please comply.</p> |
| 2  | 4.7.4<br>Impedance  | <p>The impedance voltage at extreme tappings and principal tapping shall be stated and shall be subject to tolerances in accordance with IEC 60076. The minimum as per IEC 60076-5 for this size of transformer is 8%</p> <p>Typical values for existing 7.5MVA -33kV 23MVA-33 &amp; 66kV transformers in KPLC system at principal (nominal) tap are 9.8% - 10.1%</p> <p>The two clauses are contradictory in case of parallel operation.</p> <p>So please confirm the exact impedance for us to design and also to satisfy existing KPLC system</p> | <p>The Transformers shall be provided as per the typical values for existing 7.5MVA -33kV 23MVA-33 &amp; 66kV transformers in KPLC system at principal (nominal) tap which are 9.8% - 10.1%</p>   |
| 3  | Schedule of requirements  | <p>For 23MVA – 33/11kV Power Transformers, the vector group is mentioned as YNyn0d1 and Dyn11</p> <p>For YNyn0d1, an additional winding is to be provided with Delta connection. But except in this clause nowhere is it specified as tertiary winding. Hence, please confirm whether the vector group is YNyn0d1 or YNyn0</p>   | <p>The vector group shall be YNyn0d1 for 23MVA 33/11 as indicated in the Schedule of requirements</p>   |
| 4  | 4.8.2<br>Bushings   | <p>Bushings of 33kV and 11kV terminals shall be of the solid porcelain type. To satisfy insulation requirements, 33kV bushings may be of oil filled condenser type construction, draw out type and shall have capacitance test point</p> <p>Creepage distance of bushings shall not be</p>   | <p>The clause 4.8.2 gives both options for 33kV bushings. Solid porcelain type is the preferred option.</p> <p>Please provide all necessary supporting documents as per clause 7 of the specifications.</p>   |

| No   | Clause/ Item | Query  | KPLC Response                         |  |      |      |                                     |    |     |     |   |    |     |     |  |    |     |     |   |    |     |     |   |
|--|--------------|--|---------------------------------------|--|------|------|-------------------------------------|----|-----|-----|---|----|-----|-----|--|----|-----|-----|---|----|-----|-----|---|
|  |              | <p>less than 31mm/kV based on operating phase to phase voltage</p> <p>We are pleased to inform you that, the 31mm/kV creep bushings are able to meet the required insulation levels. In this context, we would like to go with solid porcelain type bushings instead of condenser bushings for 33kV &amp; 11kV. Kindly confirm. However, we will provide you the supporting test reports at the time of detailed engineering.</p>  |                                       |  |      |      |                                     |    |     |     |   |    |     |     |  |    |     |     |   |    |     |     |   |
| 5  | 4.10.3       | <p>The minimum external clearances are as shown below:</p> <table border="1" data-bbox="440 689 956 1592"> <thead> <tr> <th data-bbox="440 689 679 801">Nominal system voltage between phases</th> <th data-bbox="679 689 759 801"></th> <th data-bbox="759 689 855 801">33kV</th> <th data-bbox="855 689 956 801">11kV</th> </tr> </thead> <tbody> <tr> <td data-bbox="440 801 679 920">Phase to Earth and Phase to Neutral</td> <td data-bbox="679 801 759 920">mm</td> <td data-bbox="759 801 855 920">485</td> <td data-bbox="855 801 956 920">300</td> </tr> <tr> <td data-bbox="440 920 679 1115">Phase to phase between between phases of the same winding</td> <td data-bbox="679 920 759 1115">mm</td> <td data-bbox="759 920 855 1115">485</td> <td data-bbox="855 920 956 1115">300</td> </tr> <tr> <td data-bbox="440 1115 679 1391">A line terminal of the high voltage winding and a line terminal of a lower voltage winding</td> <td data-bbox="679 1115 759 1391">mm</td> <td data-bbox="759 1115 855 1391">485</td> <td data-bbox="855 1115 956 1391">300</td> </tr> <tr> <td data-bbox="440 1391 679 1592">A live metal oil pipe work including conservator relief design.</td> <td data-bbox="679 1391 759 1592">mm</td> <td data-bbox="759 1391 855 1592">485</td> <td data-bbox="855 1391 956 1592">300</td> </tr> </tbody> </table> <p>We are presuming that the given External clearances and insulations are including the altitude (2200m above sea level) for correction factor.<br/>Kindly Confirm</p> | Nominal system voltage between phases |  | 33kV | 11kV | Phase to Earth and Phase to Neutral | mm | 485 | 300 | Phase to phase between between phases of the same winding | mm | 485 | 300 | A line terminal of the high voltage winding and a line terminal of a lower voltage winding | mm | 485 | 300 | A live metal oil pipe work including conservator relief design. | mm | 485 | 300 | <p>The clearances given include correction factor and shall be provided as per the specification as a minimum. Better clearances are welcomed</p> |
| Nominal system voltage between phases  |              | 33kV   | 11kV                                  |  |      |      |                                     |    |     |     |   |    |     |     |  |    |     |     |   |    |     |     |   |
| Phase to Earth and Phase to Neutral  | mm           | 485  | 300                                   |  |      |      |                                     |    |     |     |   |    |     |     |  |    |     |     |   |    |     |     |   |
| Phase to phase between between phases of the same winding                                  | mm           | 485  | 300                                   |  |      |      |                                     |    |     |     |   |    |     |     |  |    |     |     |   |    |     |     |   |
| A line terminal of the high voltage winding and a line terminal of a lower voltage winding | mm           | 485  | 300                                   |  |      |      |                                     |    |     |     |   |    |     |     |  |    |     |     |   |    |     |     |   |
| A live metal oil pipe work including conservator relief design.                            | mm           | 485  | 300                                   |  |      |      |                                     |    |     |     |   |    |     |     |  |    |     |     |   |    |     |     |   |

| No | Clause/ Item                | Query  | KPLC Response  |
|----|-----------------------------|--|--|
| 6  | 4.11                        | <p>The impulse level for 33kV &amp; 11kV are 200kVp &amp; 95kVp respectively</p> <p>We hereby inform you that, as per IEC 60076-3, the lightning impulse withstand voltage (BIL) for 33kV &amp; 11kV is 170kVp &amp; 75kVp. In view of this, please confirm whether to proceed as per IEC 60076.</p>   | Please provide in compliance with the specification. |
| 7  | 4.9<br>Current Transformers | <p>Current Transformers shall be installed in bushing turrets and shall be of the following quantities, ratios, ratings and class as per clause 4.9.1 (Table)</p> <p>In this context, for PS class current (phase CTs) transformers, knee pint voltage, magnetizing current &amp; Rct values are not mentioned in the technical specification. Hence, please provide us the values for us to consider the exact CT's as these are related to protection equipments (relays and circuit breakers) at your site.</p> | Please provide in compliance with the specification. |
| 8  | 5.3.3<br>Additional Tests   | <p>As per the technical specification, Condenser Bushing capacitance and tan delta test to be conducted during acceptance testing at our factory.</p> <p>In this context, we will provide you the type test report of condenser bushings from our supplier. Kindly confirm</p>   | Please provide in compliance with the specification. |
| 9  | 5.3.3<br>Additional Tests   | <p>For 7.5MVA-33/11kV, the technical specification calls for measurement of power taken by the fans to be done during acceptance testing at our factory.</p> <p>We hereby inform you that 7.5MVA transformer is ONAN only. In view of this, fans are not required for this rating. Hence, there is no need to conduct this test "Measurement of power taken by fans" for this rating. Please confirm</p>   | The 7.5MVA is ONAN type so no need for this test.    |
| 10 | 7.15<br>Transportation      | <p>As per clause 7.15 General conditions of contract, the supplier shall be required to meet all the transport expenses until delivery</p> <p>In this context, please confirm whether the bidder has to consider unloading charges also at the KPLC stores (or) not.</p>   | Bidder to meet all costs                             |

| No                        | Clause/ Item   | Query  | KPLC Response   |
|---------------------------|--|--|---|
| 11                        | Section IV - Schedule of Requirements of Goods       | NOTE: All deliveries shall be made to the indicated sub-stations and stores.<br><br>In this clause it is indicated that the deliveries to be made to substations and stores. Please inform if we need to deliver the complete transformer with accessories to substation or KPLC stores.   | Complete transformers shall be delivered to the place stated in the schedule of requirements with all its accessories   |
| 12                        | 4.19   | As per Clause No. 4.19 - Fitting and Accessories it is mentioned that "All the Fitting & Accessories including Gas and Actuated relays shall be of a design and make approved by KPLC". Request you to kindly provide and send the list of approved make for all fitting and accessories as per KPLC.  | The items shall be provided as per the clause 4.19 read in full.<br>The requirements are given in the clause 4.19 and shall be approved at evaluation as per clause 7.1 of the specification and before manufacture as per clause 7.2 of the specification. Please comply.  |
| 13                        | Vector group for 23MVA, 33/11kV for Lanet substation | In tender documents details are mentioned rating wise and their respective vector groups. Whereas, for 23 MVA ,33/11 kV rating and for lanet substation, different vector groups mentioned at two different places. Kindly check and confirm the vector group, whether it is YNyn0d1 or Dyn11.   | The vector group shall be Ynyn0d1 for 23MVA 33/11 as indicated in the Schedule of requirements  |
| 14                        | Tertiary Winding                                     | For 23 MVA ,33/11 kV rating, vector group mentioned is YNyn0d1. We would like to inform you that if there is requirement of third winding (tertiary), then please provide us the Voltage rating and MVA rating of tertiary winding. If tertiary winding is loaded then also provide the Impedance Values between LV- Tertiary and HV-Tertiary winding.   | The tertiary winding shall not be loaded. It shall be for magnetic balancing and shall have a rating sufficient to take short-circuit fault currents.   |
| 15                        | Letter of credit for International bidders           | In tender documents Payment terms, it is mentioned that International bidders can request/propose Letter of Credit Payment Terms. It means International bidder can request for LC after contract award. Request you to kindly confirm that International bidders can propose Letter of Credit payment terms during bid stage and kindly specify the validity period of Letter of credit and when it will be open. | All bidders are required to note that clause 7.18.8 gives them an option for letter of credit, but clause 7.18.9 gives KPLC, the discretion to accept or reject the request.<br>For LC validity refer to clause 7.18.8 (f)iv.<br>LC opening is done after contract signing. |
| <b>Kenya Power change</b> |  |  |   |

| No | Clause/ Item             | Query  | KPLC Response  |
|----|--------------------------|--|--|
| 16 | Schedule of Requirements | Lanet substation 132/33 kV substation TX 45 MVA 132/33KV OIL TYPE code 453199 and vector group as Dyn1. It is proposed to change it to Dyn11 | The vector group shall be Dyn11 for the two transformers |

#### 4) SCHEDULE OF REQUIREMENT AMENDMENT

Bidders are notified that schedule of requirements has been amended as follows:

#### SECTION IV - SCHEDULE OF REQUIREMENTS OF GOODS

For Supply of Power Transformers – Tender No. KP1/9A.3/OT/15/17-18

| <u>7.5MVA 33/11KV TRANSFORMERS</u> |        |                               |           |              |                      |
|------------------------------------|--------|-------------------------------|-----------|--------------|----------------------|
| No                                 | Code   | SUBSTATIONS                   | QTY       | Vector Group | Tender Security(KSH) |
| 1                                  | 453192 | Litein 33/11kv substation     | 1         | Dyn11        | 225,000.00           |
| 2                                  | 453192 | Nyamininia 33/11kv Substation | 1         | Dyn11        | 225,000.00           |
| 3                                  | 453192 | Kanyakine 33/11kv Substation  | 1         | Dyn11        | 225,000.00           |
| 4                                  | 453192 | Sagana 33/11kv Substation     | 1         | Dyn11        | 225,000.00           |
| 5                                  | 453189 | Kitui 33/11kv Substation      | 1         | Dyn1         | 225,000.00           |
| 6                                  | 453192 | Sibembe 33/11kv Substation    | 2         | Dyn11        | 225,000.00           |
| 7                                  | 453192 | Njoro 33/11kv Substation      | 1         | Dyn11        | 225,000.00           |
| 8                                  | 453192 | Chavakali 33/11kv Substation  | 2         | Dyn11        | 225,000.00           |
| 9                                  | 453189 | Makuyu 33/11kv Substation     | 1         | Dyn1         | 225,000.00           |
| 10                                 | 453192 | Webuye 33/11kv                | 1         | Dyn1         | 225,000.00           |
| 11                                 | 453192 | Awendo 33/11kv Substation     | 1         | Dyn11        | 225,000.00           |
| 12                                 | 453192 | Kisian 33/11kv Substation     | 1         | Dyn11        | 225,000.00           |
| 13                                 | 453192 | Isiolo 33/11kv                | 1         | Dyn11        | 225,000.00           |
| <b>TOTAL</b>                       |        |                               | <b>15</b> |              |                      |

| <b>23MVA 33/11KV TRANSFORMERS</b> |        |                            |          |         |            |
|-----------------------------------|--------|----------------------------|----------|---------|------------|
| 1                                 | 453182 | Makande 33/11kv Substation | 1        | YNynOd1 | 495,000.00 |
| 2                                 | 453182 | Lanet 33/11 kv Substation  | 1        | YNynOd1 | 495,000.00 |
| <b>TOTAL</b>                      |        |                            | <b>2</b> |         |            |

| <b>23MVA 66/11KV TRANSFORMERS</b> |        |                               |          |       |            |
|-----------------------------------|--------|-------------------------------|----------|-------|------------|
| 2                                 | 498030 | Athi River 66/11kv substation | 1        | Dyn1  | 390,000.00 |
| 3                                 | 498030 | Epz 66/11kv substation        | 1        | Dyn1  | 390,000.00 |
| <b>TOTAL</b>                      |        |                               | <b>2</b> |       |            |
| <b>TX 23MVA 132/33KV OIL TYPE</b> |        |                               |          |       |            |
| 1                                 | 498033 | Kamburu 132/33kv substation   | 1        | Dyn1  | 690,000.00 |
| 2                                 | 498033 | Chemosit 132/33kv             | 2        | Dyn11 | 690,000.00 |
| <b>TOTAL</b>                      |        |                               | <b>3</b> |       |            |

| <b>TX 45 MVA 132/33KV OIL TYPE</b> |        |                                 |          |       |            |
|------------------------------------|--------|---------------------------------|----------|-------|------------|
| 1                                  | 453199 | Lanet 132/33 kv substation      | 2        | Dyn11 | 660,000.00 |
| 2                                  | 453199 | Nakuru West 132/33kv substation | 1        | Dyn11 | 660,000.00 |
| <b>TOTAL</b>                       |        |                                 | <b>3</b> |       |            |

### **SECTION V - PRICE SCHEDULE FOR GOODS**

*(TENDERER MUST INDICATE THE CURRENCY OF THE OFFER PRICE)*

| <b>7.5 MVA 33/11 TRANSFORMERS</b> |        |                               |     |              |                       |                    |                   |                              |                               |
|-----------------------------------|--------|-------------------------------|-----|--------------|-----------------------|--------------------|-------------------|------------------------------|-------------------------------|
| 1                                 | 2      | 3                             | 4   | 5            | 6                     | 7                  | 8                 | 9                            | 10                            |
| No                                | Code   | SUBSTATIONS                   | QTY | Vector Group | Delivery Destination  | Nearest KPLC store | Country of Origin | Unit price DAP/VAT Exclusive | Total Price DAP/VAT inclusive |
| 1                                 | 453192 | Litein 33/11Kv substation     | 1   | Dyn11        | Litein Substation     | Kericho            |                   |                              |                               |
| 2                                 | 453192 | Nyamininia 33/11kv Substation | 1   | Dyn11        | Nyamininia Substation | Kisumu             |                   |                              |                               |

|    |        |                                     |   |              |   |                                   |  |  |  |
|----|--------|-------------------------------------|---|--------------|---|-----------------------------------|--|--|--|
| 3  | 453192 | Kanyakine 33/11kv Substation        | 1 | Dyn11        | Kanyakine Substation  | Meru                              |  |  |  |
| 4  | 453192 | Sagana 33/11kv Substation           | 1 | Dyn11        | Sagana Substation   | Nyeri                             |  |  |  |
| 5  | 453192 | Kitui 33/11kv Substation            | 1 | Dyn1         | Kitui Substation  | Thika                             |  |  |  |
| 6  | 453192 | <b>Sibembe 33/11kv Substation</b>   | 2 | <b>Dyn11</b> | <b>1.No.Sibembe Substation<br/>1.No. Nairobi South Stores</b> | <b>Kakamega<br/>Nairobi South</b> |  |  |  |
| 7  | 453192 | Njoro 33/11kv Substation            | 1 | Dyn11        | Njoro Substation  | Lanet                             |  |  |  |
| 8  | 453192 | <b>Chavakali 33/11kv Substation</b> | 2 | <b>Dyn11</b> | <b>Chavakali Substation</b>                                   | <b>Kisumu</b>                     |  |  |  |
| 9  | 453192 | Makuyu 33/11kv Substation           | 1 | Dyn1         | Makuyu Substation   | Thika                             |  |  |  |
| 10 |        | Webuye 33/11 kv                     | 1 | Dyn1         | Webuye Substation   | Bungoma                           |  |  |  |
| 11 | 453192 | Awendo 33/11kv Substation           | 1 | Dyn11        | Awendo Substation   | Kisii                             |  |  |  |
| 12 | 453192 | Kisian 33/11kv Substation           | 1 | Dyn11        | Kisian Substation   | Kisumu                            |  |  |  |
| 13 | 453192 | Isiolo 33/11kv                      | 1 | Dyn11        | Isiolo Substation   | Nyeri                             |  |  |  |

|   |        |  |   |         |                  |         |  |  |  |
|---|--------|--|---|---------|------------------|---------|--|--|--|
|   |        | <b><u>23MVA<br/>33/11KV<br/>TRANSFORMERS</u></b> |   |         |                  |         |  |  |  |
| 1 | 453182 | Makande 33/11kv                                  | 1 | YNynOd1 | Mbaraki Stores   | Mombasa |  |  |  |
| 2 | 453182 | Lanet 33/11 KV                                   | 1 | YNynOd1 | Lanet Substation | Nakuru  |  |  |  |

|   |        |  |   |      |                      |               |  |  |  |
|---|--------|--|---|------|----------------------|---------------|--|--|--|
|   |        | <b><u>23MVA<br/>66/11KV<br/>TRANSFORMERS</u></b> |   |      |                      |               |  |  |  |
| 1 | 498030 | Athi River 66/11kv substation                    | 1 | Dyn1 | Nairobi South stores | Nairobi South |  |  |  |



|   |        |                        |   |      |                      |               |  |  |  |
|---|--------|------------------------|---|------|----------------------|---------------|--|--|--|
| 2 | 498030 | EPZ 66/11kv substation | 1 | Dyn1 | Nairobi South stores | Nairobi South |  |  |  |
|---|--------|------------------------|---|------|----------------------|---------------|--|--|--|

|   |        |   |   |       |                     |         |  |  |  |
|---|--------|---|---|-------|---------------------|---------|--|--|--|
|   |        | <b>TX 23MVA<br/>132/33KV<br/>OIL TYPE</b> |   |       |                     |         |  |  |  |
| 1 | 498033 | Kamburu 132/33kv substation               | 1 | Dyn1  | Kamburu Substation  | Embu    |  |  |  |
| 2 | 498033 | Chemosit 132/33kv                         | 2 | Dyn11 | Chemosit Substation | Kericho |  |  |  |

|   |        |   |   |       |                  |        |  |  |  |
|---|--------|---|---|-------|------------------|--------|--|--|--|
|   |        | <b>TX 45 MVA<br/>132/33 KV<br/>OIL TYPE</b> |   |       |                  |        |  |  |  |
| 1 | 453199 | Lanet 132/33kv substation                   | 2 | Dyn11 | Lanet Substation | Nakuru |  |  |  |
| 2 | 453199 | Nakuru West 132/33kv substation             | 1 | Dyn11 | Lanet Substation | Nakuru |  |  |  |

#### **5) DELIVERY SCHEDULE AND GUARANTEED LEAD TIME**

The delivery schedule shall be six within (6) months after award. The Guaranteed Lead Time will also be six (6) Months (i.e Bidders time to Manufacture + Bidders to delivery).

#### **6) CLOSING DATE**

The tender closing date has been extended from 31<sup>ST</sup> October, 2017 to close on the 14<sup>TH</sup> November, 2017 at 10.00 a.m.

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED**

  
**BERNARD NGUGI**  
**GENERAL MANAGER SUPPLY CHAIN.**