



Kenya Power

Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/18/19-20/JM/hm
December 20199

11th

TO:

ALL PROSPECTIVE BIDDERS

1. RE: ADDENDUM NO. 3 TO THE TENDER NO. KP1/9A.3/OT/18/19-2019 FOR SUPPLY OF CIRCUIT BREAKERS, SWITCHBOARD PANELS AND 11KV METERING PANELS

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply and delivery of circuit breakers, switchboard panels and 11KV metering panels.

2. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

3. CLARIFICATIONS

No	QUERIES	CLARIFICATION
1	Regarding the CT for incomers and outgoing in the main table and other tables you will find that the specs are different, which rating(s) should we use? Also the required short circuit for the SWG is 31.5 KA, whereas circuit breaker short circuit is 40 KA, kindly clarify.	Clarification The board shall be rated 17.5KV All feeders outs, incomers and bus couplers shall have the same voltage rating. All other Parameters remain as per tender specifications

All other terms and condition remain the same.

Kindly adhere to the changes.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED



JANE MUIGAI

Ag. SUPPLY CHAIN MANAGER, PROCUREMENT