



Kenya Power

*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000-Telegrams 'ELECTRIC'- www.kenyapower.co.ke
Stima Plaza, Kolobot Road*

Our Ref: KP1/6E.3/PT/2/18/A65 – A66

5th June 2018

Dear Sir/ Madam:

**AMENDMENT NO.2 TO IPC NO: KP1/6E.3/PT/2/18/A65 and KP1/6E.3/PT/3/18/A66
PROCUREMENT OF SINGLE PHASE PRE-PAID METERS AND MINIATURE
CIRCUIT BREAKERS FOR THE LAST MILE CONNECTIVITY PROJECT**

The following amendments are made to the specific provisions of the issued bidding documents for Procurement of Single Phase Pre-Paid Meters and Miniature Circuit Breakers for The Last Mile Connectivity Project (AFD/EU) and Procurement of Single Phase Pre-Paid Meters and Miniature Circuit Breakers for The Last Mile Connectivity Project (EIB)

RELATIONSHIP WITH THE PRINCIPAL BIDDING DOCUMENTS

Save where expressly amended by the term of the addendum, the Principal Bidding Documents shall continue to be in full force and effect. The provision of this addendum shall be deemed to have been incorporated in and shall be read and construed as part of the Principal Bidding Documents.

SECTION VII. SCHEDULE OF REQUIREMENTS NUMBER 3 – TECHNICAL SPECIFICATIONS

Appendix II – Miniature Circuit Breaker (MCB) Specifications

Clause 4.2.1 has been amended from “The connection terminals shall be screw terminals with washer or clamping plate or anti-spread device and shall be large enough to accommodate power supply cables up to 2.5mm²” to “The connection terminals shall be screw terminals with washer or clamping plate or anti-spread device and shall be large enough to accommodate power supply cables up to 10mm².”

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.

**JOHN NJEHIA
CONTRACT PROJECT MANAGER – AFD/EU/EIB**