



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9AA-3/PT/07/14-15

Date 19th June 2014

M/s

.....

Dear Sirs,

ADDENDUM NO. 1 TO THE TENDER NO. KP1/9AA-3/PT/07/14-15 FOR SUPPLY OF TERMINATION AND JOINTING KITS

The following amendments are made to the specified provisions of the Tender document for Supply of termination and jointing kits dated May 2014.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. RESPONSES TO QUERIES ARE AS FOLLOWS

Question

Refer to the specification with No. KP1-3CB-TSP-05-026-1 specification for cable termination and jointing kits for voltages up to 33kV, we can find that the 11kV and 33kV cable accessories can be heat shrinkable or cold shrinkable. However, in the products list from SECTION IV-SCHEDULE OF REQUIREMENTS OF GOODS, TABLE 1, should it be cold shrinkable cable accessories or heat shrinkable cable accessories?

Answer:

It is open to the bidders to provide either heat shrinkable or cold shrink kits.
Both are acceptable.

3. DEADLINE FOR SUBMISSION OF TENDER

The closing date for the tender is **Wednesday 2nd July 2014 at 10.00 a.m.** Tenders shall be opened immediately thereafter in the Auditorium located at Stima Plaza, Kolobot Road, Nairobi.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.


BERNARD NGUGI

Ag. CHIEF MANAGER, SUPPLY CHAIN & LOGISTICS.