



Kenya Power

IES&R – P.O.Box.10355 Nairobi,Kenya
Telephone **85611205, 8563163, 8563349, 8563062**
Fax: **8566043**
Email Address: **iesinfo@kplc.co.ke**
Mobile No. Safaricom: **0725559900**

Our Ref: KPI/1/3A/4/1/OT/002/19-20/vs

11th November, 2019

Dear Sirs/madam,

ADDENDUM NO.1: TENDER NO. KP1/1/3A/4/1/OT/002/19-20 FOR SUPPLY AND DELIVERY OF ROUTERS, FIBRE OPTIC CABLES, TOOLS AND ACCESSORIES

In response to the prospective bidder's request for clarification on specific terms and conditions of the Tender, the following amendments are made to the specified provisions of the tender document for **SUPPLY AND DELIVERY OF ROUTERS, FIBRE OPTIC CABLES, TOOLS AND ACCESSORIES**.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provision of this addendum shall be deemed to have been incorporated in and shall be read as part of the principal tender document.

2. CLARIFICATIONS:

	BIDDER'S QUESTION	CLARIFICATION
a	<p>From KPLC'S specifications: Table 1 - Mechanical and environmental specifications for 48 core SM(9/125) ADSS Fibre Optic Cable. The ADSS cable is required for installation on power lines upto 66kv. The cable jacket specified is PE for ADSS and AT for approach cable. The raised concern is that the PE jacket cannot provide protection upto 66kv and that AT jacket would be preferred</p>	<p>The ADSS Cable specifications are to be maintained as they are – Ref to Table I of KPLC's specifications.</p> <p>The required cable shall be suitable for use on power lines charged upto 66KV as specified.</p>
b	<p>Clarification was sought on whether Manufacturers' Authorization is required for</p>	<p>Under Lot 1. Manufacturer's Authorization is required for items listed under Schedule of Requirements For this category 1.0.</p>

	items such as portable chairs, tents and others under tools.	1.0 Fiber Optic Cable and Fiber Installation Accessories. However, for categories 1.1 & 1.2 under Schedule of Requirements , it (Manufacturer's Authorization) is not necessary – that is for: 1.1 Fiber Optic Cable Splicing Accessories and 1.2 Fiber Optic Cable Maintenance Equipment
--	--	---

3. TENDER SUBMISSION/CLOSING DATE:

The tender closing date remains Monday 18th November, 2019 at 10.00am as indicated in the tender document.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



JOYCE OCHIENG

Ag. GENERAL MANAGER, SUPPLY CHAIN