



Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/07/18-19/JN/hm

2nd January, 2019

TO:

ALL PROSPECTIVE BIDDERS

**RE: ADDENDUM NO. 1 TO THE TENDER NO. KP1/9A.3/OT/07/18-19 FOR FOR THE SUPPLY OF AUTO LOAD
TRANSFER SWITCH 11KV& AUTO CHANGEOVER 11KV OUTDOOR TYPE-YOUTH, WOMEN & PWDs**

Please refer to the above tender.

We make the following clarifications and amendments to the above Principal Tender Document (hereinafter abbreviated as the PTD) for the Supply and delivery of fuel to Off-grid Power Stations

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATION ON SPECIFICATIONS:

Please note the correction on specifications **Document no. KP1/6C/4/1/TSP/11/007-2, for Indoor Auto Load Transfer Switch 11KV on clause 4.2.4.1 - rated short-time withstand current should be 25kA, 3 sec and not 16kA, 3sec**

Please stick to all other specifications notes.

3. EXTENSION OF CLOSING DATE:

From 16.01.2019 to 22.01.2019 at 2.00 pm

All other terms and conditions remains.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED


EVA ANJICHI
Ag. SUPPLY CHAIN MANAGER, PROCUREMENT