



Central Office – P.O. Box 30099 – 00100,
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road,
Nairobi, Kenya

Our Ref: KP1/9A.1A/OT/033/18-19/JKN/ji
Your Ref:

Date: 07th August, 2019

TO:

ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

RE: ADDENDUM NO. 1 TO THE TENDER NO. KP1/9A.1A/OT/033/18-19 FOR SUPPLY, INSTALLATION AND COMMISSIONING OF TWO 500KVA ENCLOSED DIESEL GENERATOR AT RHAMU AND LAISAMIS POWER STATIONS

Please refer to the above Tender.

The following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Supply, installation and commissioning of two 500kva enclosed diesel generator at Rhamu and Laisamis power stations

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS

Bidders are notified that the following are clarifications.

- **Automation of the fuel day tank to protect overflow of diesel when pumping from the service tank** - Bidders are notified that the technical specifications for the day tank to be supplied are clearly stated in the tender Technical specifications clause 2.7.1 (h). The high level warning should in essence provide an alert for possible overflow
- **Whether the tender included the control panel breaker and the deepsea Generator controller** - Supply of control breaker and Deep-Sea generator controller is not contained in the tender. In addition, it is the suppliers mandate to ensure that the delivered set is able to synchronize with the existing set. This is captured and highlighted in the tender document, SECTION IV - Technical specifications –Diesel Genset and associated components- PART I, clause 2.5.6.4 (page 46). The type and size of cables required is captured in SECTION IV- Technical specifications –Part II – Power Cable Specifications (Page 52).

- **Guaranteed technical particulars (GTP)** – Bidders are notified that the GTP has been uploaded in the portal as **Appendix 1**
- **SECTION IX – Special Conditions of Contract-** Bidders are notified that the Special Condition of contract has been amended and uploaded in the portal as **Appendix 11**
- **7.2.5.1 Mandatory Requirements General (Mandatory requirements)-** Bidders are notified that the mandatory requirements General (Mandatory requirements) has been amended and uploaded in the portal as **Appendix 111**.
- **EVALUATION CRITERIA 6.3.4 Qualified Key personnel as required under clause 3.20.2 (e) of the ITT with minimum 2 years' experience:** - Bidders are hereby notified that further to clause 67 of the Public Procurement and Asset disposal Act of 2015 which deals with the confidentiality of the procurement proceedings, the members of the opening and evaluation team declare, acknowledge and understand to maintain confidentiality of all information and knowledge that comes into possession in the course of carrying out an evaluation and shall not disclose such information without lawful authority. However, acknowledging the discomfiture of the requirement, an Employers Verification letter for the persons mentioned in clause **7.2.5.7 Project Implementation Capability, part 6.3.4** will be accepted.

3. DEADLINE FOR SUBMISSION OF TENDER.

The tender closing has been extended from **13th August, 2019** to **21st August, 2019** at 10.00 a.m. The procuring entity will open the bids On –line through our E- Procurement Web- Portal at 10.30 am on the same day at the Auditorium Stima Plaza.

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED



JANE NDINYA

Ag. SUPPLY CHAIN MANAGER PROCUREMENT