



# Kenya Power

---

Central Office - P.O. Box 30099 - 00100  
Telephone – 254 – 02 - 3201000  
Stima Plaza, Kolobot Road  
Nairobi, Kenya  
[www.kenyapower.co.ke](http://www.kenyapower.co.ke)

Our ref: KP1/9A.3/OT/24/17-18

13<sup>th</sup> June 2018

Your ref:

TO:

ALL PROSPECTIVE BIDDERS

**RE: ADDENDUM NO.2 TO THE TENDER NO. KP1/9A.3/OT/24/17-18 FOR SUPPLY OF ACCESSORIES FOR ABC CABLE**

---

Please refer to the above Tender.

Following an enquiry from a prospective bidder thereat, and, at our own initiative, we make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for supply of Accessories for ABC Cable

## **1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this addendum shall be deemed to have been incorporated in and shall be read and constructed as part of the PTD.

## **2. CLARIFICATIONS**

- (a) Please refer our message, clause 1, should we consider the KPLC Code nos. for the items 124201, 124203, 124206, 124208, 124211, 124215, 124238, 124243, 124263 for LV application only?

All the above is for LV ABC 3X120AAL/70Al cable application. The specification for 11kv ABC Cable accessories was provided.

- (b) The insulated bare messenger to consider for suspension and dead-end clamp is 70sq.mm as per KPLC response.

As per specification the messenger cross-section is 70mm<sup>2</sup> for LV ABC 3X120AAL/70Al

- (c) The cross section of ABC Cable for insulation piercing connector are yet to be confirmed.

As per clause 4.4.2.4 of the specification for, the sizes of the piercing connectors are indicated. For this tender the codes clarification is as below.

Material Code	Description	Description from specification	Quantity
124206	Connector Insulation Piercing For ABC	IPC ABC to ABC Tee connection	8,045
124211	Connector Insulation Piercing Al ABC	IPC for Bare(Al/Cu) to Main connections	10,056

(d) End cap: Should we consider for the complete set of AB Cable?

As per clause 4.5.1.5 the end caps dimensions/drawing are given. For this tender the size is 70-120mm<sup>2</sup>. The indicated numbers remain and are to be supplied as one unit not in pairs.

(e) We did not find any clarification regarding pigtail hook as per our request

Material Code	Description	Drawing from specification	
124201	Hook Pigtail Insulated Messenger ABC 240	Fig 12 under 4.6.2	
124238	Hook Dead End (Lv ABC) For Wooden Poles	Fig 3a under 4.3.3	
124243	Suspension Hook c/w Steel Band Set Concrete	Use figure 4a under clause 4.3.4	

### 3. MISSING SPECIFICATIONS

KPLC Specification NO. KPLC-3CB-TSP-02-004 & KPLC Specification NO. KP1-6C.1-13-TSP-05-026-1, which were missing in the portal have be uploaded.

(f) TENDER CLOSING DATE

The tender closing date has been extended from 13<sup>th</sup> June 2018 to 20<sup>th</sup> June 2018 at 10:00 a.m. All other terms and conditions remain as per the Principal Tender Document (PTD)

Yours faithfully,  
For: THE KENYA POWER & LIGHTING CO. LTD.



**DANIEL MUGA**  
**Ag. GENERAL MANAGER, SUPPLY CHAIN**