



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/03/20-21/JM/jmk

20th August 2020

TO: ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams;

RE: ADDENDUM (NO. 1) TO THE TENDER NO. KP1/9A.3/OT/03/20-21 FOR THE SUPPLY OF OVERHEAD FUSE CUTOUT 400A.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT.

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document (PTD).

2. AMENDMENTS

Provisions of the Principal Tender Document are hereby amended as follows;

a) Eligible Tenderers (Clause 3.3.1 of the Appendix to ITT);

Old: This is a national Tender open to Citizen Contractors only.

New: This Tender is now open to local contractors only.

b) Tender Validity:

Old: Notes on the Tender Security template indicates that the Tender validity as one hundred and twenty (120) days.

New: The Tender validity period displayed on the notes to the Tender Security template has been realigned with the Appendix to ITT to read one hundred and eighty (180) days.

c) Evaluation Criteria;

Old: Requirement for the bidders to submit a Manufacturer's Authorization was omitted in the evaluation criteria.

New: Clause 6.2.1.4 has been amended to make it a mandatory requirement. The Manufacturer's Authorization Template is herewith attached as provided for in the PTD.

3. CLARIFICATIONS

The following is the KPLC response to the sought clarifications;

Question: The highest voltage is 36KV. Then the total creepage distance should be $25 \times 36 = 900\text{mm}$. But it required 1200mm. Which one should we follow?

Answer: The creepage distance is for very heavy pollution level IV as per IEC 60815. 31mm/kV. (1200mm is appropriate)

4. TENDER CLOSING DATE

The tender closing date has been extended from **25th August,2020** to **8th September 2020 at 10.00am.**

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED



Dr. JOHN NGENO

GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS.

SECTION XII A - MANUFACTURER’S AUTHORIZATION FORM

(To Be Submitted On Manufacturer’s Letterhead)

To:

The Kenya Power & Lighting Company Limited,
Stima Plaza, Kolobot Road, Parklands,
P.O Box 30099 – 00100,
Nairobi, Kenya.

WHEREAS WE(*name of the manufacturer*) who are established and reputable manufacturers of
(*name and description of the goods*) having factories at(*full address and physical location of factory(ies) where goods to be supplied are manufactured*) do hereby confirm that
(*name and address of Supplier*) is authorized by us to transact in the goods required against your Tender (*insert reference number and name of the Tender*) in respect of the above goods manufactured by us.

DATED THIS..... DAY OF.....20.....

Signature of duly authorised person for and on behalf of the Manufacturer.

Name and Designation of duly authorised person signing on behalf of the Manufacturer

NOTES TO TENDERERS AND MANUFACTURERS

Only a competent person in the service of the Manufacturer should sign this letter of authority.