



*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000-Telegrams 'ELECTRIC'
Fax No. 254-02-310336
Stima Plaza, Kolobot Road*

Our Ref: KP1/9AA-2/PT/11/ICT/15-16

26th October, 2015

Dear Sir,

**ADDENDUM II: TO TENDER NO.KP1/9AA-2/PT/11/ICT/15-16 FOR
SUPPLY, INSTALLATION AND COMMISSIONING OF 220/48 VDC
BATTERY SYSTEMS.**

The following amendments are made to the specified provisions of the Tender document for the supply, installation and commissioning of 220/48 VDC battery systems.

RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT.

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

1. **A Clarification has been sought on tender currency on item No.5 on ITT**
Bidders are advised to read clause 3.13
2. **A Clarification has been sought on specification on IEC standard batteries.**

The response is, The IEC specification for the Lead Acid Batteries should be IEC 60896 and not IEC 60623. This tender is for red acid batteries and not nickel cadmium.

3. **A Clarification has been sought on price schedule on the maintenance laptop and batteries racks.**

The response is, the quantities should read 6 pieces and not 3 pieces. Every battery bank will be supplied with corresponding battery rack.

4. **A Clarification has been sought on section viii on special conditions on item no.6 -7.9.3 on inspection and testing of batteries chargers.**

The response is Kenya Power will cater the cost of travel and accommodation of staff travelling to manufacturer's factory. The bidder will facilitate the factory test to various sites where goods will be located.

5. **A Clarification has been sought on tender security**

Is amaco insurance company bid bond (tender security acceptable.)?

The response is, bidders are advised to read clause 3.18.2 (d) in principle tender document.

6. REMINDERS;

- The tender document should be in PDF and not zipped.
- Original bid bonds should be dropped in 3rd floor tender box on or before 10.30am 5th November 2015.

7. DEADLINE FOR SUBMISSION OF TENDER

- The tender has been extended so as to close on Thursday, 5th November, 2015 at 10.30am.
- All the other terms and conditions remain as per the tender document.

All the other terms and conditions remain as per the principal tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.

JOYCE OCHIENG.

Ag. GENERAL MANAGER , SUPPLY CHAIN