



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/20/18-19/li

01st July 2019

TO ALL TENDERERS

RE: ADDENDUM NO. 3 - TENDER NO. KP1/9A.3/OT/20/18-19 FOR SUPPLY OF AUTO LOAD TRANSFER SWITCH 11KV INDOOR & AUTO LOAD TRANSFER SWITCH 11KV OUTDOOR TYPE

Please refer to the above Tender. We make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Supply of Auto Load Transfer Switch 11kv Indoor & Auto Load Outdoor Transfer Switch 11kv Outdoor Type.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. TECHNICAL CLARIFICATION ON TENDER NO. KP1/9A.3/OT/20/18-19 FOR SUPPLY OF AUTO LOAD TRANSFER SWITCH 11KV INDOOR & AUTO LOAD TRANSFER SWITCH 11KV OUTDOOR TYPE

Reference is made to your emails, seeking clarification on the above Tender. The clarifications are made as below;

No.	Bidder Question	KPLC Clarification
1.	Clarify on page no. 9 of 16 of the specifications item no. 4.2.4.1 on the table which despite them being specifications for 11kv states that: i. The rated system highest voltage and frequency as 17.5Kv instead of 11kv as per the tender. ii. The rated lighting impulse withstand voltage, peak as 95kV instead of 75kv	 i. The company has adopted a highest voltage rating of 17.5kV for 11KV as indicated in the specification. ii. The 95KV rated lightning impulse withstand voltage, peak of 95kV has been chosen due to altitude correction
2.	We would like to know customer's requirement on the load side fault. In case the fault occurs at load side, the switch (load transfer switch) shall interrupt the fault by	The customer is to install circuit breakers for fault clearing.

	itself OR The switch shall be opened after clearing the fault by circuit breaker on the upstream line.	
--	---	--

3. TENDER CLOSING DATE

The Tender Closing Date still remains the same.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED



JANE NDINYA
AG. SUPPLY CHAIN MANAGER, PROCUREMENT