



# Kenya Power

Central Office - P.O. Box 30099 - 00100  
Telephone – 254 – 02 - 3201000  
Stima Plaza, Kolobot Road  
Nairobi, Kenya  
[www.kenyapower.co.ke](http://www.kenyapower.co.ke)

Our ref: KP1/9A.3/OT/23/17-18

29<sup>th</sup> May, 2018

TO:

ALL PROSPECTIVE BIDDERS

**RE: ADDENDUM NO. 1 TO THE TENDER NO. KP1/9A.3/OT/23/17-18 FOR SUPPLY OF AUTORECLOSERS**

Please refer to the above Tender.

We make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for the supply of Autoreclosers dated May 2018.

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

**2. AMENDMENT TO THE TECHNICAL REQUIREMENTS OF 11KV AUTORECLOSER:**

Bidders MUST provide for 11KV VTs for the 11Kv reclosers with the following technical parameters:-

- (i) The Ratio and Power rating of the power VT shall be 11kV/230 VAC, 500VA Limit output and a Minimum burden of 200 VA or other higher rating adequate to meet the auxiliary supply requirement for the Autorecloser control.
- (ii) The manufacturer shall specify the AC Power burden of the Autorecloser control.
- (iii) The VT will be delivered with the mounting frame. The secondary wiring of the VT shall be protected against short circuits with suitably rated fuses mounted on the VT secondary terminal box.

### 3. CLARIFICATIONS ARE MADE AS FOLLOWS:

Item No.	Item	Question/Comment by bidder	KPLC Response
1	Clause 3.17.2 Warranty	<i>The specific Warranties are as follows: For battery shall be 5 years; For autorecloser shall be 2 years; and for electronic cards shall be 3 years after the goods, or any portion thereof as the case may be, have been delivered to the final destination indicated in the contract.</i> Shall comprehensive warranty for the whole of the autorecloser system for five years be acceptable?	If the bidder wishes to provide a more superior warranty than provided for in the specification it shall be acceptable.
2	Clause 3.9, Appendix to Instructions to Tenderers.	<i>The Tenderer shall submit at least four (4) names with full contact as well as physical addresses of previous customers of similar goods together with a letter from each of them confirming completion of the contracts on schedule.</i>  Kindly clarify whether sales record requested in the above clause are for manufacturers or bidder in the case manufacturer is not the bidder.	The sales records shall be those of the manufacturer.
3	Clause 6.1.12, Financial statements	<i>The audited financial statements required must be those that are reported within eighteen (18) calendar months of the date of the tender document.</i> In the event that the financial statement for 2017 is not ready by the close of tender, kindly clarify whether 2016 and 2015 financial statements are acceptable.	Please provide as per the requirements of the tender document.

#### EXTENSION OF TENDER CLOSING DATE

The tender closing date has been extended from 4<sup>th</sup> June, 2018 to 12<sup>th</sup> June, 2018 at 10:00 a.m.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

For: THE KENYA POWER & LIGHTING CO. LTD.



DANIEL MUGA

SUPPLY CHAIN MANAGER, PROCUREMENT