



Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/13/18-19/JN/hm

10th July 2019

TO:

ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9A.3/OT/13/18-19 FOR SUPPLY OF RELAYS, CONTROL SWITCH, INDDICATORS & RESISTORS

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document

1. (hereinafter abbreviated as the PTD) for the Supply and delivery of relays, control switch, indicators & resistors

2. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

3. CLARIFICATION TENDER NO. KP1/9A.3/OT/13/18-19 FOR SUPPLY OF RELAYS, CONTROL SWITCH, INDDICATORS & RESISTORS

No	Clause No.	Clause description	Bidder Question	KPLC Clarification
1	4.4.2.4	The relay type offered must have been in service and given reliable service for a minimum period of 8 years, in at least two utilities, in at least three of the following regions/ continents: a) Europe b) North America c) Africa d) Asia	The relay offered should have been in service at least two utilities, in at least TWO of those continents, that's totally enough because developing countries are mostly in Asia and Africa	You are advised to provide as per the specification.
2	4.4.2.7	The distance Protection	Is the Distance Protection	You are advised that,

		Relay shall have four (4) analogue current input channels and Five (5) voltage input channels for connection of CTs & VTs secondary analogue signals as a minimum	Relay which has four (4) analogue current input channels and Four (4) voltage input channels also acceptable?	Distance Protection Relay which has four (4) analogue current input channels and Four (4) voltage input channels not acceptable .
3	4.4.3.25	Sensitive Earth Fault protection	Please confirm whether distance relay type II without this function is also acceptable or not	You are advised, that distance relay type II without this function is not acceptable.
4	N/A	N/A	Request to extend bid submission by one more month till August 12th .	The tender is closing on 26.07.2019
5	N/A	N/A	Kindly confirm if award shall be to the successful bidder per item	Yes the tender will be awarded to the successful bidder per item
6	N/A	N/A	Kindly confirm if we can bid part of items instead of all items.	Yes. Bidders can bid the items they feel comfortable with.
7	N/A	N/A	Can KPLC split the payment into several parts, especially offer suppliers some advance payments	No advance payment. Supplier will be paid after 30 days after delivery
8	N/A	N/A	For distance relay, type i and type ii should come from different suppliers or can be from the same supplier.	Can be from the different supplier
9	N/A	N/A	Throughout all the requirements in Section VII, bidding document doesn't mention any work related to commissioning. Please confirm there is no commissioning work which should be done by the supplier	There would be more no commissioning.

All other terms and conditions remain the same.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED

JANE NDINYA

Ag. SUPPLY CHAIN MANAGER, PROCUREMENT