



Kenya Power

Central Office - P.O. Box 30099 - 00100

Telephone – 254 – 02 - 3201000

Stima Plaza, Kolobot Road

Nairobi, Kenya

www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/06/19-20/JN/mwm

16th October, 2019

TO ALL TENDERERS

RE: ADDENDUM NO. 3 TO THE TENDER NO. KP1/9A.3/OT/06/19-20 FOR SUPPLY OF CABLES (FOR YOUTH, WOMEN AND PERSONS WITH DISABILITY).

Please refer to the above Tender.

We make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply of Cables (for youth, women and persons with disability).

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS

No.	QUERY	KPLC RESPONSE
1.	As per appendix for instructions to tenderers, evaluation will be done per item for the special groups (Youth, Women and people with disabilities) in that regards, please clarify if we shall submit for of tenders for each items	Submit form of tender for the total sum quoted for.
2.	According to the manufacturer of 66KV cable, the copper tape indicated on clause 4.2.5.3 is not applicable.	Adhere to the specification

3.	With respect to the Delivery Schedule of Goods Required, item No 11, KPLC Code 108618, Quantity is 4394, whilst the totals of the respective monthly deliveries are 7852, kindly clarify which is the correct quantity?	The correct quantity is 4,394 we shall issue a corrected delivery schedule during award.
4	As per KPLC specification Clause 4.2.7, Corrugated aluminium sheath shall be seamless. However, we can only offer seam-welded corrugated aluminium sheath instead. This is a deviation in their technical requirement and hence need approval of KPLC on the same.	Adhere to the specification
5	Please clarify and provide the Earth fault current rating & its duration (in sec) for metallic sheath, which is not provided in the specs.	31.5kA for 3 sec
6	What is the correct unit of measure for line no.5 CABLE 70SQMM LV 4/C AL PVC SWA PVC Online portal reads PC tender document reads Meter.	Meter

3. CLOSING DATE

The tender closing date changes from 17th October, 2019 10:00 am to 25th October, 2019 at 10:00 am and opened thereafter at 10:30 am.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED

JANE NDINYA

Ag. SUPPLY CHAIN MANAGER, PROCUREMENT