



# Kenya Power

Central Office - P.O. Box 30099 - 00100  
Telephone – 254 – 02 - 3201000  
Stima Plaza, Kolobot Road  
Nairobi, Kenya  
[www.kenyapower.co.ke](http://www.kenyapower.co.ke)

Our Ref: KP1/9A.3/OT/07/19-20/li

07<sup>th</sup> October 2019

**TO ALL TENDERERS**

**RE: ADDENDUM 4 - TENDER NO. KP1/9A.3/OT/07/19-20 FOR SUPPLY OF STREET LIGHTING MATERIALS**

Please refer to the above Tender. We make the following clarifications and amendments to the Principal Tender Document (hereinafter abbreviated as the PTD) for Supply of Street Lighting Materials.

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

**2. TECHNICAL CLARIFICATIONS ON TENDER NO. KP1/9A.3/OT/07/19-20 FOR SUPPLY OF STREET LIGHTING MATERIALS**

Reference is made to your emails, seeking clarification on the above Tender. The clarifications are made as below;

No.	Bidder Question	KPLC Clarification
1.	Kindly clarify on the Luminaires Sample to be provided on tendering should it be engraved or without	For the mandatory markings as per ROHS are required. KPLC markings will be for those who will be awarded.
2.	Kindly clarify on TENDER NO.KP1/9A.3/OT/07/19-20, ON ITEM WELDING SETS. <b>Page 4</b> of the tender document, is indicated <b>PETROL FUELED AND DIESEL ENGINE 10,12&amp;22 H.P.</b> Kindly clarify if you <b>PETROL FUELED OR DIESEL FUEL.</b>	It shall be petrol-fueled as per Clause 4.2.3f.
3.	Samples collection	Immediately after Evaluation, suppliers will be contacted to collect their samples strictly within a

		week at our Bulk Store (Isiolo Road, off Enterprise Road)
4.	Kindly clarify on "at least four (4) previous customers" Do you require the Manufacturer to provide details of his customers he supplied with similar goods? OR The bidder to provide OR BOTH the Manufacturer and Bidder to provide the customers details	The key point is similar products
5.	Can a bidder attach client reference letters for 76w lanterns past supply for an 80w bid and 90w lanterns past supply for the 100w lanterns?	Reference letters are for all street lighting lanterns; ranges are acceptable
6.	On page 20 (Table 4); Calculating luminaire efficacy values of lumens after losses per watt of all products except 100W is 123-124lm/w. The lumen output for 100w is 13400lm. Probably there is a typo and it should be 12400. Can you please check and confirm?	The calculation is correct. This is a typing error and highly regretted (The minimum shall be 12400 lm (+/- 5%) at steady state)
7.	Clause 4.3.1.4. - the product should have 3 colors. This is additional labor cost. Is there a way to make this easier such as body one color, bracket another and driver cover another color?	Comply to Technical specification
8.	The wattage of both the LED programmable and LED normal drivers.	The drivers shall be for 125-150W

### 3. TENDER CLOSING DATE

Kindly note the Tender Closing Date remains the same.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED**

**JANE NDINYA**

**AG. SUPPLY CHAIN MANAGER, PROCUREMENT**