



Kenya Power

*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3201889
Stima Plaza, Kolobot Road*

Our Ref:
M/s

16th September, 2019

Dear Sir,

ADDENDUM NO. 1 TO THE TENDER NO.KP1/9A.2/OT/012/ID/19-20 DESIGN SUPPLY AND RELOCATION OF TOWERS FOR KIPEVU 132KV LINES AT CHANGAMWE ROUND ABOUT

The following amendments are made to the specified provisions of the Tender document.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. CLARIFICATION MADE TO THE INTERESTED BIDDERS.

The following responses are made to clarifications sought on various issues on the tender document and shall be deemed to form the addendum:-

1. Consider 4 angle towers with the 5th tower as angle but provisional subject to the design during execution (may or may not be necessary)
2. Consider aircraft balls for 3 spans
3. Training – Consider local so long as facilitators be accredited trainers /designers/consultants
4. Existing towers consider dismantle, mark nodes, reference and transport in coded bundles to Rabai 220 KV substation
5. Consider tower testing complete with extensions

6. Lengths of leg extensions will be determined by design and based on the location shown on the ground
7. Drawings for the existing line are available for reference during actual design stage
8. Design shall be fitted within existing way leave thus consider no acquisitions and factor in working under live conditions
9. The bid is open to all public with eligibility details on the document conditions of contract
10. Ignore the BOQ embedded on the tender document and consider separate attached BOQ that is signed
11. Adopt technical data sheet on the document for Conductor,OPGW,fittings
12. Road level changes from the existing to new formation level are 6.5m on the lower side (Rabai side) and 11m on the kipevu side
13. Relocation of 33kv and 11kv lines to be done by client as enabling works and not in scope.

SECTION 1. INVITATION TO TENDER

The tender closing date has been extended from **18th September, 2019** to **27th September, 2019** at **10:00am** and opening on the same day at **10.30am**.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



JANE NDINYA
AG.MANAGER, SUPPLY CHAIN (PROCUREMENT)