



Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref. KP1/12A-2/PT/2/15/A40/WO/eo

29th May, 2015

Dear Sir/ Madam

CLARIFICATION - TENDER NO. KP1/12A-2/PT/2/15/A40 PROCUREMENT FOR DESIGN, SUPPLY, SUPPLY AND INSTALLATION OF EXTENSIONS OF LV SINGLE PHASE LINES AND SERVICE CABLES- LAST MILE CONNECTIVITY PROJECT (LMCP)

Bidders are required to note the Clarifications to the Tender as detailed in the Table attached.

| Item | Query by Bidders | KPLC Responses |
|------|---|--|
| 1 | Please clarify whether samples of <ul style="list-style-type: none">• PPM dropper cable• Concentric cable Should be submitted along with the tender document as indicated in the GTPs attached Pg. 10 and also in the Concentric cable datasheets | No, Sample of any Material in the Tender for Lots 1 to 10 shall be supplied together with the Tender. |
| 2. | What are to be considered as the major items for the works | The following items shall be considered as the major Items for contract for works Lo1 -10. <ol style="list-style-type: none">1. Poles (Both Wooden & Concrete)2. 50mm² Conductor3. Insulators4. 10mm² Concentric cable5. LV Stays As requested in the specification , note that for the major items , the following shall be submitted; <ol style="list-style-type: none">1. Manufacturers authorisation2. Type Test Certificates3. Guaranteed Technical Particulars |

| | | |
|----|--|--|
| | | <p>4. Reference Lists of supply from both inside and outside the country</p> <p>5. Quality Certification as required in the Specifications.</p> <p>6. Any other item as stipulated in the Technical Specification.</p> |
| 3. | <p>In your clarification Point 38 of Addendum No. 1, you mentioned "The Meter Box is coming with brackets for Mounting."</p> <p>Please clarify if meter box is required in Lot No. 11 or in which Lot do you need meter box with brackets and is there any specification for it?</p> | No, Meter Box is not required . |
| 4. | Are items under supply in Lot 11 (Prepayment Meters) Tax exempt | Yes, the project is tax exempt. The Employer shall seek for Tax Exemption, Import duty, VAT, Railway Development Levy and IDF. |
| 5. | <p>In your tender document, it is written: 4.2.1.3 The default communication between the MCU and the UIU shall be over cable for a distance of not less than 100 meters. However, the meter shall support PLC as an alternate communication mode for purposes of scalability to smart metering.</p> | <p>The meter is required to have provision for PLC communication module which will be purchased in future.</p> <p>No PLC module is required for the meters that have cable communication between MCU and UIU.</p> |
| 6. | <p>In the designs and construction, there will be cases where we shall definitely require to install HT inter poles. Kindly consider including the following in your BQs:</p> <p>1. 11 meters, 12 meters, wooden and concrete poles.</p> <p>2. 11 kv and 33kv wooden and concrete interpole fittings</p> | The Employer shall carry out such works. |

All other terms and conditions remains as per the tender document.

Yours faithfully,
For: KENYA POWER & LIGHTING COMPANY LIMITED.

ENG. JOSEPH K. GATHURU
ELECTRIFICATION PROJECT MANAGER