



## Kenya Power

---

*Central Office – P.O. Box 30099, Nairobi, Kenya  
Telephone – 254-020-3201000  
Fax No. 254-02-310336  
Stima Plaza, Kolobot Road  
Nairobi, Kenya*

*Tuesday, July 1, 2014*

M/s.

Dear Sir/Madam

**ADDENDUM TO TENDER NO KP1/9AA-2/PT/ITT/08/14 FOR THE SUPPLY, INSTALLATION, COMMISSIONING AND MAINTENANCE OF AUTOMATIC VOLTAGE STABILIZERS FOR THE KPLC DATA CENTRES AT THE ELECTRICITY HOUSES IN NAIROBI, MOMBASA, NAKURU, NYERI AND KISUMU**

The following amendments are made to the specified provisions of the Public Tender document for the supply, installation, commissioning and maintenance of automatic voltage stabilizers for the KPLC data Centres at the electricity houses in Nairobi, Mombasa, Nakuru, Nyeri and Kisumu

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

**2. ADDITIONAL PROJECT REQUIREMENTS**

Bidders are required to note the attached additional requirements of the project which will now form page 74 of the tender document.

**3. DEADLINE FOR SUBMISSION OF TENDER**

The tender closing date has been extended from Tuesday 1<sup>st</sup> July, 2014 so as to close on Tuesday, 15<sup>th</sup> July, 2014 at 10.00 a.m. The procuring entity will open the bids thereafter on the same day in the auditorium Stima Plaza.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.

A.N. GATUKUI

**SUPPLY CHAIN MANAGER ( PROCUREMENT).**

## ADDENDUM

The following are the additional Requirements for AVR's installation, for E Houses Data Centres in Nairobi, Mombasa, Nakuru, Nyeri and Kisumu

No.	ITEM DESCRIPTION	NAIROBI	MOMBASA	NAKURU	NYERI	KISUMU
1	CAPACITY (KVA) 3 phase 415 V Ac	200 KVA	100 KVA	100 KVA	100 KVA	100 KVA
2	Change over Switch (BYPASS)	150 Amps	150 Amps	150 Amps	150 Amps	150 Amps
3	Contactora	300 Amps	150 Amps	150 Amps	150 Amps	150 Amps
4	Isolator	150 Amps	150 Amps	150 Amps	150 Amps	150 Amps
5	Armored Power Cable 4 core	70 square mm, 20 meters	35 mm square 50 Metres	35 sq mm 150 m	35 sq mm – 65 m 16 sq mm – 55 m	35 sq mm 25meters
6	MCCB	400 Amps	250 Amps	250 Amps	250 Amps	250 Amps
7	12 Way Distribution Board Quality metallic type Comprising	2No. 3 pole 63-150 A  No. single pole 2No 32A, 2No 20A, 2 No 10A	2No. 3 pole 63-A  6 No. single pole 2No 32A, 2No 20A, 2No 10A	2No. 3 pole 63-A  6 No. single pole 2No 32A, 2No 20A, 2No 10A	2No. 3 pole 63-A  6 No. single pole 2No 32A, 2No 20A, 2No 10A	2No. 3 pole 63-A  Single pole 12 No.30 A 7 No 10A
8	Metallic Cable tray 50 x 150 mm	NA	NA	NA	2No. 3 metres pieces	NA
9	Automatic Voltage Switch	As per the contactor	As per the contactor	As per the contactor	As per the contactor	As per the contactor