



Kenya Power

Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/03/19-20jn/mn

4th November 2019

M/s -----

RE: ADDENDUM NO. 1 TENDER NO. KP1/9A.3/OT/03/19-20 SUPPLY OF SURGE ARRESTERS 33KV 10KA COMPOSITE, SURGE ARRESTERS 220KV 10KA AND FUSE CUT OUT LV OVERHEAD SERVICE 400A

The following clarifications and amendments are made to the Principal Tender Document (*hereinafter abbreviated as the PTD*) Supply of Surge Arresters 33kv 10A Composite, Surge Arresters 220kv 10A and Fuse Cut Out LV Overhead Service 400.October 2019

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS

The clarifications are made as below: -

No	Sec/ Part/ Sub-Sec	Clause	Clarification required for	Our Response
1	Section III - ITT	3.19 Validity of Tenders	The Tender Validity given in alphabetic letters is Ninety (90) days whereas the same was given in numeric letter as 180 days. Kindly confirm which one is correct.	The validity is 180 days
2	Section VII - GCC	7.20 Variation of Contract	Under clause 7.20, a) "the quantity variation for goods shall not exceed ten percent (15%) of the original contract quantity". in which the alphabetic and numeric percentages are different. Kindly confirm which one is correct.	shall not exceed fifteen percent (15%) of the original contract quantity

3	Section IV - Schedule of Requirements / Delivery Schedule	Notes	Under Notes no. 4, it is mentioned "All deliveries shall be made to KPLC stores or as otherwise indicated in accordance with the Delivery Schedule." But the Address of KPLC stores is not mentioned anywhere in the Tender Document. Kindly provide us the Delivery address of KPLC stores.	Delivery shall be to BULK STORES KPLC-ISIOLO RAOD INDUSTRIAL AREA-NRB
4	Section IV - Schedule of Requirements / Delivery Schedule	Part A - Brief Schedule of Details on Goods Required	In Item No. 1, KPLC code -117608, the description states "Surge Arresters 33kV 10A Composite". But in the Tender portal, the document attached with this tender is for Integrated Drop-out Surge Arrestors/Fuse (11kV & 33kV) Unit Specification. Kindly confirm that the required item is Surge Arresters 33kV 10kA Composite only for which the Tender Specification released on KPLC Tender portal recently titled "Current Specification of 33KV Surge Arresters".	Item Is Surge Arresters 33kV 10kA Composite.AS PER THE TECHNICAL SPECS ATTACHED
5	Section IV - Schedule of Requirements / Delivery Schedule	Part A - Brief Schedule of Details on Goods Required	In Item No. 1, KPLC code -117608, the description states "Surge Arresters 33kV 10A Composite" and Item No. 2, KPLC code -117650, the description states "Surge Arresters 220kV 10A". Please note that the Current Rating mentioned as 10A in above should be 10KA as per technical specification. Kindly confirm.	AS PER THE 220KV SPECIFICATION ATTACHED.

3. CHANGE OF CLOSING DATE

The closing date has been extended to **14th November, 2019 at 10.00 am.**

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED


JANE NDINYA

Ag SUPPLY CHAIN MANAGER, PROCUREMENT