



*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000-Telegrams 'ELECTRIC'- www.kenyapower.co.ke
Stima Plaza, Kolobot Road*

Our Ref: KP1/6E.3/PT/2/18/A65 - A66

30th May 2018

Dear Sir/ Madam:

**AMENDMENT NO.1 TO IPC NO: KP1/6E.3/PT/2/18/A65 and KP1/6E.3/PT/3/18/A66
PROCUREMENT OF SINGLE PHASE PRE-PAID METERS AND MINIATURE
CIRCUIT BREAKERS FOR THE LAST MILE CONNECTIVITY PROJECT**

The following amendments are made to the specific provisions of the issued bidding document for Procurement of Single Phase Pre-Paid Meters and Miniature Circuit Breakers for The Last Mile Connectivity Project (AFD/EU) and Procurement of Single Phase Pre-Paid Meters and Miniature Circuit Breakers for The Last Mile Connectivity Project (EIB)

RELATIONSHIP WITH THE PRINCIPAL BIDDING DOCUMENT

Save where expressly amended by the term of the addendum, the Principal Bidding Document shall continue to be in full force and effect. The provision of this addendum shall be deemed to have been incorporated in and shall be read and construed as part of the Principal Bidding Document

SECTION VII. SCHEDULE OF REQUIREMENTS NUMBER 3 – TECHNICAL SPECIFICATIONS

Appendix II – Miniature Circuit Breaker (MCB) Specifications

- a) Clause 4.2.1 has been amended from “The Miniature Circuit Breakers (MCB) shall be a Moulded Case Circuit Breaker and shall comply with the requirements of IEC 60947-2 and IEC 898” to “The Miniature Circuit Breakers (MCB) shall comply with the requirements of IEC 60947-2 and IEC 898.”
- b) Clause 4.2.18 has been amended from “The rated current for the MCB, which it will be able to carry continuously without tripping, shall be one (1) Amp or Seven (7) Amp (or as specified on the schedule of tender requirements).” to “The rated current for the MCB, which it will be able to carry continuously without tripping, shall be sixty three (63) Amps (or as specified on the schedule of tender requirements).”
- c) “Clause 4.2.35 has been amended from “The MCB shall have one protected pole” to “The MCB shall have both “Live” and “Neutral” poles protected, and both shall operate simultaneously”

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.

**JOHN NJEHIA
CONTRACT PROJECT MANAGER – AFD/EU/EIB**