



Kenya Power

Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/18/19-20/JM/hm

4th December 20199

TO:

ALL PROSPECTIVE BIDDERS

1. RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9A.3/OT/18/19-2019 FOR SUPPLY OF CIRCUIT BREAKERS, SWITCHBOARD PANELS AND 11KV METERING PANELS

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (hereinafter abbreviated as the PTD) for the Supply and delivery of circuit breakers, switchboard panels and 11KV metering panels.

2. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

3. CLARIFICATIONS

| No | QUERIES | CLARIFICATION |
|----|---|--|
| 1 | We haven't received technical specifications for 11kv metering breaker | Specification attached now. |
| 2 | The specifications for 11kv panel switchboard has several conflicting sections which require clarification or additional information a) The specifications provided only indicate 11kv panel switchboard with 4 panels (Incoming panel + Bus bar Panel + Bus Riser Panel + outgoing panel) while the schedule of | a) 13 panels switchboard required, rating 1600A. Composition: 2No.Incomers, 1No.bus coupler and 10No. |

| | | |
|---|---|--|
| | <p>requirements requires a quote for 11kv panel switchboard with 13 panels and 15 panels respectively.</p> <p>b) The specifications document only gives requirements for a panel with the rated normal current of 1600A, yet the schedule of requirements indicates that the switchboards should have a rated normal current of 1500A and 2700A for 11kv 13-panel switchboard and 11kv 15-panel switchboard respectively.</p> | <p>outgoing feeders</p> <p>b) Only 13panels required at the ratings in (a) above</p> |
| 3 | The sales records and reference letters sought, are they from the manufacturers clients or if the bidder is not the manufacturer then from the bidders clients | Manufacturer |
| 4 | Section 4.3.1 of the panel switchboard talks about spare sets required, from the statement, seems that something is missing. Also, clarify if the spares are per each switchboard or per the lot. | Spares for the 13 no. panel switchboard |

4. TENDER DOCUMENT

a) SECTION IV - SCHEDULE OF REQUIREMENTS / DELIVERY SCHEDULE & SECTION V - PRICE SCHEDULE FOR GOODS

LOT A

Item no. 3 quantity has been reviewed as below.

| Item No. | *KPLC Code | Brief Description | Unit of Measure | Quantity | Tick |
|----------|------------|--|-----------------|----------|------|
| 3 | 199330 | 11KV 13 panel switchboard 1500A (31.5KA) | Pc | 8 | |

LOT A

| 1 | 2 | 3 | 4 | 5 | 6 |
|------------|--|----------|-------------------|------------------------------|-------------------------------|
| *KPLC Code | Description | Quantity | Country of origin | Unit price DDP VAT Inclusive | Total price DDP VAT inclusive |
| 199330 | 11KV 13 panel switchboard 1500A (31.5KA) | 8 | | | |

b) APPENDIX TO INSTRUCTIONS TO TENDERERS

The tender security for item no. 3 has been reviewed as below.

| | | | | | |
|-----|---------------------------|---|--|------------------------|----------|
| 10. | 3.18.1 Tender Security | Tender security shall be as follows. | | | |
| | | LOT A | | | |
| | | code | Item description | Tender security amount | Currency |
| | | 199330 | 11KV 13 panel switchboard 1500A (31.5KA) | 1,907,113 | KSH |

5. CLOSING DATE

The closing date have been extended from 11th December 2019 to 8th January 2020

All other terms and condition remain the same.

Kindly adhere to the changes.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED



JANE MUIGAI

Ag. SUPPLY CHAIN MANAGER, PROCUREMENT

