



Kenya Power

The Kenya Power & Lighting Co. Ltd
Central Office – P.O. Box 30099 Nairobi, Kenya
STIMA PLAZA, KOLOBOT ROAD, PARKLANDS, NAIROBI.
Telephone – 24-20-3201000 – Fax No. 254 – 20 – 3514485

Our Ref: KP1/9A.3/OT/07/20-21
Your Ref:

Date: 25.09.2020

TO:

ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

RE: ADDENDUM (NO.4) TO THE TENDER NO. KP1/9A.3/OT/07/20-21 FOR (SUPPLY OF FUSES).

The following amendments are made to the specified provisions of the Tender document for the Supply of Fuses.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT.

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. TECHNICAL CLARIFICATIONS

	Clause Ref No.	Clause description/requirement/query	KPLC response
1	Request 1.	We notice that the appendix to instruction to tender clearly states that Manufacturer authorisation is not applicable to this tender, please clarify if this has an impact on bidders eligibility for those who are not manufacturers.	Manufacturer authorization is a mandatory requirement.
2	Request 2.	We notice that the rated currents for the 11kv and 33kv fuses has not been clarified. Please let us know what is the	The 11kV and 33kV expulsion fuse cut-out shall be able to carry fuses, Type K, up to 200A

	actual rated current for the fuses is it 100A or 200A.	in the fuse carrier as per IEC 60282-2. Fuse links are of different sizes as indicated in the tender document.
--	--	---

3. TENDER CLOSING

Tender closing date has been extended from 30th of September 2020 to **7th October 2020 at 10.00am.**

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED



DR. JOHN NGENO
GENERAL MANGER, SUPPLY CHAIN & LOGISTICS.