



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.

KP1/3CB/TSP/05/008

Issue No.

3

Revision
No.

0

Date of
Issue

2014-03-31

Page 1 of 14

TABLE OF CONTENTS

0.1 Circulation List

0.2 Amendment Record

FOREWORD

1. SCOPE
2. REFERENCES
3. TERMS AND DEFINITIONS
4. REQUIREMENTS
5. TESTS AND INSPECTION
6. MARKING, LABELLING AND PACKING
7. DOCUMENTATION

ANNEX A: SCHEDULE OF GUARANTEED TECHNICAL PARTICULARS FOR OFFERED CABLES

(to be filled and signed by the Manufacturer and submitted together with relevant copies of the Manufacturer's catalogues, brochures, drawings, technical data & calculations, sales records for past five years, four customer reference letters, details of manufacturing capacity, the manufacturer's experience, copies of complete type test reports and accreditation certificate to ISO/IEC 17025 for the testing laboratory for tender evaluation, all in English Language)

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.

KP1/3CB/TSP/05/008

Issue No.

3

Revision
No.

0

Date of
Issue

2014-03-31

Page 2 of 14

0.1 Circulation List

COPY NO.	COPY HOLDER
1	Research & Development Manager
2	Supply Chain Manager – Procurement
Electronic copy (pdf) on The Kenya Power & Lighting Company Server (currently: http://172.16.1.40/dms/browse.php?fFolderId=23)	

0.2 Amendment Record

Rev No.	Date (YYYY-MM-DD)	Description of Change	Prepared by (Name & Signature)	Approved by (Name & Signature)
Issue3 Rev 0	2014-03-31	Cancel and replaces Issue 2 Rev 0 dated 2012- 11-05	S. Kimitei 	G. Owuor

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.

KP1/3CB/TSP/05/008

Issue No.

3

Revision
No.

0

Date of
Issue

2014-03-31

Page 3 of 14

FOREWORD

This specification has been prepared by the Research and Development Department in collaboration with Distribution Division both of The Kenya Power and Lighting Company Limited (abbreviated as KPLC) and it lays down requirements for three core XLPE insulated aluminium cables, 11kV. It is intended for use by KPLC in purchasing the cables.

The bidder shall submit information which demonstrates satisfactory service experience of the manufacturer with products which fall within the scope of this specification.

1. SCOPE

This specification is for three core, stranded aluminium conductors, XLPE insulated, galvanized steel wire armoured, PVC outer sheathed power cables for operation at a.c. voltages of 6350 Volts to sheath, 11000 Volts between conductors and highest system voltage of 12000 Volts for use in KPLC distribution network operated at 50Hz.

The specification is for the following sizes of 11kV cables:

3 x 95 mm² AL/XLPE/SWA/PVC

3 x 185 mm² AL/XLPE/SWA/PVC

3 x 300 mm² AL/XLPE/SWA/PVC

The specification also covers inspection and test of the cables as well as schedule of Guaranteed Technical Particulars to be filled, signed by the manufacturer and submitted together with other required details for tender evaluation.

The specification stipulates the minimum requirements for three core XLPE insulated aluminium 11kV cables acceptable for use in the company and it shall be the responsibility of the supplier to ensure adequacy of the design, good workmanship, good engineering practice and adherence to standards, specifications and applicable regulations in the manufacture of the cables for The Kenya Power & Lighting Company Ltd.

The specification does not purport to include all the necessary provisions of a contract.

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.

KP1/3CB/TSP/05/008

Issue No.

3

Revision
No.

0

Date of
Issue

2014-03-31

Page 4 of 14

2. REFERENCES

The following standards contain provisions which, through reference in this text constitute provisions of this specification. Unless otherwise stated, the latest editions (including amendments) apply.

IEC 60502-2: Power Cables with extruded insulation and their accessories for rated voltages from 1kV ($U_m=1.2kV$) up to 30kV ($U_m=36kV$)- Part 2: Cables for rated voltages from 6kV ($U_m=7.2kV$) up to 30kV ($U_m=36kV$).

IEC 60228: Conductors of insulated cables.

BS 6622: Specification for cables with extruded cross-linked polyethylene or ethylene propylene rubber insulation for rated voltages from 3.8/6.6kV to 19/33kV.

3. TERMS AND DEFINITIONS

For the purpose of this specification the definitions given in IEC 60228 and IEC 60502-2 apply, together with the following:

AL: Aluminium

PVC: Polyvinyl chloride

SWA: Steel Wire armour

XLPE: Cross-linked polyethylene

4. REQUIREMENTS

4.1. SERVICE CONDITIONS

The cables shall be suitable for the following service conditions and applications:

4.1.1 Cable Application

- The cable shall be a distribution cable for use in outdoors installations and tropical conditions (temperature range of $-1^{\circ}C$ to $+40^{\circ}C$, humidity of upto 95%, saline conditions and altitudes of upto 2200m above sea level).
- The cable shall be suitable for laying in cable ducts and directly in the ground in switching stations, between stations and underground to overhead conversion.
- The cable shall also be suitable for laying on slopes.
- Permissible continuous loading operating temperature shall be $90^{\circ}C$.
- Permissible emergency loading temperature shall be $130^{\circ}C$ for at least 8 hours.

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.

KP1/3CB/TSP/05/008

Issue No.

3

Revision
No.

0

Date of
Issue

2014-03-31

Page 5 of 14

f) Permissible short circuit temperature shall be 250°C (for short-circuit duration of 5s as per IEC 60502).

4.1.2 The cables shall be connected to underground system operating at a nominal voltage of 11kV, 50Hz and maximum system voltage of 12kV and are solidly earthed at the transformer neutrals. The short circuit fault level shall be taken as 25kA 3s.

4.1.3 The cables shall have suitable anti-termite protection (details to be submitted by supplier to KPLC for approval before manufacture).

4.1.4 The cable shall have an oversheath with a fire performance that conforms to the requirements IEC standards.

4.1.5 The cable shall be designed for reliable service life of at least 30 years.

4.2. MATERIALS AND CONSTRUCTION

4.2.1. Design

4.2.1.1 The cable shall be designed and manufactured to BS 6622, IEC 60502-2 and the requirements of this specification.

4.2.1.2 All materials used shall be compatible and the cable shall have continuous operating temperature of 90°C and short circuit temperature of 250°C (5 seconds duration) as per IEC 60502-2.

4.2.2. Conductor

The cable shall be made from circular stranded compacted plain aluminium conductor that conforms to IEC 60228.

4.2.3. Conductor Screen

4.2.3.1 A conductor screen consisting of an extruded layer of cross-linkable semi-conducting compound shall be applied over the conductor and cover the surface of the conductor completely.

4.2.3.2 The extruded conductor screen shall be applied in the same operation as the insulation and be fully bonded to the insulation.

4.2.4. Insulation

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.

KP1/3CB/TSP/05/008

Issue No.

3

Revision
No.

0

Date of
Issue

2014-03-31

Page 6 of 14

4.2.4.1 The insulation shall be cross-linked polyethylene (XLPE) conforming to the requirements of IEC 60502-2.

4.2.4.2 The insulation shall be applied by extrusion and cross-linked to form a compact and homogeneous layer.

4.2.4.3 The colour of the insulation shall be such that it is easily distinguishable from the screening materials.

4.2.4.4 Individual cores shall be identified by coloured tape over the insulation and the colours shall be Red, Yellow and Blue.

4.2.5. Insulation Screen

4.2.5.1 There shall be an insulation screen consisting of a cross-linked extruded semi-conducting layer in combination with a metallic layer.

4.2.5.2 The extruded semi-conducting layer shall consist of a strippable semi-conducting compound capable of removal for jointing and terminating. It shall be applied in the same operation as the insulation, directly over the insulation and shall cover the surface of the core completely.

4.2.5.3 A metallic screen shall be applied around each core. The screen shall consist of helically applied overlapped copper tape. An energy absorbing bedding layer should be applied.

4.2.6. Laying-up

4.2.6.1 The cores shall be laid-up with a right hand direction of lay. Fillers of non-hygroscopic material shall be used to form a substantially compact and circular cable.

4.2.6.2 The metallic screens of the three cores shall be in contact with each other.

4.2.7. Armour

4.2.7.1 An extruded separation layer of black polyvinyl chloride (PVC) shall be applied between the laid-up cores and the armour.

4.2.7.2 The armour shall consist of a single layer of round galvanized steel wires applied helically with a left-hand lay.

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:
**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.	KP1/3CB/TSP/05/008
Issue No.	3
Revision No.	0
Date of Issue	2014-03-31
Page 7 of 14	

4.2.8. Oversheath

4.2.8.1 There shall be an extruded oversheath of black polyvinyl chloride (PVC) as per IEC 60502-2.

4.2.8.2 The cable shall be clearly and permanently embossed with the following information throughout the length of the oversheath.

- (i) 11000 VOLTS XLPE POWER AL CABLE PROPERTY OF KPLC
- (ii) Name of manufacturer
- (iii) Year of manufacture
- (iv) The number of cores, type and nominal area of conductors

Letters and figures shall be raised and consist of upright block characters. Minimum size of characters shall be not less than 15% of average overall cable diameter and the distance between one set of markings and the next shall not exceed 500mm.

An indelible marking shall also be given at every one meter interval to assist field personal in cutting required length.

4.3. STANDARD SIZES AND CHARACTERISTICS

The standard sizes for the XLPE cables shall be as follows:

Conductor nominal sectional area	mm ²	95	185	300
Voltage Designation		6.35/11 (12) kV		
Conductor shape		compact round stranded		
Thickness of insulation	mm	3.4	3.4	3.4
Thickness of separation layer	mm	1.5	1.7	1.9
Nominal armour wire diameter	mm	2.5	2.5	3.15
Thickness of oversheath, nominal	mm	2.8	3.2	3.6
Approximate overall diameter	mm	62.6	74.1	86.8
Power frequency test voltage, 5 min	kV	42	42	42
Maximum conductor resistance	Ω/km	0.32	0.164	0.100

Note: The Current Carrying Capacity of the cable in the ground and in air shall be stated by the manufacturer in the Guaranteed Technical Particulars as per Annex A.

4.4. QUALITY MANAGEMENT SYSTEM

4.4.1 The bidder shall submit a quality assurance plan (QAP) that will be used to ensure that the cable design, material, workmanship, tests, service capability, maintenance and documentation, will fulfil the requirements stated in the contract documents, standards,

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No. KP1/3CB/TSP/05/008

Issue No. 3

Revision No. 0

Date of Issue 2014-03-31

Page 8 of 14

specifications and regulations. The QAP shall be based on and include relevant parts to fulfil the requirements of ISO 9001:2008.

4.4.2 The Manufacturer's Declaration of Conformity to reference standards and copies of quality management certifications including copy of valid and relevant ISO 9001: 2008 certificate shall be submitted with the tender for evaluation.

4.4.3 The bidder shall indicate the delivery time of the cables, manufacturer's monthly & annual production capacity and experience in the production of the type and size of cable being offered. A detailed list & contact addresses (including e-mail) of the manufacturer's previous customers for similar rating of cables sold in the last five years as well as reference letters from at least four of the customers shall be submitted with the tender for evaluation.

5. TESTS AND INSPECTION

5.1 The cable shall be inspected and tested in accordance with the requirements of this specification, IEC 60228 and IEC 60502-2. It shall be the responsibility of the supplier to perform or to have performed all the required tests.

5.2 Copies of previous test certificates and test reports by a third party testing laboratory that is accredited to ISO/IEC 17025 shall be submitted with the offer for evaluation. A copy of the accreditation certificate to ISO/IEC 17025 for the testing laboratory shall also be submitted. Any translations of certificates and test reports into English language shall be signed and stamped by the Testing Laboratory that carried out the tests.

The type test reports shall include the following as per IEC 60502-2:

- a) Bending test, followed by a partial discharge test;
- b) Tan δ measurement;
- c) Heating cycle test, followed by a partial discharge test;
- d) Impulse test, followed by a voltage test;
- e) Voltage test for 4 h.

As per IEC 60502-2, when type tests have been successfully performed on a type of cable with a specific conductor cross-sectional area and rated voltage, type approval shall be accepted as valid for cables of the same type with other conductor cross-sectional areas and/or rated voltages, provided the following three conditions are all satisfied:

- a) The same materials, i.e. insulation and semi-conducting screens, and manufacturing process are used;

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



TITLE:
**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.	KP1/3CB/TSP/05/008
Issue No.	3
Revision No.	0
Date of Issue	2014-03-31
Page 9 of 14	

- b) The conductor cross-sectional area is not larger than that of the tested cable, with the exception that all cross-sectional areas up to and including 630 mm² are approved when the cross-sectional area of the previously tested cable is in the range of 95 mm² to 630 mm² inclusive;
- c) The rated voltage is not higher than that of the tested cable.

Approval shall be independent of the conductor material.

5.3 Routine and sample test reports for the cables to be supplied shall be submitted to KPLC for approval before shipment of the goods. KPLC Engineers will witness these tests at the factory before shipment and shall include the following:

- 5.3.1 The routine tests as per IEC 60502-2 and are as follows:
- a) Measurement of the electrical resistance of conductors;
 - b) Partial discharge test
 - c) Voltage test.

- 5.3.2 The sample tests as per IEC 60502-2 and are as follows:
- a) Conductor examination;
 - b) Check of dimensions;
 - c) Voltage test;
 - d) Hot set test for XLPE insulation and elastomeric sheaths.

In addition to Routine and Sample Tests as per IEC 60502-2, KPLC Engineers will verify the length on a randomly selected drum at the factory during Acceptance Testing.

5.4 Sampling (as per IEC 60502-2)

5.4.1 Samples shall be selected as per Table 1 and IEC 60502-2 for other lengths.

Table 1: Number of samples for sample tests

Cable length				Number of samples
Multicore cables		Single-core cables		
Above km	Up to and including km	Above km	Up to and including km	
2	10	4	20	1
10	20	20	40	2
20	30	40	60	3
30	40	60	80	4
40	50	80	100	5

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No. KP1/3CB/TSP/05/008

Issue No. 3

Revision No. 0

Date of Issue 2014-03-31

Page 10 of 14

5.4.2 If any sample fails in any of the tests, two further samples shall be taken from the same batch and subjected to the same test or tests in which the original sample failed. If both additional samples pass the tests, all the cables in the batch from which they were taken shall be regarded as complying with the requirements of this specification. If either of the additional samples fails, the batch from which they were taken shall be regarded as failing to comply.

5.5 During delivery of the cables, KPLC will inspect them and may perform or have performed any of the relevant tests in order to verify compliance with the specification. The supplier shall replace/rectify without charge to KPLC, cables which upon examination, test or use fail to meet any of the requirements in the specification.

6. MARKING, LABELLING AND PACKING

6.1 The finished cable shall be wound in one continuous length on metallic drum such as to prevent damage during transportation and handling. The drums shall be lagged with wood all round to prevent damage to the cable.

6.2 Each drum shall have one continuous length of 500m, 400m and 300m for cable sizes 3x95mm², 3x185mm² and 3x300mm² respectively. The actual length of cable shall not be less than the length indicated on the drum.

6.3 Both ends of the drum length of cable shall have been sealed to prevent the ingress of water during transportation, storage, handling and installation. The sealing shall enclose the oversheath completely and shall be by close fitting plastic caps. Both ends of the cable shall be secured to the drum to prevent mechanical damage.

6.4 The following information shall be marked legibly and in a permanent manner on the flange of the drum:

- a) The manufacturer's name;
- b) The type and rating of cable;
- c) The conductor cross-sectional area in mm²;
- d) The length of the cable, in metres;
- e) The year of manufacture;
- f) The gross mass and net mass, in kilogram;
- g) The instructions for handling and use (in English Language);
- h) The words "**PROPERTY OF THE KENYA POWER & LIGHTING CO.**"

Note: The cable shall have been marked in accordance with clause 4.4

Issued by: Head of Section, Technical Stds & Specs

Signed:

Date: 2014-03-31

Authorized by: Head of Department, R&D

Signed:

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.

KP1/3CB/TSP/05/008

Issue No.

3

Revision No.

0

Date of Issue

2014-03-31

Page 11 of 14

7. DOCUMENTATION

7.1 The bidder shall submit its tender complete with technical documents required by Annex A (Guaranteed Technical Particulars) for tender evaluation. The information shall include the following:

- a) Guaranteed Technical Particulars signed by the manufacturer;
- b) Copies of the Manufacturer's catalogues, brochures, drawings and technical data;
- c) Sales records for the last five years and at least four customer reference letters;
- d) Details of manufacturing capacity and the manufacturer's experience;
- e) Copies of required test reports by a third party testing laboratory accredited to ISO/IEC 17025;
- f) Copy of accreditation certificate to ISO/IEC 17025 for the third party testing laboratory;
- g) Manufacturer's warranty and guarantee;
- h) Manufacturers letter of authorization, ISO 9001:2008 certificate and other technical documents required in the tender.

7.2 The successful bidder (supplier) shall submit the following documents/details to The Kenya Power & Lighting Company for approval before manufacture:

- a) Guaranteed Technical Particulars,
- b) Design Drawings and construction details of the cable,
- c) Quality assurance plan (QAP) that will be used to ensure that the cable design, material, workmanship, tests, service capability, maintenance and documentation will fulfil the requirements stated in the contract documents, standards, specifications and regulations. The QAP shall be based on and include relevant parts to fulfil the requirements of ISO 9001:2008
- d) Test Program to be used after manufacture,
- e) Marking details and method to be used in marking the cables,
- f) Manufacturer's undertaking to ensure adequacy of the design,
- g) Packaging details (including packaging materials and length on drum).

The drawings to be submitted by the supplier to KPLC for approval before manufacture shall be in standard format clearly indication drawing number, parts list with material details & quantities, standard of manufacture, ratings, approval details and identify of the manufacturer (as per manufacturer's authorization submitted during tendering)

----- THIS SPACE LEFT BLANK -----

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.	KP1/3CB/TSP/05/008
Issue No.	3
Revision No.	0
Date of Issue	2014-03-31
Page 12 of 14	

ANNEX A: SCHEDULE OF GUARANTEED TECHNICAL PARTICULARS FOR OFFERED CABLES

(to be filled and signed by the Manufacturer and submitted together with relevant copies of the Manufacturer's catalogues, brochures, drawings, technical data & calculations, sales records, four customer reference letters, details of manufacturing capacity, the manufacturer's experience, copies of complete type test reports and accreditation certificate to ISO/IEC 17025 for the testing laboratory for tender evaluation, all in English Language)

Tender No..... Bidder's Name & Address

CLAUSE	Description	Bidder's offer
	Name and address of the Manufacturer	
	Country of manufacture	
	Manufacturer's Letter of Authorization	
	Model/Type Reference No. of the offered cable	
	Manufacturer's warranty and guarantee for the offered cable	
1	Scope: a) Design, manufacture, test, ship and deliver 3/C Aluminium XLPE insulated 11kV cables to KPLC store/site as per terms of contract b) Ensure adequacy of the design, good workmanship, good engineering practice and adherence to standards, specifications and applicable regulations in the manufacture of the cables for The Kenya Power & Lighting Co. Ltd	a) b)
2	Applicable standards	
3	Terms and definitions	
4.1.1	Cable Application	
4.1.2	System Conditions	
4.1.3	Anti-termite protection	
4.1.4	Fire Performance (indicate applicable IEC standards)	
4.1.5	Minimum Design Service Life	
4.2.1.1	Applicable Standards	
4.2.1.2	Continuous Operating Temperature Short Circuit Temperature (five seconds duration)	
4.2.2	Conductor	
4.2.3	Conductor Screen	
4.2.4.1	Insulation	
4.2.4.2	Insulation application	

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



Kenya Power

TITLE:

**SPECIFICATION FOR CABLE
11kV 3/C AL XLPE SWA PVC**

Doc. No.

KP1/3CB/TSP/05/008

Issue No.

3

Revision No.

0

Date of Issue

2014-03-31

Page 13 of 14

CLAUSE	Description	Bidder's offer	
4.2.4.3	Insulation Colour		
4.2.4.4	Individual Cores		
4.2.5	Insulation Screen (4.2.5.1 – 3)		
4.2.6	Laying-up		
4.2.7.1	Separation Layer		
4.2.7.2	Armour		
4.2.8.1	Oversheath		
4.2.8.2	Embossing on Oversheath		
4.3	Conductor nominal sectional area, mm ²		
	Voltage Designation		
	Conductor shape		
	Thickness of insulation, mm		
	Thickness of separation layer, mm		
	Armour wire diameter, mm		
	Thickness of oversheath, mm		
	Approximate overall diameter, mm		
	Power frequency withstand voltage of cable		
	Test Voltage (after installation), d.c., kV/5min		
	Maximum conductor resistance, Ω/km		
	Current carrying capacity	In air	
		In duct	
4.4.1	Quality Assurance Plan		
4.4.2	Manufacturer's Declaration of Conformity to Reference Standards		
	Copy of Manufacturer's ISO 9001:2008 Certificate		
4.4.3	Customer sales records and customer reference letters submitted to support the offer.		
5.1	Test Standard		
	Responsibility of carrying out tests		
5.2	Copies of Type Test Certificates & Type Test Reports to IEC 60502-2		
	a) Bending test, followed by a partial discharge test;		
	b) Tan δ measurement;		
	c) Heating cycle test, followed by a partial discharge test;		
	d) Impulse test, followed by a voltage test;		
	e) Voltage test for 4 h		
5.3	Tests to be witnessed by KPLC Engineers at factory before shipment		

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31



TITLE:
**SPECIFICATION FOR CABLE
 11kV 3/C AL XLPE SWA PVC**

Doc. No.	KP1/3CB/TSP/05/008
Issue No.	3
Revision No.	0
Date of Issue	2014-03-31
Page 14 of 14	

CLAUSE	Description	Bidder's offer
	1. Routine tests to IEC 60502-2	
	a) Measurement of the electrical resistance of conductors;	
	b) Partial discharge test	
	c) Voltage test.	
	2. Sample tests to IEC 60502-2	
	a) Conductor examination;	
	b) Check of dimensions;	
	c) Voltage test;	
	d) Hot set test for XLPE insulation and elastomeric sheaths	
	e) Verification of the length on a randomly selected drum	
5.4	Sampling	Sample size Acceptance criteria
5.5	Inspection & test of cable during delivery before acceptance to KPLC stores/site	
6.1	Cable Drums & Wooden Lagging	
6.2	Number of lengths on Drum Total Length of Cable on Drum	
6.3	Cable end plug sealing & securing on drum	
6.4	Marking on Cable Drum Flange	
7.1	Documents submitted with tender for evaluation	
7.2	Documents to be submitted by supplier to KPLC for approval before manufacture	
-	Manufacturing capacity of similar cable (Qty per month)	
-	Manufacturer's experience	
-	Statement of compliance to Tender Specifications	
-	Deviations from Tender Specifications	

.....
Manufacturer's Name, Signature, Stamp and Date

Issued by: Head of Section, Technical Stds & Specs

Authorized by: Head of Department, R&D

Signed:

Signed:

Date: 2014-03-31

Date: 2014-03-31