



Kenya Power

*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000-Telegrams 'ELECTRIC'
Fax No. 254-02-310336
Stima Plaza, Kolobot Road*

Our Ref: KP1/9AA-2/PT/04/ICT/15-16

24th August, 2015

Dear Sir,

**ADDENDUM II: TO TENDER NO.KP1/9AA-2/PT/04/ICT/15-16 FOR
MIGRATION OF COMMUNICATION TOWERS.**

The following amendments are made to the specified provisions of the Tender document for the proposed Migration of communication towers.

RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT.

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

1. **A Clarification has been sought on pages 36,37 and 38 number 2 which reads,** Erect (Rigging) 36m tower. In case of any member bent or needs replacement; it will be done at no extra cost.
The response is, this will only apply if the firm dismantling the tower wins otherwise any other firm no.
2. **A Clarification has been sought on communication building.**
The response is, as stated in the tender document on page 36 number 2. The communication building will only be at Bumala site and not Bomet or Nguni. The BOQ for the building is herein attached and the costs for the BOQ attached to be summarized and slotted in site 2 under communication building.
3. **A Clarification has been sought about some tower members/sections at Sokoke being welded.**
The response is, as seen during the site visit, no member/sections has been welded.
4. **A Clarification has been sought about the tower loading.**
The basic wind speed shall be read as 40m/s whereas the design wind speed shall be obtained from methods given in BS CP3; Chapter V part 2. The dead load a part from the tower self-weight will have micro-wave and point to point antennas of about 800 kgs,.
5. **REMINDERS:**
 - The tender document should be in PDF and not zipped.

- Original bid bonds should be dropped in 3rd floor tender box on or before 10.00am 27th August 2015.
- There will be cable trays from the tower to the new (Bumala) and existing communication building.
- Don't quote for transport of towers from the existing sites to the new sites. This will be done by KPLC.
- No manufacturer's authorization for this tender since it's not a new tower.

6. DEADLINE FOR SUBMISSION OF TENDER

- The tender has been extended so as to close on Thursday, 3rd September, 2015 at 10.30am.
- All the other terms and conditions remain as per the tender document.

All the other terms and conditions remain as per the principal tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.


BERNARD NGUGI.
SUPPLY CHAIN MANAGER