



Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

KENYA ELECTRICITY EXPANSION PROJECT (KEEP)
Pre-Bid Meeting and site Visits Contract A35 (World Bank Funded)

A. Meeting

	Date, Time and Venue	Agenda
Pre-Bid Meeting for Contract A35	Date: 18 th April, 2014 Time: 0900hrs to 1030hrs KPLC's Office Auditorium at Stima Plaza, Kolobot Road, Nairobi	1. Introductions 2. Bidders contact details 3. Queries from Bidders 4. Answers to some of the queries 5. A brief on site visits

1. The meeting started with introduction by KPLC team and registration of the bidders who had attended for purpose of getting their details for purpose of communication on matters related to this tender.
2. The bidders raised queries concerning the tender and they were answered as follows;
 - a. Is the tender tax exempt?
ANS: The tender is tax exempt BUT the bidders shall include 1.5% Railway Development Levy on imported goods only i.e. Schedule No.1
NB Railway Development Levy is not a tax but a levy and hence it shall form part of the cost.
 - b. The bidders raised question on whether the construction period would be increased in case of a bidder wins more than one lot.
ANS: The construction period shall be 15months irrespective of whether one wins one or more lots.
 - c. The bidders asked for inclusion of technical specifications for OPGW.
The specifications are in Technical Specifications, Section VI, technical schedules.
This specification for OPGW, applies for all lots (Lot, 2 &3).
 - d. The bidders asked for inclusion of technical specifications for 150mm² CASR Conductor.
ANS: Attached Below;

Specifications for 150 mm² ACSR Bare Conductor

Item	Particulars	Unit	Guaranteed Figure
1	Nominal Area of Aluminium	mm ²	
2	Approximate overall diameter	mm.	
3	Overall diameter of covered conductors.	mm	
4	Stranding No/mm Al.	No./mm	
5	Calculated maximum d.c. resistance at 20°C	□ /Km	
6	Calculated minimum breaking load	kN	
7	Approximate mass of conductor	Kg/Km	

- e. The bidders asked for clarification due to discrepancy between the quantities on the advert (Specific Procurement Notice) and the one in the Price schedule.
ANS: The discrepancy issue has been addressed in the clarifications attached with a revised B.O.Q attached
3. The program for the site visit was also read and copies of the itineraries for the three lots given to participants in attendance and the meeting came to a closure paving way to start of site visit the same day.



ENG. HEZEKIAH MWALWALA
DEPUTY MANAGER, PROJECTS