



Kenya Power

*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000-Telegrams 'ELECTRIC' - www.kenyapower.co.ke
Stima Plaza, Kolobot Road*

Our Ref: KP1/6E.2/PT/9/16/A55

28th October, 2016

M/s

Dear Sir/ Madam:

CLARIFICATION No 1: ON ICB No: KP1/6E.2/PT/9/16/A55 FOR PROCUREMENT OF INSPECTION AGENCY FOR WOODEN POLES ISSUED ON 22nd SEPTEMBER, 2016

1. CLARIFICATION TO BID DOCUMENT

The following responses are made to clarifications sought on various issues in the Bidding Documents for Procurement of Inspection Agency for Wooden Poles.

QUERY NO.	QUERY	RESPONSE
1	Page 25 of the document No 5.5 (c) 1. Moisture meter is required for testing poles before treatment. At what point will the pre-treatment test be done given that you have only shown the stores that the treated poles shall be delivered.	The pre-treatment tests (Moisture tests) will be done at the Manufacturer's premises, particularly on poles in the white.
2	Page 18 clause 20.1 bid submission. How many copies of the document are required?	Refer to Section II –Bid Data Sheet (BDS) Clauses 9.2 and 19.1.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.

**ENG. JOSEPH K. GATHURU
ELECTRIFICATION PROJECT MANAGER**