



Kenya Power

The Kenya Power & Lighting Co. Ltd

Central Office – P.O. Box 30099 Nairobi, Kenya

STIMA PLAZA, KOLOBOT ROAD, PARKLANDS, NAIROBI.

Telephone – 24-20-3201000 – Fax No. 254 – 20 – 3514485

Our Ref: KP1/9AA-2/PT/01/14-15

Date: 21st May, 2014

Your Ref:

TO: ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

RE: ADDENDUM NO. 1 TO THE TENDER NO. KP1/9AA-2/PT/01/14-15 FOR SUPPLY OF FABRICATED ITEMS.

Please refer to the above Tender.

Following the pre-bid meeting held in our Auditorium at Stima Plaza Nairobi on 19th May, 2014, upon enquiry from prospective bidders thereat, and, at our own initiative we make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Supply of Prefabricated items 2014.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. SECTION III – INSTRUCTIONS TO TENDERERS

- i) Clause 3.18.1 Tender Security-** Bidders are advised to note that the **tender security shall be 1%** of the total tendered value and **not Ksh. 500,000.00** as indicated in the document.
- ii) Clause 3.19 Validity of Tenders-** Tenders shall remain valid for **90 days** and not 120 days as indicated in the this clause. Bidders shall ensure that their bid bond is valid **30 days** beyond the validity of the tender.(**i.e 120 days**)
- iii) Clause 3.37.2 Award of Framework Contract-** The award criteria is hereby amended to read that: **‘Award shall be made to the lowest bidder per lot. If**

a bidder is lowest in all lots ,they shall be awarded the first two lots with the highest quantities and the last lot shall be re-tendered”.

iv) **Clause 3.43- Monopolies and Restrictive Trade Practices has been withdrawn from the tender document.**

3. SECTION IV – SCHEDULE OF REQUIREMENTS OF GOODS

The tender reference should be **KP1/9AA-2/PT/01/14-15-For Supply of steel Prefabricated items** instead of **KP1/9AA-2/PT/15/13-14** as is in the document.

4. SECTION VI – EVALUATION CRITERIA

i) **Clause 6.1.4.2- Item number (d)** which requires bidders to provide names with full contact as well as physical addresses of previous customers of similar goods and reference letters from at least four (4) previous customers has been withdrawn and will not be evaluated.

ii) **Clause 6.1.11 (g)** – has been amended to read-: A representative sample of 300mm for the Steel Channel Steady Bar and one piece of the Pole Cap are required.

Additional information on the pole cap shall be:

- i) The Pole Cap acts as a water barrier after nailing it on wooden pole tops.
- ii) The Pole Cap thickness shall be minimum 0.25mm.
- iii) The Pole Cap shall be UV light resistant.

(A sample for the Pole Cap can be viewed in our Bulk Store along Isiolo Road industrial area , a sample veiwing form is attached to this addendum.(Appendix i)

5. SECTION XXVIII – PART B-DETAILED TECHNICAL SPECIFICATIONS.

The Guaranteed Technical Particulars have been added to the technical specifications and attached to this addendum.(Appendix ii)

6. DEADLINE FOR SUBMISSION OF TENDER

The tender closing date has been extended to **Thursday, 12th June 2014 at 10.00 a.m** at **Stima Plaza Auditorium** The procuring entity will open the bids thereafter on the same day in the auditorium Stima Plaza.

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,


FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED



ENG. JOHN OMBUI


CHIEF MANAGER, SUPPLY CHAIN AND LOGISTICS

APPENDIX I

 <p>Kenya Power</p> <p>The Kenya Power & Lighting Co. Ltd</p>	<p>ISO 9001:2000 QMS SUPPLY CHAIN & LOGISTICS WORK INSTRUCTIONS</p> <p>SECTION: SUPPLY CHAIN</p>	Doc. No.	KP1/9AA-2/PT/01/14-15
		Issue No.	
		Revision No.	
		Date of Issue	
	<p>SUBJECT: SAMPLE VIEWING FORM (BULK STORE-ISIOLO ROAD)</p>		

			SIGNATURE	DATE & STAMP
NAME OF STORES OFFICIAL				
NAME OF SUPPLIER'S REPRESENTATIVE				
NO	CODE	ITEM DESCRIPTION	REMARKS	
1.	135903	Cover Pole Cap 12'' x 12''		

APPENDIX II

 Kenya Power	TITLE:	Doc. No.	KPLC/1/3CB/TSP/03/003
	SPECIFICATION FOR STEEL STRUCTURES FOR OVERHEAD LINES	Issue No.	1
		Revision No.	1
		Date of Issue	2014/05/20
		Page 1 of 1	



ANNEX A: *Guaranteed Technical Particulars (to be filled and signed by the Manufacturer and submitted together with copies of manufacturer's catalogues, brochures, drawings, technical data, sales records, customer reference letters, details of manufacturing capacity & experience and copies of type test certificates and type test reports for tender evaluation)*

TENDER NO......

	Description	Guaranteed Technical Particulars for Conductor offered
1	Name of the manufacturer and country of origin	
2	Name of Item	
3	Type Reference Number or Model Number	
4	Applicable Standards	
5	Material and grade	
6	Service Conditions	
7	Copy of accreditation certificate to ISO/IEC 17025	
8	Quality Management System(QAP)	
9	List of Type test reports submitted (indicate test report numbers, date, Testing Institution and contact addresses)	
10	Galvanizing(μm or g/mm^2)	
11	Manufacturer's Guarantee and Warranty	
12	List catalogues, brochures, technical data, drawings, customer sales records, customer reference letters, manufacturer's experience and capacity submitted to support the offer	
13	List Acceptance Tests to be witnessed by KPLC Engineers at the factory	
14	Manufacturing capacity & experience	
15	Statement of compliance to specification	

.....
Manufacturer's Name, Signature, Stamp and Date

-----THIS SPACE LEFT BLANK-----

Issued by: Head of Section PSR	Authorized by: Research & Development Manager
Signed: 	Signed: 
Date: 2014-05-20	Date: 2014-05-20