



# Kenya Power

---

*The Kenya Power & Lighting Co. Ltd*  
*Central Office – P.O. Box 30099 Nairobi, Kenya*  
**STIMA PLAZA, KOLOBOT ROAD, PARKLANDS, NAIROBI.**  
*Telephone – 24-20-3201000 – Fax No. 254 – 20 – 3514485*

**Our Ref:** KP1/9AA-3/PT/10/15-16  
**Your Ref:**

**Date:** 2<sup>nd</sup> September, 2015

TO:

ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

**RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9AA-3/PT/10/15-16 - SUPPLY OF INSULATORS FRAMEWORK CONTRACT OPEN TENDER**

Please refer to the above Tender.

Following the pre-bid meeting held in our Auditorium at Stima Plaza Nairobi on 13<sup>th</sup> August, 2015, upon enquiry from prospective bidders thereat, and, at our own initiative we make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Prefabricated 2015.

1. **RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. **SECTION VI- EVALUATION CRITERIA**

Part 1- Preliminary evaluation criteria under **Section 6.1.14** amended to read as follows:  
“Notwithstanding the above, considering any outstanding orders, the performance of the supplier and /or capacity of the tenderer.”

3. **SPECIFICATIONS FOR INSULATORS**

a. **Bidders Question:**

Item code- 184862- 66kV – Horizontal Post Insulator c/w clamp and bracket – Please confirm if the product is to be 1A, 1B, 2A or 2B on page 22 of the tender specification.

## **KPLC Response**

TYPE 2B – 66KV for line post insulator (Silicon Rubber) for use in concrete poles is recommended for the current tender.

### **b. Bidders Question**

Item No. 9- 132kV POST INSULATORS OF 132KV OF HORIZONTAL – The specification received is for a Station Post Insulator – which is correct post insulator or Horizontal insulator? Please provide specification if Horizontal insulator.

## **KPLC Response**

Specification attached in the tender document is for station post insulator. The tender requires line post insulator (Horizontal). The specification for the line post insulator (Horizontal) will be uploaded in the E- Procurement Web portal in KPLC Website on **Tuesday 25<sup>th</sup> August, 2015.**


## **4. EXTENSION OF TENDER CLOSING DATE**

Due to the challenges encountered by the bidders not being able to view the tender and specifications either missing or not clear, the tender closing date has been extended to close on the **10<sup>th</sup> September, 2015 at 10.00 a.m** from **27<sup>th</sup> August, 2015.**

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED**

  
**BERNARD NGUGI**  
**Ag. CHIEF MANAGER, SUPPLY CHAIN**



# Kenya Power

---

*The Kenya Power & Lighting Co. Ltd*  
*Central Office – P.O. Box 30099 Nairobi, Kenya*  
**STIMA PLAZA, KOLOBOT ROAD, PARKLANDS, NAIROBI.**  
*Telephone – 24-20-3201000 – Fax No. 254 – 20 – 3514485*

**Our Ref:** KP1/9AA-3/PT/10/15-16  
**Your Ref:**

**Date:** 2<sup>nd</sup> September, 2015

TO:

ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

**RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9AA-3/PT/11/15-16 - SUPPLY OF INSULATORS FRAMEWORK CONTRACT FOR YOUTH, WOMEN AND PERSONS WITH DISABILITIES**

Please refer to the above Tender.

Following the pre-bid meeting held in our Auditorium at Stima Plaza Nairobi on 13<sup>th</sup> August, 2015, upon enquiry from prospective bidders thereat, and, at our own initiative we make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Prefabricated 2015.

1. **RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. **SECTION VI- EVALUATION CRITERIA**

Part 1- Preliminary evaluation criteria under **Section 6.1.14** amended to read as follows:  
“Notwithstanding the above, considering any outstanding orders, the performance of the supplier and /or capacity of the tenderer.”

3. **SPECIFICATIONS FOR INSULATORS**

a. **Bidders Question:**

Item code- 184862- 66kV – Horizontal Post Insulator c/w clamp and bracket – Please confirm if the product is to be 1A, 1B, 2A or 2B on page 22 of the tender specification.

## **KPLC Response**

TYPE 2B – 66KV for line post insulator (Silicon Rubber) for use in concrete poles is recommended for the current tender.

### **b. Bidders Question**

Item No. 9- 132kV POST INSULATORS OF 132KV OF HORIZONTAL – The specification received is for a Station Post Insulator – which is correct post insulator or Horizontal insulator? Please provide specification if Horizontal insulator.

## **KPLC Response**

Specification attached in the tender document is for station post insulator. The tender requires line post insulator (Horizontal). The specification for the line post insulator (Horizontal) will be uploaded in the E- Procurement Web portal in KPLC Website on **Tuesday 25<sup>th</sup> August, 2015.**

### **4. INSTRCTIONS TO TENDERERS – TENDERER'S ELIGIBILITY AND QUALIFICATIONS**

It is not a requirement in this tender for:

- a) Bidders to submit names of the four (4) previous customers.
- b) Must provide letters from the previous customers, including successful completion of the contract.

### **5. EXTENSION OF TENDER CLOSING DATE**

Due to the challenges encountered by the bidders not being able to view the tender and specifications either missing or not clear, the tender closing date has been extended to close on the **10<sup>th</sup> September, 2015 at 10.00 a.m** from **27<sup>th</sup> August, 2015.**

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED**

  
**BERNARD NGUGI**  
**Ag. CHIEF MANAGER, SUPPLY CHAIN**



# Kenya Power

---

*The Kenya Power & Lighting Co. Ltd*  
*Central Office – P.O. Box 30099 Nairobi, Kenya*  
**STIMA PLAZA, KOLOBOT ROAD, PARKLANDS, NAIROBI.**  
*Telephone – 24-20-3201000 – Fax No. 254 – 20 – 3514485*

**Our Ref:** KP1/9AA-3/PT/09/15-16  
**Your Ref:**

**Date:** 2<sup>nd</sup> September, 2015

TO:

ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

**RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9AA-3/PT/09/15-16 - SUPPLY OF PG CLAMPS & LINETAPS FRAMEWORK CONTRACT FOR YOUTH , WOMEN AND PERSONS WITH DISABILITIES.**

Please refer to the above Tender.

Following the pre-bid meeting held in our Auditorium at Stima Plaza Nairobi on 13<sup>th</sup> August, 2015, upon enquiry from prospective bidders thereat, and, at our own initiative we make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Prefabricated 2015.

1. **RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. **CLAUSE 3.18.1 - TENDER SECURITY DECLARATION**

The tender security is not a requirement for this tender, instead a Tender Security Declaration Form shall be filled and uploaded in the portal. This shall form part of the mandatory preliminary evaluation criteria.

3. **SECTION VI- EVALUATION CRITERIA**

Part 1- Preliminary evaluation criteria under **Section 6.1.14** amended to read as follows:  
“Notwithstanding the above, considering any outstanding orders, the performance of the supplier and /or capacity of the tenderer.”

4. **INSTRCUTIONS TO TENDERERS – TENDERER’S ELIGIBILITY AND QUALIFICATIONS**

It is not a requirement in this tender for:

- a) Bidders to submit names of the four (4) previous customers.
- b) Must provide letters from the previous customers, including successful completion of the contract.

5. **EXTENSION OF TENDER CLOSING DATE**

Due to the challenges encountered by the bidders not being able to view the tender and specifications either missing or not clear, the tender closing date has been extended to close on the **15<sup>th</sup> September, 2015 at 10.00 a.m** from **27<sup>th</sup> August, 2015**.

The procuring entity will open the bids On –line through our E- Procurement Web Portal at 10.30am on the same day at the **auditorium Stima Plaza**.

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED**

  
**BERNARD NGUGI**  
**Ag. CHIEF MANAGER, SUPPLY CHAIN**



# Kenya Power

---

*The Kenya Power & Lighting Co. Ltd*  
*Central Office – P.O. Box 30099 Nairobi, Kenya*  
**STIMA PLAZA, KOLOBOT ROAD, PARKLANDS, NAIROBI.**  
*Telephone – 24-20-3201000 – Fax No. 254 – 20 – 3514485*

**Our Ref:** KP1/9AA-3/PT/12/15-16  
**Your Ref:**

**Date:** 2<sup>nd</sup> September, 2015

TO:

ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

**RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9AA-3/PT/12/15-16 - SUPPLY OF PREFABRICATED ITEMS FRAMEWORK CONTRACT FOR YOUTH , WOMEN AND PERSONS WITH DISABILITIES.**

Please refer to the above Tender.

Following the pre-bid meeting held in our Auditorium at Stima Plaza Nairobi on 13<sup>th</sup> August, 2015, upon enquiry from prospective bidders thereat, and, at our own initiative we make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Prefabricated 2015.

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

**2. INSTRCUTIONS TO TENDERERS – TENDERER'S ELIGIBILITY AND QUALIFICATIONS**

It is not a requirement in this tender for:

- a) Bidders to submit names of the four (4) previous customers.
- b) Must provide letters from the previous customers, including successful completion of the contract.

**3. SECTION VI- EVALUATION CRITERIA**

Part 1- Preliminary evaluation criteria under **Section 6.1.14** amended to read as follows:  
“Notwithstanding the above, considering any outstanding orders, the performance of the supplier and /or capacity of the tenderer.”

4. **EXTENSION OF TENDER CLOSING DATE**

Due to the challenges encountered by the bidders not being able to view the tender and specifications either missing or not clear, the tender closing date has been extended to close on the **15<sup>th</sup> September, 2015 at 10.00 a.m** from **27<sup>th</sup> August, 2015**.

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED**

  
**BERNARD NGUGI**  
**Ag. CHIEF MANAGER, SUPPLY CHAIN**





# Kenya Power

---

*The Kenya Power & Lighting Co. Ltd*  
Central Office – P.O. Box 30099 Nairobi, Kenya  
**STIMA PLAZA, KOLOBOT ROAD, PARKLANDS, NAIROBI.**  
Telephone – 24-20-3201000 – Fax No. 254 – 20 – 3514485

**Our Ref:** KP1/9AA-3/PT/03/15-16

**Date:** 2<sup>nd</sup> September, 2015

**Your Ref:**

**TO:**

ALL PROSPECTIVE BIDDERS

Dear Sirs/ Madams

**RE: ADDENDUM NO. 2. TO THE TENDER NO. KP1/9AA-3/PT/03/15-16 - SUPPLY OF PREFABRICATED ITEMS LOCAL TENDER.**

Please refer to the above Tender.

Following the pre-bid meeting held in our Auditorium at Stima Plaza Nairobi on 13<sup>th</sup> August, 2015, upon enquiry from prospective bidders thereat, and, at our own initiative we make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Prefabricated 2015.

1. **RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. **SECTION VI- EVALUATION CRITERIA**

Part 1- Preliminary evaluation criteria under **Section 6.1.14** amended to read as follows: "Notwithstanding the above, considering any outstanding orders, the performance of the supplier and /or capacity of the tenderer."

3. **CHANGES IN DESCRIPTION AS PER THE REVISED SPECIFICATIONS.**

Following the revision of the specifications for steel structures uploaded in the Web-portal, items nos 8,10,11,12,13 and 14 on Page No 34 of the tender document have a changes in description as follows:-

1. 182911 – 11KV Cross Arm(L1625 mm x 70mm x70mm x 9.5mm structural steel angle, galvanized)

2. 182914 - 11KV Terminal Cross Arm (L1620mm x 125mm x 76mm x 9.5mm structural steel angle, galvanized)
3. 196921 - Steady Cross Member ( U2290mm x 100mm x 50mm x 6mm structural steel galvanized)
4. 186922 – Steady Cross Member (U2290mm x 125mm x 64mm x 9.5mm structural steel galvanized)
5. 186925 - Fuse/ Solid Link Cross Member Channel (U2290 x 100 x 50 x 6mm structural steel, galvanized)
6. 186926 - Fuse/ Solid Link Cross Member Channel (U2290 x 125 x 64 x 6mm structural steel, galvanized).

4. **SPECIFICATIONS FOR UNIVERSAL CLAMPS**

The Specifications for Universal clamps uploaded in the portal, and all sizes are in clause 4.4 on dimensions.

5. **DEADLINE FOR SUBMISSION OF TENDER.**

The tender closing date remains **15<sup>th</sup> September, 2015 at 10.00 a.m.**

The procuring entity will open the bids On –line through our E- Procurement Web-Portal at 10.30am on the same day at the **auditorium Stima Plaza.**

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED**

  
**BERNARD NGUGI**  
**Ag. CHIEF MANAGER, SUPPLY CHAIN**