



*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000-Telegrams 'ELECTRIC'
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road*

Our Ref. KP1/12A-2/PT/1/13 MK/skm

KP1/12A-2/PT/1/13

21st January, 2014

M/s

Dear Sir/ Madam

ADDENDUM (1) TO TENDER NO. KP1/12A-2/PT/1/13 FOR THE SUPPLY, INSTALLATION AND MAINTENANCE OF FIRE SUPPRESSION SYSTEM AND FIRE PROTECTION EQUIPMENT FOR SCADA EQUIPMENT AT CONTROL CENTRES.

The following amendments are made to the specified provisions of the Tender document for the supply, installation and maintenance of Fire Suppression System and Fire Protection Equipment for SCADA equipment at Control Centres dated 3rd December, 2013.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT.

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. AREAS TO COVER IN THE EQUIPMENT ROOM FOR ALL THE LOCATIONS.

The raised floors for the equipment rooms shall be included in the scope to be protected by the fire suppression system.

The Dimensions of the National Control rooms in the scope are:

LOCATION	ROOM	DIMENSIONS(CM)	HEIGHT(CM)
NATIONAL CONTROL CENTRE	SERVER ROOM	720×300	270
	TELECOMMUNICATION ROOM	730×580	341
	UPS ROOM	600×406	341
	BATTERY ROOM	600×249	341

3. KEY SIGNALS THAT ARE REQUIRED FROM THE FIRE SUPPRESSION SYSTEM.

The following key signals are to be provided by use of auxiliary voltage free contacts:

- i. Loss of main AC power.
- ii. System Trouble.

4. ADDITIONAL REQUIREMENTS

Provide information if offered system can be centrally monitored and any additional hardware as an option.

5. DEADLINE FOR SUBMISSION OF TENDER

The closing date for submission and opening has been extended as follows;

NO.	TENDER NO	DESCRIPTION OF GOODS	ORIGINAL CLOSING DATE	NEW TENDER CLOSING DATE
1.	KP1/12A-2/PT/1/13	Supply, Installation and Maintenance of Fire Suppression System and Fire Protection Equipment for Scada Equipment at Control Centers.	24.01.2014	07.02.2014

The time for submission and opening remains the same as indicated in the Tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.


BERNARD NGUGI
AG.CHIEF MANAGER, SUPPLIES, STORES AND TRANSPORT