



The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000-Telegrams 'ELECTRIC'- www.kenyapower.co.ke
Stima Plaza, Kolobot Road

Our Ref: KP1/6E-2/PT/5/16/A51

28th December, 2016

M/s

Dear Sir/ Madam:

CLARIFICATION No.4 ON ICB No: KP1/6E-2/PT/5/16/A51 FOR PROCUREMENT OF PREPAID METERS AND METER ACCESSORIES ISSUED ON 21ST OCTOBER, 2016

CLARIFICATION TO BID DOCUMENT

The following responses are made to clarifications sought on various issues in the Bidding Documents for Procurement of Prepaid Meters and Meter Accessories.

Item No.	Clarification	Response
1	<p>With regard to Tender No-KP1/6-E/PT/5/16/A51, Section 4.2.1.24. The PLC shall comply IEEE1901.2 using OFDM at modulation frequency band up to 500KHz(G3/PRIME) ,we have two questions hereunder needed your clarification:</p> <p>1. According to G3/PRIME, Association requirement, G3 complies with ITU-T G.9903 and PRIME complies with ITU-T G.9904, instead of IEEE1901.2. Please confirm if ITU-T G.9903 and ITU-T G.9904 standards are also acceptable?</p> <p>2. For standard of IEEE1901.2, can the frequency band either be FCC band or CENELEC-A band, not limited to FCC Band?</p>	<p>1. Please comply with the requirements of IEEE1901.2</p> <p>2. The Frequency band is not limited to FCC band or CENELEC - A</p>
2	<p>Regarding the clarification ref: KP1/6E-2/PT/5/16/A51 dated on 21st Dec 2016 article 9 as below:</p> <p>As the original contract shall be kept in the company and also some of the purchasers do not have stamp only with signature.</p> <p>Meanwhile according to the requirement of tender document section III Evaluation and Qualification Criteria Page 37 as below: <i>The Bidder shall be</i></p>	<p>Yes, it is acceptable.</p>

Item No.	Clarification	Response
	<p><i>required to provide the following information in the format shown below in order to determine the available capacity. This information shall be certified by an auditor that certified the financial statements of the Bidder. The Purchaser reserves the right to verify this information before contract award. Details provided in this form must reflect the actual supply capacity of the bidder. Any inconsistency in the capacity declaration may lead to rejection of the bids. The Contracts received from January 1, 2011 till date of invitation for bid shall be included in the table below to demonstrate that bidder meet at least quantities indicated for each lot in the table below in any one of the last five years.</i></p> <p>So we want to clarify that the copy of the contract stamped by the audit company but without the purchaser's stamp (but with the purchaser signature) as per the original tender requirement is acceptable?</p>	

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



ENG. JOSEPH K. GATHURU
ELECTRIFICATION PROJECT MANAGER