



Kenya Power

Central Office - P.O. Box 30099 – 00100,
Telephone +254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/33/19-20/JM/aoo

29th May, 2020

TO ALL TENDERERS

RE: ADDENDUM NO. 3 TO THE TENDER NO. KP1/9A.3/OT/33/19-20 FOR SUPPLY OF MATERIALS FOR REPAIR OF EMBAKASI-CITY CENTRE 220KV LINE

Please refer to the above Tender.

We make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply of Materials for Repair of Embakasi-City Centre 220kv Line.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS ON ISSUES RAISED BY PROSPECTIVE BIDDER(S):

Following request for clarifications on some issues by a prospective bidder, the clarifications are hereby made as follows:

No	KPLC Requirement	Bidder's Query	KPLC's Response
1	Clause 4.1.2.1: Cable Application The cable for which the 220kV terminations and Joints are to be installed has characteristics defined in the specifications KP1/6C/4/1/TSP/05/010-3: 220KV Single Core XLPE Insulated Copper Cables-Specification	Please provide referenced specification	Current Version is as attached. This is provided for information only and not for bidding for the Cable.
2	D.1 (a) During the FAT, the manufacturer shall	Please confirm whether travel &	<ul style="list-style-type: none">• KPLC meets the cost of travel and

	conduct complete training for the 220kV Terminations and Joints for two KPLC engineers/Technicians.	accommodation costs for FAT/Training will be borne by tenderer or Kenya Power for the duration of the exercise.	accommodation for the Engineers witnessing the FAT and attending training. The cost of training itself will be borne by the supplier as required in clause C.3 and D.1. <ul style="list-style-type: none"> • Clause D.1 (c)- The bidder is required to provide a training proposal with duration and cost for KPLC to consider in case a separate team is to be send to the factory for training.
3	Clause 4.8.1.6: The design shall comply with newest editions of IEC 62271-2-9 and other applicable standards and possibly adjusted to the various specific needs of the project.	Please confirm design of the link boxes whether to include Sheath Voltage Limiters or without and rating for the same.	The Link Boxes shall be provided with Sheath Voltage Limiters whose rating shall be 6.3kV.
4	Clause D.2 Local Training	Please confirm who will be responsible to provide the 220kv Cable to be used for the installation training?	The manufacturer will provide the 220kv Cable and conduct training both in their factory and at KPLC in Nairobi, Kenya.

3. EXTENSION OF TENDER CLOSING DATE:

The Tender Closing Date has been extended from to 2nd June 2020 to 9th June 2020.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED

DR. JOHN NGENO
GENERAL MANAGER, SUPPLY CHAIN