

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/24/19-20/JM/dn

10th December, 2019

TO ALL TENDERERS

RE: ADDENDUM NO. 1 TO THE TENDER NO. KP1/9A.3/OT/24/19-20 FOR SUPPLY OF CABLE 400MM² S/C 66KV CU XLPE CAS PVC DISABILITY).

Please refer to the above Tender.

We make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply of Cables (for youth, women and persons with disability).

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.


2. CLARIFICATIONS

NO.	QUERY	KPLC RESPONSE
1	As per KPLC specification Clause 4.2.7, Corrugated aluminium sheath shall be seamless. However, we can only offer seam-welded corrugated aluminium sheath instead. This is a deviation in their technical requirement and hence need approval of KPLC on the same.	Adhere to the specification
2	Please clarify and provide the Earth fault current rating & its duration (in sec) for metallic sheath, which is not provided in the specs.	31.5kA for 3 sec

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED


JANE MUIGAI
FOR AG. GENERAL MANAGER SUPPLY CHAIN