



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9AA-3/PT/09/14-15

Date 9th June 2014

M/s

.....

Dear Sirs,

ADDENDUM NO. 1 TO THE TENDER NO. KP1/9AA-3/PT/09/14-15 FOR SUPPLY OF AUTORECLOSERS 33KV

The following amendments are made to the specified provisions of the Tender document for Supply of Autorecloser 33KV dated May 2014.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. RESPONSES TO QUERIES ARE AS FOLLOWS

- a) **Question:** Based on Construction are bidders meant to provide the Surge Arresters or include the Mounting Provisions?

Answer:

Surge arrestor mounting shall be provided as per clause 4.2.3 of specifications

- b) **Question:** The Bill of Quantity (BQ) does not include the four (4) Laptops. Will the laptops be supplied every year over the three year contract period and will the installation, Commissioning & Training be conducted every year?

Answer

The laptops shall be provided only once.

c) **Question:** What does the abbreviation VWVE mean?

Answer

VWVE is just a brand name for 33KV Autoreclosers and is hereby deleted from the description of the item that shall now read Autorecloser 33KV

d) **Question:** The specifications (clause 4.2.2) read “the Auto Recloser shall have Oil or Air/Solid for electrical insulation and employ vacuum interrupters”. Is SF6 dielectric also acceptable?

Answer

KPLC Specifications clause 4.2.2 require the auto recloser shall have Oil or Air/Solid for electrical insulation and employ vacuum interrupters.

3. DEADLINE FOR SUBMISSION OF TENDER

The closing date for the tender is **Wednesday 9th July 2014 at 10.00 a.m.** Tenders shall be opened immediately thereafter in the Auditorium located at Stima Plaza, Kolobot Road, Nairobi.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



BERNARD NGUGI

Ag. CHIEF MANAGER, SUPPLY CHAIN & LOGISTICS.