



# Kenya Power

*The Kenya Power & Lighting Co. Ltd.  
Central Office – P. O. Box 30099, Nairobi, Kenya  
Telephone – 254-02-3201000  
Fax No. 254-02-3201889  
Stima Plaza, Kolobot Road*

*Our Ref: kp1/9AA.2/OT/20/NM/17-18/bm  
8<sup>th</sup> November, 2017*

M/s .....

Dear Sir,

**ADDENDUM & EXTENSION OF TENDER CLOSING DATE TENDER NO. KP1/9A.2/OT/20/NM/17-18 FOR PROCUREMENT AND INSTALLATION OF FIRE DETECTION AND SUPPRESSION TECHNOLOGY AT KEY PRIMARY SUBSTATIONS WITHIN THE EXISTING NETWORK**

The following amendments are made to the specified provisions of the Tender document.

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

**2. CLARIFICATIONS MADE TO THE INTERESTED BIDDERS.**

Following the Pre- Bid meeting held on **8<sup>th</sup> November 2017** there was need to amend previous bill of quantities accommodate further additional as per attached appendices I

**3. DEADLINE FOR SUBMISSION OF TENDER**

The tender closing date shall remain **29/11/2017 at 10.00am** Tender shall be opened thereafter at **Stima Plaza Auditorium.**

All the other terms and conditions remain as per the tender document.

Yours faithfully,

**For: KENYA POWER & LIGHTING COMPANY LIMITED.**

  
**BERNARD NGUGI**  
**GENERAL MANAGER SUPPLY CHAIN**

Enclosed

**APPENDICES I****FIRE TRACE, DETECTION AND SUPPRESSION SYSTEM****1. QUANTITIES**

	SUB-STATION	11KV PANELS	PROTECTION AND TAP CHANGER CONTROL PANELS	BATTERY CHARGERS	415V AC DIST. BOARD	TOTAL
1	PARKLANDS	21	5	1	1	28
2	NBI WEST	17	6	2	1	26
3	NEW INDUSTRIAL	17	4	2	0	23
4	ATHI RIVER	15	6	3	1	25
5	RUAI	14	4	2	1	21

**2. DESIGN**

Include design as separate cost element on the schedule of prices

**3. FAT**

The contractor should factor the cost of FAT for 3 KPLC engineers to witness a live demo on the system at the manufacturer's factory. KPLC will meet the cost of Air ticket and accommodation for the its staff. The contractor shall meet the cost of local transport. This also should be included as a separate cost item

**4. SUB-STATION LAY-OUT DRAWINGS**

The s/station layout drawings shall be availed during the site visits

**5. SCADA INTEGRATION**

The fire alarm control panel shall have enough contacts for integration of all alarms to the scada system

**6. METHODOLOGY**

- The contractor shall clearly demonstrate how he is going to lay the fire trace tube including adequate protection against accidental damage. Drawings shall be forwarded to KPLC for approval before commencement of works.
- The contractor shall also provide a detailed schedule of works including the number of shutdowns, time of each shutdown required for each s/station

**7. SCHEDULE OF SITE VISITS**

	SUB-STATION	DATE OF VISIT	CONTACT PERSON	REMARKS
1	PARKLANDS, NAIROBI WEST, AND NEW INDUSTRIAL S/STATIONS	Wednesday 15 <sup>th</sup> Nov 2017	John Kanampiu (0717721198) Zacheus Oluoch (0723937089)	Start at parklands at 9.00 am
2	RUAI AND ATHI RIVER S/STATIONS	Thursday 16 <sup>th</sup> Nov 2017	John Kanampiu (0717721198) Zacheus Oluoch (0723937089) Mark Kimathi (0720780763)	Meet at Ruai s/station at 10.00 am