



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/06/19-20/mwm

08th October, 2019

TO ALL TENDERERS

RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9A.3/OT/06/19-20 FOR SUPPLY OF CABLES (FOR YOUTH, WOMEN AND PERSONS WITH DISABILITY).

Please refer to the above Tender.

We make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply of Cables (for youth, women and persons with disability).

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS

No.	QUERY	KPLC RESPONSE
1.	Item no. 13, 1x400 66KV Cable, the cable is required to be screened with Corrugated Aluminum Sheet (CAS), we are kindly requesting if we can submit an alternative description for the cable to be CU/XLPE/LEAD/PVC instead of CU/XLPE/CAS/PVC.	Lead is harmful to the environment and hence the company has stopped using it. Therefore, the screening shall remain Corrugated Aluminium sheets.
2.	For item 1,2,6,8, the description in BOQ are clear for us to quote price. But specification and GTP is lacking. Kindly share For item 3,10,11, the description in BOQ show it is copper electric wire with 7strands, but the single wire size 0.029,0.027 and 0.044 is wrong. Usually for 2.5mm2 copper conductor, it	Specification already shared Table 3 in the specification tsp-05-016 shows 2.5mm2 is 7/0.67 and 6mm2 is 7/1.04

	<p>is 7/0.67mm; For 6mm² copper conductor, it is 7/1.04mm, the specification and GTP is lacking. Kindly share.</p> <p>For item 9, the GTP is lacking. Kindly share</p>	<p>specification already attached.</p>
--	---	--

3. CLOSING DATE

The tender closing date remains 10:00 am on 17th October, 2019 and opens at 10:30 am 17th October, 2019.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY LIMITED


BERNARD NGUGI
GENERAL MANAGER, SUPPLY CHAIN