



Kenya Power

*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3201889
Stima Plaza, Kolobot Road*

Our Ref: KP1/9A.2/OT/34/ADMIN/18-19

18th February, 2019

**ADDENDUM NO. 1 TO THE TENDER NO. KP1/9A.2/OT/34/ADMIN/18-19 FOR
CONSTRUCTION OF KITALE COMMERCIAL OFFICE.**

The following amendments are made to the specified provisions of the Tender document.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. SECTION VII - BILL OF QUANTITIES (ELECTRICAL INSTALLATIONS)

The bill of quantities for electrical installation was omitted in the tender and are attached herewith.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.

EVA ANJICHI
AG. SUPPLY CHAIN MANAGER (PROCUREMENT)

BILL NO. IV- ELECTRICAL INSTALLATIONS

Item	Description	Qty	Unit	Rate (Kshs)	Amount (Kshs)
	Supply, install, test and commission the following ;-				
	<u>LIGHTING POINTS</u>				
A	Lighting points wired in 3x 1.5 mm ² SC CU cables drawn in 20mm diameter concealed HG P.V.C conduits for one way switching couplers , sandles clips junction boxes but excluding the fittings .	200	LM		
B	Lighting points wired in 3x 1.5 mm ² SC CU cables drawn in 20mm diameter concealed HG P.V.C conduits for two way switching couplers , sandles clips junction boxes but excluding the fittings .	400	LM		
	Piloted Flush mounted 10Amps wide rocker , switch plate as MK or approved equivalent as for				
C	One gang one way	9	No.		
D	Two gang two way	4	No.		
E	Two gang one way	2	No.		
F	Three gang One way	2	No.		
	<u>LIGHTING FITTINGS</u>				
	<u>Lighting fittings complete with electronic ballasts and tubes/lamps as follows:-</u>				
G	Type A- 1200x36W high frequency surface mounted slim section fluorescent light fitting with 28w LED tubes (frostred) , white finished steel body and ABS plastic end caps as Thorn Modulight or approved equivalent	9	No.		
H	Type B-600x600mm 36W slim LED panels frosted. high frequency ceiling luminaire with polycarbonate body and trim in white polycarbonate diffuser .	72	No.		
I	Type D) - Self contained single sided exit sign with 8W fluorescent lamp for maintained emergency lighting for 3 hour duration as Thorn EFX3 c/w CAT EFXF 7 Euro Legends or approved equivalent	2	No.		
SUB TOTAL C/F TO PRICE SUMMARY PAGE					

G. Namanya

Item	Description	Qty	Unit	Rate (Kshs)	Amount (Kshs)
POWER POINTS					
A	3x4 mm ² SC CU cables for twin flush wall mounted socket outlets drawn in 25mm Ø HG PVC conduit from distribution board concealed in walls.	600	LM		
B	13A flush mounted twin piloted white enamel moulded type socket outlet faceplate as MK cat2647 WHI or approved equivalent mounted flush on the wall .	50	No.		
C	45A DP cooker unit + 15A SP switched socket outlet neon indicators and marked cooker.	1	No.		
D	Cooker Connector unit as MK or equivalent	1	No.		
E	3x6.0 mm ² SC CU cables drawn in 25mmØ HG PVC conduit from distribution board for cooker point above	60	LM		
F	Piloted 20A DP isolator unit as MK cat 2202CH for undersink instantaneous water heaters	1	No		
G	Power points wired in 3x4 mm ² SC CU cables in concealed 20mm dia HG PVC conduit from distribution board to DP points for items above	1	No.		
AREA/PARKING LIGHTING.					
H	50W LED flood light lamp overall size 206x145.5mm with powder coated steel plate casement with holder complete with integral control gear, wiring in 1.5mm ² twin with earth sheathed cable from the distribution board for a height of upto 3metres on the wall.	8	No.		
I	60A/30mA ELCB as MEM or approved equivalent	1	No.		
J	Photo electric cell (Timer) as THORN cat No. QPK or approved equivalent	1	No.		
K	30 Amps. Triple pole contactor as TELEMECANIQUE or approved equivalent.	1	No.		
SUB TOTAL C/F TO PRICE SUMMARY PAGE					

G. B. N. M. S. S. S.

Item	Description	Qty	Unit	Rate (Kshc)	Amount (Kshc)
A	5 Metres, top entry, Galvanised steel post for mounting the photocell above.	1	No.		
B	1.5mm ² twin with earth sheathed copper cable drawn in 20 mm dia.PVC conduit from the distribution boardPVC/SWA/PVC copper cables complete with appropriate cable glands and lugs concealed in walls for security lights.	200	LM		
C	The following for items 10.1.15 & 10.1.16 above:- i.) Trenching to a depth of a minimum of 700mm	5	LM		
	ii) Tiling with 'HATARI' tiles	5	LM		
	ii) Back filling of the trenches	5	LM		
D	50mm diameter HG PVC ducts with 100 mm thick concrete sorround	5	LM		
	POWER DISTRIBUTIONS				
E	12way TPN, flush mounted distribution board complete with 125A integral isolator as MEM or approved equivalent complete with all accessories but excluding MCBs.	1	No.		
F	12way c/w 125A TPN integral isolator	1	No.		
	Miniature Circuit Breakers (MCB's/RCBOS) for item				
G	10A SP MCP	4	No.		
H	20A SP MCB	3	No.		
I	30A SP MCB	2	No.		
J	45A SP MCB	1	No.		
K	60A TPN MCB	1	No.		
L	TP blanking plate	9	No.		
SUB TOTAL C/F TO PRICE SUMMARY PAGE					

S. Namanda

Item	Description	Qty	Unit	Rate (Kshs)	Amount (Kshs)
	Earthing, for all electrical installation above of the following and any other necessary accessories to KEBS and KPLC approved standards.:-				
A	12.5 mm x 1200 mm earth rod as FURSE cat. No. RB 105.	1	No.		
B	12.5 mm dia. Driving stud as FURSE cat.No. ST100.	1	No.		
C	Rod to cable clamp as FURSE cat. No. CR510.	1	No.		
D	Concrete inspection pit as FURSE cat. No.PT005. (or a well made 320mm x 320mmx 210 mm depth pit.)	1	No.		
E	6mm sq. SC PVC CU cables drawn in 20 mm dia.PVC conduit concealed in walls.	20	LM		
SUB TOTAL C/F TO PRICE SUMMARY PAGE					

Bramasna

SUMMARY					
ITEM	DESCRIPTION			AMOUNT	
				KSHS	CTS
1	Total from page 1				
2	Total from page 2				
3	Total from page 3				
4	Total from page 4				
5	Allow for production of 3 copies of as installed drawings				
	TOTAL C/F TO GRAND SUMMARY				

Total amount in words :, Kenya

Tenderer's Name and Stamp.....

PinNo.....VAT Certificate

Witness.....Address.....

Signature of

Witness.....Date.....

Handwritten signature

Handwritten mark

