



Central Office - P.O. Box 30099 - 00100  
 Telephone – 254 – 02 - 3201000  
 Stima Plaza, Kolobot Road  
 Nairobi, Kenya  
[www.kenyapower.co.ke](http://www.kenyapower.co.ke)

**Our Ref: KP1/9AA-3/PT/82/14-15**

**22<sup>nd</sup> May 2015**

M/s .....

Dear Sirs,

**ADDENDUM NO. 1 TO THE THREE YEAR FRAMEWORK TENDER NO. KP1/9AA-3/PT/82/14-15 FOR SUPPLY OF PREPAID METERS 3 YEAR FRAMEWORK CONTRACT – OPEN TENDER**

The following amendments are made to the specified provisions of the Tender document for Supply of prepaid meters 3 year framework contract

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

**The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.**

**2. CLARIFICATION**

<b>QUERIES</b>	<b>RESPONSE</b>
Please advise on the right voltage of three phase meter with PLC communication	The voltage is 3*230V/400V. This applies for all the 3 phase meter specifications in this tender
Please advise whether is IP51 or IP54	The degree of protection for all the meters shall be IP 54
Is this voltage range fixed	The voltage range for the meter operation remains $0.5U_n$ to $1.15U_n$ , but the load switch shall interrupt if voltage falls below $0.4U_n$ and above $1.15U_n$ and restore power when the voltage falls within the range $0.4U_n$ to $1.15U_n$ .
On Page 7 of technical specification for three phase whole current (direct connected) static meters for active energy, Clause 4.2.41 says " A laptop computer and two optical probes, for programming and down loading the meter data shall be provided at no extra cost."	The Laptop Computers will be supplied by the winning bidder after award of tender

: Do bidder need provide the laptop computer with sample meters before tender closing date? or is it only required when supplying meters in batch after tender award	
Foreign bidders to quote 'Total price DAP, VAT & Duty Inclusive. Please clarify if IDF and RDL should be included in DAP or we just need to include inspections and clearing charges as well as delivery	DAP includes all charges excluding VAT and Duty, meaning DAP price should include all other charges

### 3. DEADLINE FOR SUBMISSION OF TENDER

The closing date for the tender remains **Friday 12<sup>th</sup> June 2015 at 10.00 a.m.** Tenders shall be opened immediately thereafter in the Auditorium located at Stima Plaza, Kolobot Road, Nairobi.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

**For: KENYA POWER & LIGHTING COMPANY LIMITED.**

  
Bernard Ngugi

**Ag.GENERAL MANAGER, SUPPLY CHAIN**