



Kenya Power

The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000-Telegrams 'ELECTRIC'- www.kenyapower.co.ke
Stima Plaza, Kolobot Road

Our Ref: KP1/6E.1//PT/1/19/AO1/EAO/ao

7th August, 2019

Dear Sir/ Madam:

CLARIFICATION No.1 OF BIDDING DOCUMENT FOR ICB NO: KP1/6E.1/PT/1/19/AO1 FOR SUPPLY OF UNIVERSAL CLAMPS FOR THE LAST MILE CONNECTIVITY PROJECT.

1. CLARIFICATION TO BID DOCUMENT

The following responses are made to clarifications sought on various issues in the Bidding Documents for Procurement of Universal Clamps.

No	Query	Response
1	<p>While preparing the proposal, our team has come across a point which is creating confusion. We Urgently need clarification from your end. Please refer to the above Subject. We would like to participate in the above mentioned tender. we have the following clarifications from the manufacturer regarding the type of universal clamps. Kindly give us the KPLC code for the Universal Clamp L/Duty(178-203MM.HS/DXA/T/TX as per your specification.</p> <p>In the tender document Section VI requirements/1.list of goods and related service, the quantity is: Universal Clamp L/Duty (178-203MM.HS/DXA/T/TX) 487,010pcs. However, in the Technical Specification and drawings, there are 3 types of 178-203 light duty universal clamps, which include horizontal section clamp, intermediate pole clamp and section/stay clamp. Please clarify the quantity for each type of clamps respectively or if the quantity is for one type which type is it.</p>	<p>We are procuring one type of the universal clamps.</p> <p>The item to be purchased is the light Duty Multipurpose Clamp 178-203MM TX (TSP/02/004/02 intermediate pole clamp) figure 2 in our specifications. The center bolt shall be M16X 50MM fully threaded. The rib bolts remain the same.</p>

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.


BERNARD NGUGI
GENERAL MANAGER, SUPPLY CHAIN