



Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9AA-3/PT/68/14-15

Date: 20th March 2015

M/s
.....

Dear Sirs,

ADDENDUM NO.1 TO THE TENDER NO.KP1/9AA-3/PT/68/14-15 FOR SUPPLY OF POLE MOUNTED METER BOX AND GRINDERS

The following amendments are made to the specified provisions of the Tender document for Supply of Pole Mounted Meter Box and Grinders dated 03.03.2015.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. THE FOLLOWING CLARIFICATIONS ARE MADE:

Question I: Confirm the exact materials for the meter box? Usually we use SMC material

Answer: Clause 7.1 is amended to read as follows;

The material shall be polycarbonate, made to a weather proof finish

Question II: What exact material for the steel mounting bars (fig 3)? Stainless steel or zinc-coated steel sheet? and what thickness is required?

Answer: Type of Material for steel bars is Galvanized steel (Thus zinc coated is okay). Thickness is 1.5 mm

3. THE TENDER IS AMENDED AS FOLLOWS;

Clause 5.3 (d) is now amended to read as follows:

5.3 (d) 20 fastening and un-fastening tools for the brackets/ straps shall be supplied

4. DEADLINE FOR SUBMISSION OF TENDER

The new closing date for the tender is **Tuesday 7th April, 2015 at 10.00 a.m.**

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.


B. K. NGUGI
AG. GENERAL MANAGER, SUPPLY CHAIN